

COWLITZ

COUNTY

DEPARTMENT OF COMMUNITY DEVELOPMENT

COUNTY ADMINISTRATION BLDG.—207 FOURTH AVENUE, NORTH
KELSO, WASHINGTON 98626 TEL. NO. 577-3052

REPAIR

SEWAGE PERMIT APPROVAL

Property Address: 1654 North 2nd Avenue Town Kelso

Permit Name: Hamar Construction/ Wash. Mutual

Home Address: 114 Alturas Drive

City Kelso State Wash. Zip Code 98626

Section: _____ Township _____ Range _____ Tax Lot# 3A-B1 Parcel No. 62885

Subdivision F. Smith DLC Lot _____ AF# 860,521,038
Block _____

Lot Size _____ Number of Acres 0.23

APPROVED FOR: REPAIR of Septic System for 2 bedroom home

Septic Tank: 750 Gallon minimum Capacity (two compartment)

Drainfield: 350 Sq. Ft., Total minimum (length X width of trenches)

Suggested layout of system:

Number of drainfield lines: 4

Length of drainfield lines: 30 feet } OR }

Width of distribution lines: 3 feet

Trench Depth: Minimum 12 Maximum 12 in. Depth into natural ground 12 inches

Minimum distance between Trenches — Center to Center 7½ feet

OTHER REQUIREMENTS:

- 1) A 12inch capping fill is needed to assure adequate treatment of the sewage effluent before it reaches the seasonally high water table.
- 2) Maintain 10 feet minimum setbacks from property lines, and buildings.
- 3) Pumped the old steel tank and replace or fill with gravel and cover with soil ; a new septic tank is required .

Please call me if there are any questions at 577-3052.

OTHER ITEMS

SOIL DATA:
0-14 Sil
14-54 layers PSL VPSL
MOTTLES FROM 20"
SOME RESIDUAL FROM LANDSCAPE POSITION
5% slope behind GARAGE TOWARD REAR DROP LINE


ENCLOSURES _____

APPROVED BY: Pedro Theodor Jr. CES DATE: 7/22/86

MEMORANDUM

Cowlitz County
Department of Community Development
207 Fourth Avenue North
Kelso, Washington 98626
Telephone: (206) 577-3052

DATE: 7/22/86
TO: Hamar Construction/ Washington Mutual
FROM: Pedro Pescador Jr., CPSS
SUBJ: SKETCH ONLY- Repair of septic system at 1654 North 2nd Ave., Kelso



Pedro Pescador Jr. CPSS