MASTER APPLICATION

(Please Print)

Permit No. _____
Date _____ By _____

APPLICANT ARLETHA M. HILL TELEPHONE 423-3577
ADDRESS 1119 22nd. Ave. CITY Longview STATE WA ZIP 98632
PROPERTY OWNER WALTER FRYE TELEPHONE none
ADDRESS 424 N. 50th. CITY Longview STATE WA ZIP 98632

****

PROJECT LOCATION
ADDRESS 424 50th CITY Longview
SUBDIVISION Rewey's Clark Creek Ac. LOT 7 BLOCK 4
SECTION _____ TOWNSHIP _____ RANGE _____ TAX LOT NO. _____
LOT DIMENSIONS _____ PARCEL WL 122002.0 ACRES App. ½ ac.

****

BUILDER _____ LICENSE NO _____
DESCRIBE PROJECT Address, soil test for ex. House. (house never been lived in + no system ever put in there) was used for stge

Type of Heating _____ Fair Market Value $ _____
No. of Structures in Project 1 Bedrooms 2
Water Supplied by City of Longview Private X Public _____ Existing _____ Proposed X
Sewage disposed by Septic Private X Public _____ Existing _____ Proposed X

VICINITY SKETCH **PLOT PLAN**



The above information and attachments are true and correct to the best of my knowledge and if any additions are required my application will not be processed until I forward it.

Date November 7th 1980 App. Signature Arletha Hill

PERMIT FEES

Building _____
Plan Check _____ %
Mobile Home _____
Plumb/Mech _____
Sewage App 25.00
Other _____
TOTAL _____

OFFICE USE ONLY

Land Use District CP-SR Occupancy _____ Address Stake Up 11-10-80
Address ~~424~~ N 50th By _____ Soil Test 11-12-80

SPECIAL NOTES: Cannot drive into property - park across street - also, can obtain easement for drainfield on neighboring prop.

008315
11-7-80
BB

MINIMUM SPECIFICATIONS:

ISSUE CENTER

_____ Permit Approved By: _____

COWLITZ COUNTY

DEPARTMENT OF COMMUNITY DEVELOPMENT
COUNTY ADMINISTRATION BLDG.—207 FOURTH AVENUE, NORTH
KELSO, WASHINGTON 98626 TEL. NO. 577-3052

SEWAGE PERMIT APPROVAL

Property Address: 424 No. 50th Town LOngview

Permit Name: Arletha M. Hill

Home Address: 1119 22nd. Avenue

City Longview State Washington Zip Code 98632

Section: _____ Township _____ Range _____ Tax Lot# _____ Parcel No. _____

Subdivision Rewey's Clark Creek Ac. Lot 7 Block 4

Lot Size _____ Number of Acres .50

APPROVED FOR: TWO BEDROOM DWELLING

Septic Tank: 750 Gallon minimum Capacity (two compartment)

Drainfield: 360 Sq. Ft., Total minimum (length X width of trenches)

Suggested layout of system:

Number of drainfield lines: 2 | OR | ----------

Length of drainfield lines: 60 feet | | ----------

Width of distribution lines: 3 feet | | ----------

Trench Depth: Minimum 18 inches Maximum 24 inches Depth into natural ground _____

Minimum distance between Trenches — Center to Center 7½ feet

OTHER REQUIREMENTS:

1/The drainfield must remain a minimum distance of 15 feet from the road embankement.
2/The drainfield must be established along slope contours trench bottoms must remain level.
3/The drainfield must remain a minimum distance of 10 feet from all property boundaries, trees, and buildings.
4/The drainfield must not be driven upon at any time.

OTHER ITEMS

Slope = 4%
≈ 0-8" SL
≈ 8-40" Sandy Silt loam
≈ 40"+ - 48" Silty Clay loam

ENCLOSURES _____

APPROVED BY: [signature] DATE: NOV. 12, 1980