COWLITZ COUNTY

DEPARTMENT OF COMMUNITY DEVELOPMENT

COUNTY ADMINISTRATION BLDG.—207 FOURTH AVENUE, NORTH
KELSO, WASHINGTON 98626 TEL. NO. 577-3052

SEWAGE PERMIT APPROVAL

Property Address: 560 North 50th. Town Longview

Permit Name: Mr. Charles W. Davis

Home Address: 4303 Greenway Place

City Longview State Washington Zip Code 98632

Section: 12 Township 8 N. Range 3 W. Tax Lot# _____ Parcel No. WL1220029

Subdivision _____ Lot _____ Block _____

Lot Size _____ Number of Acres 5.0

APPROVED FOR: Three Bedroom Dwelling

Septic Tank: 900 Gallon minimum Capacity (two compartment)

Drainfield: 630 Sq. Ft., Total minimum (length X width of trenches)

Suggested layout of system:

Number of drainfield lines: 3
Length of drainfield lines: 70 feet
Width of distribution lines: 3 feet

OR inadequate area for more than three lines plus the replacement area

Trench Depth: Minimum 18 inches Maximum 24 inches Depth into natural ground _____

Minimum distance between Trenches — Center to Center 7 ½ feet

OTHER REQUIREMENTS:

1/ A water diversion trench will be installed along the uphill side of the driveway
2/ ~~The drainfield will be established along slope contours, trench bottoms~~ will remain level and not driven upon at any time.
3/ The drainfield will remaina minimum of 100 feet from all surface waters ~~and wells, including those located on adjacent properties~~
4/ The drainfield will remain a minimum distance of 10 feet from all property boundaries, trees, and buildings.
5/ ~~All surface drains such as from roof downspouts will be channeled away~~ from the drainfield location.
6/ The drainfield will not be built upon at any time.

OTHER ITEMS

Slope ≈ 10%
≈ 0-30" Silt loam
≈ 30-40-46" Silty clay loam
≈ 46"+ Decaying rock w/ Clay loam

ENCLOSURES _____

APPROVED BY: [signature] DATE: October 18 1979

MASTER APPLICATION

(Please Print)

Permit No. 657
Date 7-22-81 By BB

APPLICANT CHARLES W. DAVIS TELEPHONE 425 6866
ADDRESS 4303 GREENWAY PLACE CITY LONGVIEW STATE WA ZIP 98632
PROPERTY OWNER DON DAVIS (SAME AS ABOVE) TELEPHONE
ADDRESS CITY STATE ZIP

****

PROJECT LOCATION
ADDRESS 560 NORTH 50 TH CITY LONGVIEW, WA.
SUBDIVISION REWEYS CLARK CREEK ACRES LOT 6 BLOCK 2
SECTION 12 TOWNSHIP 8 N RANGE 3 W TAX LOT NO.
LOT DIMENSIONS 644X325 PARCEL# WL12200029 ACRES 5

****

BUILDER OWNER LICENSE NO
DESCRIBE PROJECT ADDRESS - SOIL TEST - FOR A PROPOSED THREE BEDROOM ~~HOME~~ Mobile Home
MOBILE HOME
1972 4 SEASONS; VALUE #6200.00
Type of Heating ELECTRIC Fair Market Value $ ~~50,000.00~~ 6200.00
No. of Structures in Project Bedrooms 3
Water Supplied by CITY OF LONGVIEW Private Public X Existing X Proposed
Sewage disposed by SEPTIC Private X Public Existing Proposed

VICINITY SKETCH



PLOT PLAN



The above information and attachments are true and correct to the best of my knowledge and if any additions are required my application will not be processed until I forward it.

Date 10/5/79 App. Signature Charles W. Davis

PERMIT FEES

Building	
Plan Check	%
Mobile Home	20.00
Plumb/Mech	10.00
Sewage App	25.00 pd receipt #007321 on 10-8-79
Other	
TOTAL	30.00 MH

OFFICE USE ONLY

Land Use District LP-F-Osp. Occupancy Address Stake Up
Address 560 - No 50th By Soil Test Oct 14 1979

SPECIAL NOTES:

Next to (south side) 570 - No 50th

Re-applied for Mobile Home Permit 4-30-81 BB

MINIMUM SPECIFICATIONS:

Tie Downs to Mobile Home to be called for inspection within 30 days. Hookup inspection to water system required.

ISSUE CENTER

Date Permit Approved By: