[illegible]TZ COUNTY DEPARTMENT OF COMMUNITY DEVELOPM[illegible]
207 FOURTH AVENUE NORTH ♦ KELSO, WASHINGTON 98626 ♦ TELEPHONE (206) 577-3052

SUBSURFACE SEWAGE APPLICATION FOR **SITE EVALUATION**

#BC-123-88

Property Location: 2839 ALLEN STREET
11/1/88 KELSO, WA 98626 Lot No. _____
Section 25 -Township 8N-Range 2W Tax Lot # 16D-2 Parcel # WI2516015 Acres 2.13

FIELD INFORMATION

General Topography 20-25% TERRACE EDGE— UNDULATING

Relationship to Existing Domestic Water Sources WELL OR SPRING

Hydrology: Depth to Ground Water Table (representative) >5' EXCEPT FOR HOLE #1 (WEST) WHICH IS IN THE SEASONAL SWALE.

Relationship to Surface Waters CREEK NORTH OF SITE ≈100 FT.

Soil Profile #1 0-32" Vdk BRN SiL
33-60 BRN MOTTLED SiCL

#2 0-60"+ BRN GR. SiL (COLD FILL)
#3 0-36" BRN SiL
36-60+ LT. BRN VFSL RESIDUAL MOTTLES.

* ROAD AND PAD CUT — 6'

Miscellaneous Information 70'/BEDROOM X 2 = 140 FT. = 420 FT.²
SERIAL SYSTEM.— EVEN OUT SLOPE — AVOID HOLE #1
* SUGGEST 3 BEDROOM SYSTEM — ADD 70 FT.

PLOT PLAN