[illegible]WLITZ COUNTY DEPARTMENT OF BUILDING AND [illegible]
207 FOURTH AVENUE NORTH ♦ KELSO, WASHINGTON 98626 ♦ TELEPHONE (206) 577-3052

SUBSURFACE SEWAGE APPLICATION FOR **SITE EVALUATION** #RC-19-94

Property Location: 3115 ALLEN ST. ROAD
4/4/94 KELSO, WA 98626 Lot No.

Section 30 Township 8N Range 1W Tax Lot # 3F Parcel # WE3003007 Acres 1.25

FIELD INFORMATION

General Topography 0-2% OLD TERRACE SILTS

Relationship to Existing Domestic Water Sources WELL-SHARED-EAST.

Hydrology: Depth to Ground Water Table (representative) > 36"

Relationship to Surface Waters CREEK-NORTH OF TERRACE

Soil Profile 0-36" DK-BRN-BRN Sil mmSAB

* ADJUST AS NEEDED W/ 100 FT. SETBACK FROM WELL AND CREEK.

Miscellaneous Information 70'/BEDROOM X 2 = 140 FT. = 420 FT.$^2$ LOOP SYSTEM.

PLOT PLAN