

-SITE CHARACTERISTICS

Topography: General Topographic Characteristics north facing slope  
Drainage Characteristics: first order stream 120'+ to north  
Slopes: General 0-50 %; Proposed Drainfield Location 0 %  
Geology: Type of Bedrock & Depth no data  
Vegetation: cleared  
Distance to, and type of, nearest surface water: 120'+  
(If Less than 250 Feet)  
Distance to nearby wells: NA  
(If Less than 250 Feet)  
Distance to public sewers: NA  
(If Less than 500 Feet)  
Other structures on property: NA

-SOIL SERIES

As mapped by U.S. Soil Conservation Service: Rose Valley silt loam (?)  
Appears to be (if different from S.C.S. Classification): NA

-SOIL LOGS

<u>Depth</u>	<u>Description</u>	<u>Comments</u>
<u>0"-10"</u>	<u>silt loam</u>	<u>dark brown</u>
<u>10"-26"</u>	<u>silt loam</u>	<u>light brown to red brown</u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>
<u> </u>	<u> </u>	<u> </u>

-MAXIMUM SEASONAL GROUNDWATER ELEVATION

Soil Mottling 26" Water Table not found  
(Depth Found & Degree of Development) (Depth to Standing Water)

COMMENTS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

-SITE CHARACTERISTICS

3303 Allen Street

Topography: General Topographic Characteristics: west facing slope

Drainage Characteristics: generally not well drained

Slopes: General 0-50 %; Proposed Drainfield Location 0 %

Geology: Type of Bedrock & Depth no data

Vegetation: partially cutover second growth mixed forest

Distance to, and type of, nearest surface water: small stream 125' south  
(If Less than 250 Feet)

Distance to nearby wells: NA  
(If Less than 250 Feet)

Distance to public sewers: NA  
(If Less than 500 Feet)

Other structures on property: NA

-SOIL SERIES

As mapped by U.S. Soil Conservation Service: KeB

Appears to be (if different from S.C.S. Classification): KeA

-SOIL LOGS

<u>Depth</u>	<u>Description</u>	<u>Comments</u>
<u>0"-10"</u>	<u>silt loam</u>	<u>dark brown</u>
<u>10"-26"</u>	<u>silt loam</u>	<u>light brown</u>
<u>26"-48"</u>	<u>silty clay loam</u>	<u>mottled</u>

<u>Depth</u>	<u>Description</u>	<u>Comments</u>
<u>0"-14"</u>	<u>silt loam</u>	<u>dark brown</u>
<u>14"-30"</u>	<u>silt loam</u>	<u>light brown</u>
<u>30"-48"</u>	<u>silty clay loam</u>	<u>mottled</u>

<u>Depth</u>	<u>Description</u>	<u>Comments</u>

-MAXIMUM SEASONAL GROUNDWATER ELEVATION

Soil Mottling 26"-30" Water Table not observed  
(Depth Found & Degree of Development) (Depth to Standing Water)

COMMENTS: 3'-4' high bank over 30% 60' to 70' down slope

**MASTER APPLICATION**

Print Legible Press Hard

Permit NO. 1171  
 Date 7-2-82 By BB  
82-06-44



APPLICANT John Burns TELEPHONE 577-5860  
 ADDRESS 3234 Allen Street CITY Kelso STATE \_\_\_\_\_ ZIP 98626  
 PROPERTY OWNER Same as above TELEPHONE \_\_\_\_\_  
 ADDRESS \_\_\_\_\_ CITY \_\_\_\_\_ STATE \_\_\_\_\_ ZIP \_\_\_\_\_

\*\*\*\*\* 3302 \*\*\*\*\*  
 PROJECT ADDRESS NO. 303 STREET Allen Street CITY Kelso  
 SUBDIVISION \_\_\_\_\_ LOT \_\_\_\_\_ BLOCK \_\_\_\_\_  
 SECTION 30 TOWNSHIP 8N RANGE 1W TAX LOT NO. 13C  
 PARCEL NO. WE30-13-004 ACRES 3.71 AUDITORS FEE NO. 549,487

\*\*\*\*\*  
 DESCRIBE PROJECT Health District review of Wisconsin mound  
CONSTRUCT 2 BDRM DWELLING 6-17-82 NO. OF BDRMS. 2  
 WATER SUPPLIED BY: well Private  Public \_\_\_\_\_ Existing \_\_\_\_\_ New   
 SEWAGE DISPOSED BY: septic system Private  Public \_\_\_\_\_ Existing \_\_\_\_\_ New   
 BUILDER Self CONTRACTORS LICENSE NO. \_\_\_\_\_  
 TYPE OF HEATING \_\_\_\_\_ FAIR MARKET VALUE OF PROJECT 63,640 53,060

**VICINITY SKETCH**

**SITE PLAN**



The above information and attachments are true and correct to the best of my knowledge and if any additions are required my application will not be processed until I forward it.

Date 12/16/81 Applicants Signature John Burns  
6-17-82 PLEASE NOTE BACK OF CARD FOR BUILDING INSPECTION REQUIREMENTS

**MINIMUM SPECIFICATIONS**

Date 6-21-82 Permit Approved By [Signature]

	PERMIT FEES	CODE	BY
Soil Evaluation			
Final Inspection			
Transfer			
Building	<u>325.00</u>	<u>S.F.</u>	<u>ETW</u>
San Check	<u>4020 / 30.00</u>		
Plumb/Mech	<u>Plumb Mech.</u>		
Mobile Home			
Other			
TOTAL	<u>413.00</u> <u>455.00</u>		

Zoning AG Comp Plan \_\_\_\_\_ Flood Plain \_\_\_\_\_  
 Type of Occupancy: Existing \_\_\_\_\_ Proposed R-3  
 Address stake will be placed-Date: \_\_\_\_\_ By: [Signature] Date: 12/21/81  
 Address Assigned: 3302 ALLEN ST  
 Soil Test Date \_\_\_\_\_ Re-test \_\_\_\_\_

SPECIAL NOTES:  
Process for bldg. 6-17-82 BB

Property is zoned AG (minimum 5 acres) lot size.

★ Must under go zoning change and short plat property prior to permit approval.  
 FINAL inspection approval soil: Date \_\_\_\_\_ By \_\_\_\_\_  
 FINAL inspection approval bldg: Date \_\_\_\_\_ By \_\_\_\_\_

Receipt No. 009975 Date 7-2-82  
 Receipt No. Refund 72.00 Date 7-6-82  
 Receipt No. \_\_\_\_\_ Date \_\_\_\_\_