COWLITZ COUNTY DEPARTMENT OF COMMUNITY DEVELOPMENT
207 FOURTH AVENUE NORTH ♦ KELSO, WASHINGTON 98626 ♦ TELEPHONE (206) 577-3052

SUBSURFACE SEWAGE APPLICATION FOR **SITE EVALUATION**

#EC-118-91

Property Location: 771 HAZEL DELL ROAD
7/11/91 CASTLE ROCK, WA 98611 Lot No. 1
Section 33 -Township 9N -Range 2W Tax Lot # 13, 13D Parcel # WJ3313002 -3313007 Acres 2.0+ OF 11.9

FIELD INFORMATION

General Topography 15-30% RESIDUAL UPLANDS.

Relationship to Existing Domestic Water Sources WELL (PROPOSED)

Hydrology: Depth to Ground Water Table (representative) >60"

Relationship to Surface Waters N/A

Soil Profile ALL 0-60" BRN/LT. BRN/LT. RED. BRN SIL/GR. SIL
NO MOTTLES. MMSAB.

* ADJUST TO ACTUAL HOMESITE & WELLS.
* 25% = SLOPE LIMIT OF BACKHOE

Miscellaneous Information 70'/BEDROOM X 3 = 210 FT. = 630 FT.²
SERIAL SYSTEM.

PLOT PLAN