DEPARTMENT OF BUILDING AND PLANNING

COWLITZ COUNTY

SUBSURFACE SEWAGE APPLICATION FOR SITE EVALUATION

Property Location: 485 Apple Creek Road. #EC-223-97
8/21/97 Longview, WA 98632

Lot No. _____ Section 23 - Township 9N - Range 4W Tax Lot # 14A-2 14B-2, 14B-3 Parcel # WC2304009 Acres 5.16

FIELD INFORMATION

General Topography 0-2% gently undulating old floodplain

Relationship to Existing Domestic Water Sources Well (proposed)

Hydrology: Depth to Ground Water Table (representative) > 60"+

Relationship to Surface Waters Creeks - East & West.

Soil Profile 0-60' DKBRN-YBRN SiC MINSAB - NO MOTTLES

*Adjust as needed w/ 100 ft. setback from creeks and well.

Miscellaneous Information: 70'/bedroom x 3 = 210 ft. = 630 ft.²
Loop System.

PLOT PLAN



270.3:1(r9/96:wH500)