DEPARTMENT OF BUILDING AND PLANNING

COWLITZ COUNTY

SUBSURFACE SEWAGE APPLICATION FOR SITE EVALUATION

CPSS.
7/8/99

Property Location: 131 A TIMBERLINE DRIVE. #EC-167-99
CASTLE ROCK, WA 98611

Lot No. 2 Section 1 - Township 9N - Range 2W Tax Lot # 5D Parcel # WJ01105003 Acres 2.40

FIELD INFORMATION

General Topography 8-10% RESIDUAL-COLLUVIAL UPLANDS

Relationship to Existing Domestic Water Sources P.U.D.

Hydrology: Depth to Ground Water Table (representative) >60"+

Relationship to Surface Waters N/A

Soil Profile 0-60"+ DK BRN-Y/RED BRN SIL/GR SICC MMSAB/MOSAB
NO MOTTLES- FRIABLE SUBSTRATE.

* ADJUST AS NEEDED W/ 5 FT. SETBACK FROM LOTLINES AND FOUNDATION - 10 FT. FROM TREES.

Miscellaneous Information: 80'/BEDROOM X 3 = 240 FT. = 720 FT.²
SERIAL SYSTEM

PLOT PLAN