MASTER APPLICATION

Print Legible — Press Hard

Appl/Permit NO. _____
Date _____ By _____
Plan Check NO. _____

APPLICANT Mildred B Pollock TELEPHONE 796-4951
ADDRESS 814 Hwy 101 South CITY Brinnon STATE WA ZIP 98320
PROPERTY OWNER SAME TELEPHONE _____
MAILING ADDRESS _____ CITY _____ STATE _____ ZIP _____

****

PROJECT ADDRESS NO. 15057 STREET Lewis River Rd. CITY Ariel
SUBDIVISION _____ LOT _____ BLOCK _____
SECTION 17 TOWNSHIP 6 N RANGE 4 E TAX LOT NO. _____
PARCEL NO. ER-17-02-009 ACRES 2 1/2 AUDITORS FEE NO. _____

****

DESCRIBE PROJECT No Development Plans at Present - Soil Test out of 5 years

NO. OF BDRMS. _____

WATER SUPPLIED BY: Well Private X Public ____ Existing ____ New X
SEWAGE DISPOSED BY: Septic Tank Private X Public ____ Existing ____ New X
BUILDER _____ CONTRACTORS LICENSE NO. _____
TYPE OF HEATING _____ FAIR MARKET VALUE OF PROJECT _____

VICINITY SKETCH



SITE PLAN



The above information and attachments are true and correct to the best of my knowledge and if any additions are required my application will not be processed until I forward it.

Date 10-22-82 Applicants Signature Mildred B Pollock

PLEASE NOTE BACK OF CARD FOR BUILDING INSPECTION REQUIREMENTS

MINIMUM SPECIFICATIONS

Date _____ Permit Approved By _____

	PERMIT FEES	CODE	BY
Soil Evaluation	25.00	SN	DKB
Final Inspection			
Transfer			
Building			
Plan Check			
Plmb/Mech			
Mobile Home			
Other			
TOTAL			

Zoning _____ Comp Plan RR-2 Flood Plain _____
Type of Occupancy: Existing _____ Proposed _____
Address stake will be placed-Date: _____ By: _____ Date: _____
Address Assigned: _____
Soil Test Date _____ Re-test _____
SPECIAL NOTES:

No issuance of permits until short plat approved.

1. Receipt No. 010273 Date 10-21-82
2. Receipt No. _____ Date _____
3. Receipt No. _____ Date _____

FINAL inspection approval soil: Date _____ By _____
FINAL inspection approval bldg: Date _____ By _____

COWLITZ COUNTY

DEPARTMENT OF COMMUNITY DEVELOPMENT
COUNTY ADMINISTRATION BLDG.—207 FOURTH AVENUE, NORTH
KELSO, WASHINGTON 98626 TEL. NO. 577-3052

SEWAGE PERMIT APPROVAL

Property Address: 15057 Lewis River Road Town Ariel

Permit Name: Richard Malone

Home Address: Rt. 1 Box 372

City Amboy State WA Zip Code 98601

Section: 17 Township 6N Range 4E Tax Lot# 6A-1 Parcel No. ER1702009

Subdivision Aultman Short plat #83007 Lot 1 Block

Lot Size Number of Acres 2.36 acres

APPROVED FOR: THREE BEDROOM DWELLING SEPTIC SYSTEM

Septic Tank: 900 Gallon minimum Capacity (two compartment)

Drainfield: 630 Sq. Ft., Total minimum (length X width of trenches)

Suggested layout of system:

Number of drainfield lines: 3 | OR

Length of drainfield lines: 70 feet | OR

Width of distribution lines: 3 feet | OR

Trench Depth: Minimum 20 inches Maximum 30 inches Depth into natural ground ----------

Minimum distance between Trenches — Center to Center 7½ feet

OTHER REQUIREMENTS:

1/ The drainfield shall remain a minimum distance of 100 feet from all wells and surface waters, including those located on adjacent properties.

2/ The drainfield shall remain a minimum distance of 10 feet from all trees, property boundaries, water lines under pressure, and buildings.

3/ The drainfield shall be established along slope contours, trench bottoms shall remain level and not be driven nor graded upon at any time.

4/ All gutter downspouts and other surface drains shall be channeled away from the drainfield area.

5/ Drainfield laterals shall be installed level to no more than 6 inches of drop per 100 feet.

OTHER ITEMS

0-10" dk brn organic loam friable

10-27" buff brn loam - mod-fine-granular

27-48" buff brn. silt loam looks like single grain sandy loam but rubs out to silt loam.

0-27" brn. sil. friable

27-54 - brn firm (weakly cemented silt loam

ENCLOSURES low bulk density - mod-fine sab structure

APPROVED BY: Don Olson DATE: May 20 85