



UTILITY MAP MUST SHOW:

- 1. Location of property. >
- 2. Directional arrow indicating north. >
- 3. Any adjacent property addresses and landmarks near subject property. >
- 4. Nearest intersecting roads. >



DO NOT USE SITE PLAN FRAME AS PROPERTY LINES!



07110000

NOV 06 2012

SITE PLAN MUST SHOW:

- 1. Lot dimensions and property lines.
- 2. Directional arrow indicating north.
- 3. Road location and any existing or proposed driveways.
- 4. All proposed and existing structures, their dimensions and distances to each other, to property lines and to centerline of road.
- 5. Location of soil test area, drainfield, reserve drainfield area, slope of land, well, and their distances to proposed structures or projects.
- 6. Location and amount of any fill or grading.
- 7. Location of address stake, if applicable.
- 8. All bodies of water, natural and manmade (streams, creeks, rivers, ditches, etc.), and distance to proposed structures or development.
- 9. All easements (utility, access, etc.)
- 10. Adjacent property addresses and uses.
- 11. Draw to scale, if possible.

SOIL EVALUATION REPORT

#EC-315-97

PROPERTY LOCATION 188 Aultman Road, ~~188~~ ARIEL

APPLICANT: Doug Ray PHONE: 360-256-0557

MAILING ADDRESS: 7416 N.E. 69th St., Vancouver, WA 98662  
CITY STATE ZIP

SPECIFICATIONS:

FOR 3 BEDROOM DWELLING: SEPTIC TANK 900 GALLON MINIMUM CAPACITY (TWO COMPARTMENT)

TYPE OF WATER SUPPLY DRAINFIELD 720 SQUARE FEET TOTAL MINIMUM (LENGTH X WIDTH OF TRENCHES)

Private well

EXISTING \_\_\_\_\_ PROPOSED xy

LAYOUT OF SYSTEM:

NUMBER OF DRAINFIELD LINES: 3 OR \_\_\_\_\_  
LENGTH OF DRAINFIELD LINES: 80' OR \_\_\_\_\_  
WIDTH OF DRAINFIELD LINES: 3' OR \_\_\_\_\_

TRENCH DEPTH: MINIMUM 18", MAXIMUM 24"

MINIMUM DISTANCE BETWEEN TRENCHES (CENTER TO CENTER): 7.5'

ADDITIONAL REQUIREMENTS:

97112000

NOTE:

This approval indicates that this site is suitable for septic tank and drainfield use. A septic tank permit will be issued by the Department of Community Development provided the site meets the requirements of other relevant regulations such as the County Comprehensive Plan, the Subdivision Ordinance, and the Shoreline Management Plan.

- OFFICE COPY
- DCD COPY \_\_\_\_\_  
Date Sent
- APPLICANT'S COPY \_\_\_\_\_  
Date Sent

SUBMITTED BY: *Milly Ben*  
11/4/97  
Date

FOV

-SITE CHARACTERISTICS-

Topography: General Topographic Characteristics Essentially Flat  
 Drainage Characteristics: Well Drained

Slopes: General 0 - 2 %; Proposed Drainfield Location 0 - 2 %

Geology: Type of Bedrock & Depth No Data

Vegetation: Fir second growth

Distance to, and type of, nearest surface water: NA  
 (If Less than 250 Feet)

Distance to nearby wells: NA  
 (If Less than 250 Feet)

Distance to public sewers: NA  
 (If Less than 250 Feet)

Other structures on property: NA

-SOIL SERIES-

As mapped by U.S. Soil Conservation Service: Cinnabar Silt Loam  
 Appears to be (if different from S.C.S. Classification): \_\_\_\_\_

-SOIL LOGS

W. Hole

<u>Depth</u>	<u>Description</u>	<u>Comments</u>
0 - 8"	Silt Loam	A Horizon
8 - 60"	Sandy Silt Loam	

<u>Depth</u>	<u>Description</u>	<u>Comments</u>
0 - 4"	Silt Loam	A Horizon
4 - 60"	Sandy Silt Loam	

97110300

<u>Depth</u>	<u>Description</u>	<u>Comments</u>

-MAXIMUM SEASONAL GROUNDWATER ELEVATION

Soil Mottling \_\_\_\_\_ Water Table \_\_\_\_\_  
 (Depth Found & Degree of Development) (Depth to Standing Water)

COMMENTS: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

SOIL EVALUATION REPORT

PROPERTY LOCATION 15069 Lewis River Road, Ariel, WA

APPLICANT: Doug Ray PHONE: (206) 256-0557

MAILING ADDRESS: 7416 N.E. 69th Vancouver WA 98662  
CITY STATE ZIP

SPECIFICATIONS:

FOR 3 BEDROOM DWELLING: SEPTIC TANK 900 GALLON MINIMUM CAPACITY (TWO COMPARTMENT)

TYPE OF WATER SUPPLY: DRAINFIELD 540 SQUARE FEET TOTAL MINIMUM (LENGTH X WIDTH OF TRENCHES)

Well  
EXISTING \_\_\_\_\_ PROPOSED X

LAYOUT OF SYSTEM:

NUMBER OF DRAINFIELD LINES: 3 OR 4  
LENGTH OF DRAINFIELD LINES: 68 OR 52  
WIDTH OF DRAINFIELD LINES: 3' OR 3'  
TRENCH DEPTH: MINIMUM 18", MAXIMUM 24"  
MINIMUM DISTANCE BETWEEN TRENCHES (CENTER TO CENTER): 7.5'

ADDITIONAL REQUIREMENTS:


\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

NOTE:

This approval indicates that this site is suitable for septic tank and drainfield use. A septic tank permit will be issued by the Department of Community Development provided the site meets the requirements of other relevant regulations such as the County Comprehensive Plan, the Subdivision Ordinance, and the Shoreline Management Plan.

- OFFICE COPY
  - DCD COPY
  - APPLICANT'S COPY
- Date Sent \_\_\_\_\_  
Date Sent \_\_\_\_\_

SUBMITTED BY: Willie Drew  
DATE: 6/14/86



SITE CHARACTERISTICS

Topography: General Topographic Characteristics Relatively flat  
 Drainage Characteristics: Green waterway in northern part of lot  
 Slopes: General 0-5 %; Proposed Drainfield Location 2 %  
 Geology: Type of Bedrock & Depth No data  
 Vegetation: Open grassland  
 Distance to, and type of, nearest surface water: 100' + s. to canal  
 (If Less than 250 Feet)  
 Distance to nearby wells: NA  
 (If Less than 250 Feet)  
 Distance to public sewers: NA  
 (If Less than 500 Feet)  
 Other structures on Property: NA

SOIL SERIES

As mapped by U. S. Soil Conservation Service: CmB  
 Appears to be (if different from S.C.S. Classification): \_\_\_\_\_

SOIL LOGS

<u>Depth</u>	<u>Description</u>	<u>Comments</u>
<u>0-12</u>	<u>Silt loam</u>	<u>dark brown</u>
<u>12-60+</u>	<u>Sandy silt loam</u>	<u>light brown</u>


<u>Depth</u>	<u>Description</u>	<u>Comments</u>

<u>Depth</u>	<u>Description</u>	<u>Comments</u>

MAXIMUM SEASONAL GROUNDWATER ELEVATION

Soil Mottling \_\_\_\_\_ Water Table \_\_\_\_\_  
 (Depth Found & Degree of Development) (Depth to Standing Water)

COMMENTS: Saturated soil at 36" in Northern part of lot.



MASTER APPLICATION

(Please Print)

Permit No. \_\_\_\_\_ Date \_\_\_\_\_ By \_\_\_\_\_

APPLICANT Mr. Doug Ray TELEPHONE 693-2013  
ADDRESS 8408 SE Middle Way CITY Vancouver STATE Wa. ZIP 98664  
PROPERTY OWNER  Ray, Day, and Folk Jr. TELEPHONE \_\_\_\_\_  
ADDRESS  see attached for addresses CITY \_\_\_\_\_ STATE \_\_\_\_\_ ZIP \_\_\_\_\_


\*\*\*\*\*  
ADDRESS 15069 Lewis River Rd CITY Ariel  
PROJECT SUBDIVISION \_\_\_\_\_ LOT 34 BLOCK \_\_\_\_\_  
LOCATION SECTION 17 TOWNSHIP 6N RANGE 4E TAX LOT NO. T-6B2/T-6A2/T-6B  
LOT DIMENSIONS \_\_\_\_\_ PARCEL ER 17 06 003 ACRES 1.5  
\*\*\*\*\*  
ER 17 06 004

BUILDER \_\_\_\_\_ LICENSE NO. \_\_\_\_\_  
DESCRIBE PROJECT address request; soil evaluation conducted by Dennis and Associates, Inc.,  
(See attached paperwork)

Type of Heating \_\_\_\_\_ Fair Market Value \$ \_\_\_\_\_  
No. of Structures in Project \_\_\_\_\_ Bedrooms 3  
Water Supplied by well Private  Public \_\_\_\_\_ Existing \_\_\_\_\_ Proposed   
Sewage disposed by septic system Private  Public \_\_\_\_\_ Existing \_\_\_\_\_ Proposed

VICINITY SKETCH

PLOT PLAN



The above information and attachments are true and correct to the best of my knowledge and if any additions are required my application will not be processed until I forward it.

Date 12/18/81

App. Signature [Signature]

PERMIT FEES

OFFICE USE ONLY

Building \_\_\_\_\_  
Plan Check \_\_\_\_\_ % \_\_\_\_\_  
Mobile Home \_\_\_\_\_  
Plumb/Mech \_\_\_\_\_  
Sewage App 10.00  
Other 12-18-81  
TOTAL # 004241

Land Use District RR-2 Occupancy \_\_\_\_\_ Address Stake Up \_\_\_\_\_  
Address 15069 Lewis River Rd By [Signature] Soil Test \_\_\_\_\_

SPECIAL NOTES:

Short plat required prior to any permit issuance.

MINIMUM SPECIFICATIONS:

ISSUE CENTER

Date \_\_\_\_\_ Permit Approved By: \_\_\_\_\_