

SOIL EVALUATION REPORT

#EC-235-97

298

PROPERTY LOCATION Easy Street Road, Castle Rock

APPLICANT: Orville E. Esteb PHONE: 360-687-4865

MAILING ADDRESS: 23841 N.E. 182nd Avenue, Battle Ground, WA 98604  
CITY STATE ZIP

SPECIFICATIONS:

FOR 3 BEDROOM DWELLING: SEPTIC TANK 900 GALLON MINIMUM CAPACITY (TWO COMPARTMENT)

TYPE OF WATER SUPPLY DRAINFIELD 720 SQUARE FEET TOTAL MINIMUM (LENGTH X WIDTH OF TRENCHES)

Public

EXISTING XX PROPOSED \_\_\_\_\_

LAYOUT OF SYSTEM:

NUMBER OF DRAINFIELD LINES: 3 OR \_\_\_\_\_  
LENGTH OF DRAINFIELD LINES: 80' OR \_\_\_\_\_  
WIDTH OF DRAINFIELD LINES: 3' OR \_\_\_\_\_

TRENCH DEPTH: MINIMUM 18" MAXIMUM 24"

MINIMUM DISTANCE BETWEEN TRENCHES (CENTER TO CENTER): 7.5'

ADDITIONAL REQUIREMENTS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

NOTE:

This approval indicates that this site is suitable for septic tank and drainfield use. A septic tank permit will be issued by the Department of Community Development provided the site meets the requirements of other relevant regulations such as the County Comprehensive Plan, the Subdivision Ordinance, and the Shoreline Management Plan.


- OFFICE COPY
- DCD COPY \_\_\_\_\_  
Date Sent
- APPLICANT'S COPY \_\_\_\_\_  
Date Sent

SUBMITTED BY: *Orville E. Esteb*  
7/14/97  
Date


RECEIVED  
BLDG. & PLAN  
AUG 21 1997

VICINITY MAP MUST SHOW:

- 1. Location of property. >
- 2. Directional arrow indicating north. >
- 3. Any adjacent property addresses and landmarks near subject property.. >
- 4. Nearest intersecting roads. >



DO NOT USE SITE PLAN FRAME AS PROPERTY LINES!



SITE PLAN MUST SHOW:

- 1. Lot dimensions and property lines.
- 2. Directional arrow indicating north.
- 3. Road location and any existing or proposed driveways.
- 4. All proposed and existing structures, their dimensions and distances to each other, to property lines and to centerline of road.
- 5. Location of soil test area, drainfield, reserve drainfield area, slope of land, well, and their distances to proposed structures or projects.
- 6. Location and amount of any fill or grading.
- 7. Location of address stake, if applicable.
- 8. All bodies of water, natural and manmade (streams, creeks, rivers, ditches, etc.), and distance to proposed structures or development.
- 9. All easements (utility, access, etc.)
- 10. Adjacent property addresses and uses.
- 11. Draw to scale, if possible.

-SITE CHARACTERISTICS-

Topography: General Topographic Characteristics Rolling to Hilly  
Drainage Characteristics: Well Drained  
Slopes: General 0 - 15 %; Proposed Drainfield Location 8 - 10 %  
Geology: Type of Bedrock & Depth No Data  
Vegetation: Logged Off and Heavy Brush  
Distance to, and type of, nearest surface water: NA  
(If Less than 250 Feet)  
Distance to nearby wells: NA  
(If Less than 250 Feet)  
Distance to public sewers: NA  
(If Less than 250 Feet)  
Other structures on property: NA

-SOIL SERIES-

As mapped by U.S. Soil Conservation Service: Sequest Silt Loam  
Appears to be (if different from S.C.S. Classification): \_\_\_\_\_

-SOIL LOGS

<u>Depth</u>	<u>Description</u>	<u>Comments</u>
<u>0 - 13"</u>	<u>Sandy Silt Loam</u>	<u>A Horizon</u>
<u>13 - 60"</u>	<u>" " "</u>	<u>Light Brown</u>

<u>Depth</u>	<u>Description</u>	<u>Comments</u>
<u>0 - 13"</u>	<u>Sandy Silt Loam</u>	<u>A Horizon</u>
<u>13 - 36"</u>	<u>" " "</u>	<u>Light Brown</u>
<u>36 - 60"</u>	<u>Sandy Clay Loam</u>	<u>" "</u>

<u>Depth</u>	<u>Description</u>	<u>Comments</u>

-MAXIMUM SEASONAL GROUNDWATER ELEVATION

Soil Mottling Not Found Water Table Not Found  
(Depth Found & Degree of Development) (Depth to Standing Water)

COMMENTS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_