COWLITZ COUNTY

DEPARTMENT OF COMMUNITY DEVELOPMENT
COUNTY ADMINISTRATION BLDG. — 309 ACADEMY
KELSO, WASHINGTON 98626 TEL. NO. 577-3052

SEWAGE PERMIT APPROVAL

Property Address: 368 Baker Road Town Ariel

Permit Name: Delbert Seeley

Home Address: 4965 SE Malden Drive

City ~~Milwaukie~~ Portland State Oregon Zip Code 97206

Section: 23 Township 6 N Range 3 E Tax Lot# Parcel No. Em23-60-010

Subdivision Short Plat # 78-080 Lot 1 Block

Lot Size 330 x 660 Number of Acres 2.5 acres DEO 1-19-84

APPROVED FOR: Three Bedroom Dwelling

Septic Tank: 900 Gallon minimum Capacity (two compartment)

Drainfield: 495 Sq. Ft., Total minimum (length X width of trenches)

Suggested layout of system:

Number of drainfield lines:	3		4
Length of drainfield lines:	55 Feet	OR	42 Feet
Width of distribution lines:	3 Feet		3 Feet

Trench Depth: Minimum 18 inches Maximum 24 inches Depth into natural ground

Minimum distance between Trenches — Center to Center 7 ½ feet

OTHER REQUIREMENTS:

1/ Drainfield will be established along contours of the slope, lines will remain level.
~~2/ Drainfield will remain a minimum of 100 feet from all surface waters~~, and well, including wells on adjoining property.
3/ Drainfield will remain a minimum of 10 feet from all trees, property ~~boundaries, and buildings.~~
4/ Drainfield will not be driven upon at any time, and nor shall it be grazed by cattle and/or horses.

OTHER ITEMS

slope about 0/3%
about 0/18 inches, loam
~~about 18/42 inches, silt loam~~
about 42/48 inches, gravelly silt loam

ENCLOSURES

APPROVED BY: [signature] DATE: July 17, 1978

MASTER APPLICATION

(Please Print)

Permit No. _____
Date 7/3/78 By Op

APPLICANT JOHN & MARGARET LASSELL 654-5067 DELBERT & KATHLEEN SEELEY 774-7047 TELEPHONE
ADDRESS LASSELL 9747 SE 51 CITY MILWAKIE STATE ORE ZIP 97206
PROPERTY OWNER SEELEY 4965 SE MALDEN DR PORT TELEPHONE ORE 97206
ADDRESS SAME CITY _____ STATE _____ ZIP _____

****

PROJECT LOCATION
ADDRESS 368 BAKER RD CITY ARIEL
SUBDIVISION _____ LOT _____ BLOCK _____
SECTION 23 TOWNSHIP 6 RANGE 3 TAX LOT NO. 16
LOT DIMENSIONS 330 W 660 L PARCEL 1 ACRES 5

****

BUILDER OWNER LICENSE NO. _____
DESCRIBE PROJECT SOIL TEST & ADDRESS PRIOR TO SHORT PLATTING

Type of Heating ELEC Fair Market Value $ 35000
No. of Structures in Project 1 Bedrooms 3
Water Supplied by WELL Private ✓ Public _____ Existing _____ Proposed ✓
Sewage disposed by SEPTIC Private ✓ Public _____ Existing _____ Proposed ✓

VICINITY SKETCH **PLOT PLAN**



The above information and attachments are true and correct to the best of my knowledge and if any additions are required my application will not be processed until forward it.

Date 7/3/78 App. Signature Delbert Seeley

PERMIT FEES

Building _____
Plan Check _____ %
Mobile Home _____
Plumb/Mech _____
Sewage App 10.00
Other _____
TOTAL _____

OFFICE USE ONLY

Land Use District R.F. cp. Occupancy R1 Address Stake Up 7/3/78
Address 368 Baker RD By Whittaker Soil Test 7/12/78

SPECIAL NOTES: IF GATE IS LOCKED PLEASE SEE ROBERT BAKER AT 325 BAKER RD.

MINIMUM SPECIFICATIONS:

ISSUE CENTER

Date _____ Permit Approved By: _____