COWLITZ COUNTY DEPARTMENT OF COMMUNITY DEVELOPMENT
207 FOURTH AVENUE NORTH - KELSO, WASHINGTON 98626 - TELEPHONE (360) 577-3052

SITE EVALUATION

SUBSURFACE SEWAGE APPLICATION FOR

Property Location: BOB NEVIL SITE: LOT 1 BALD EAGLE ROAD

Section 18 Township 6N Range 4E Tax Lot # _____ Parcel # LOT 1 Acres 5.50+/-

FIELD INFORMATION

General Topography 25-35% SOUTH IN AREA OF TEST HOLES

Relationship to Existing Domestic Water Sources GREATER THAN 100 FEET

Hydrology: Depth to Ground Water Table (representative) NONE ENCOUNTERED TO 70" IN VICINITY OF TEST HOLES. (see map)

Relationship to Surface Waters GREATER THAN 100 FEET ANY DIRECTION

Soil Profile	DEPTH	COLOR	TEXTURE	ROOTS	MOTTLES	STRUCURE & OTHER COMMENTS
TP1 (W)	0-24"	Dk Brn	SiL	Med.	----------	3MSBK (well structured)
	24-64"	Brn	SiL	No	----------	2MSBK (well structured)
TP2 (S)	0-26"	Dk Brn	SiL	Med.	----------	3MSBK
	26-60"	Brn	SiL	No	----------	2MSBK
TP3 (E)	0-28"	Dk Brn	SiL	Med.	----------	3MSBK
	28-67"	Brn	SiL	No	----------	2MSBK
TP4 (N)	0-24"	Dk Brn	SiL	Med.	----------	3MSBK
	24-64"	Brn	SiL	No	----------	2MSBK

Miscellaneous Information SITE MEETS REQUIREMENTS FOR STANDARD. USE 0.45 GPD / SF.
MAX. TRENCH DEPTH = 24". LOCATE D.F. OVER SOUTH HOLES. RESERVE OVER NORTH HOLES

PLOT MAP: Scale = 1" = 140' +.



APPROVED
SEP 12 2008
COWLITZ COUNTY
BUILDING & PLANNING

NATHAN C. EK
LICENSED DESIGNER
EXPIRES: APRIL 28, 2009
9.11.08
re-signed in Blue for County purposes only

RECEIVED
SEP 12 2008
COWLITZ COUNTY
BUILDING & PLANNING