



STATE OF WASHINGTON
DEPARTMENT OF SOCIAL AND HEALTH SERVICES
AGING AND LONG-TERM SUPPORT ADMINISTRATION
20425 72nd Avenue S, Suite 400, Kent, WA 98032-2388

May 22, 2019

CERTIFIED MAIL

9489 0090 0027 6066 6913 63

**Safe Haven AFH LLC
**Safe Haven AFH LLC
8438 S 123rd Pl
Seattle, WA 98178

RE: **Safe Haven AFH LLC License #753686

Dear Provider:

The Department completed a full inspection of your Adult Family Home on May 21, 2019 and found that your home does not meet the adult family home licensing requirements listed below.

The Department staff who did the inspection and provided consultation:
Julie Miranda, Nursing Consultant Institutional/AFH Licensor

Consultation:

WAC 388-76-10805 Automatic smoke detectors. The adult family home must ensure approved automatic smoke detectors are:

- (1) Installed, at a minimum, in the following locations:
- (b) In proximity to the area where the resident or adult family home staff sleeps; and

The adult family home (AFH) did not install a smoke alarm in proximity to Room A where Resident #6 resided; and Room B where Resident #3 and #5 resided. The AFH installed the smoke alarm in proximity to the rooms the day after the inspection.

You Must:

- Begin the process of correcting the deficiency or deficiencies immediately; and
- Complete correction as soon as possible.

You Are Not:

- Required to submit a plan-of-correction for the deficiency or deficiencies found.

The Department May:

- Inspect the home to determine if you have corrected all deficiencies.

You May:

- Ask for an informal dispute resolution meeting, according to the attached "Informal Dispute Resolution" instructions; and

****Safe Haven AFH LLC**

****Safe Haven AFH LLC License #753686**

May 22, 2019


Page 2

- Ask questions and provide written information to help clarify or dispute the deficiencies.

If You Have Any Questions:

- Please contact me at (253) 234-6007.

Sincerely,

A handwritten signature in black ink that reads "Elena Atanasova" followed by a long horizontal flourish.

Elena Atanasova, Field Manager
Region 2, Unit G
Residential Care Services

Enclosure