



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name	Waller Road Home	Provider Number	001014
Address	4710 WALLER RD E,	Approval Status	Disapproved
City, State, Zip	Tacoma, WA 98443	Facility Type	Residential Care

On 4/30/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

4 Hardware

Door handles, pulls, latches, locks and other operating devices on doors required to be accessible by Chapter 11 of the International Building Code shall not require tight grasping, tight pinching or twisting of the wrist to operate. IFC 1010.1.9.1 2015	Findings during the inspection were: Door knobs on all Exit Doors must be replaced to single-action levers. Exit doors may not require tight grasping, tight pinching or twisting of the wrist to operate. <i>OK</i>
--	---

Next inspection scheduled on or after: 5/30/2019

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative



 Signature

Kimberly Benz Assistant Admin

 Print Name and Title

Deputy State Fire Marshal Lysandra Davis
 2502 112 ST
 Tacoma WA 984455104
 () -



 Signature