



**Washington State Patrol
Fire Protection Bureau**
Phone: (360) 596-3900

Business Name Nikkei Manor	Provider Number 001186
Address 700 6TH AVE S,	Approval Status Approved
City, State, Zip Seattle, WA 98104	Facility Type Residential Care

On 08/28/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

<p>COMPLAINT # 3552641</p> <p>Here's a complaint of a dryer fire from lint.</p> <p>Please include the answers to the following questions in your report in FDM.</p> <ol style="list-style-type: none"> 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No 	<p>On August 28th, 2018 I conducted a complaint investigation on complaint I.D. # 3552641. An interview was conducted with the Health Services Manager.</p> <p>According to the interview, the interviewee did not have direct knowledge of the incident and could only discuss what was reported to her.</p> <p>The Health Services Manager confirmed they had a small fire in dryer #7 on the second floor. A staff member noticed smoke coming from the dryer, and retrieved a fire extinguisher and extinguished the fire with no sprinkler activation. The fire alarm was activated by a manual fire alarm pull station, and a staff member called 911. The 911 dispatcher advised the staff caller that they must evacuate all residence. The staff caller informed the dispatcher they are a shelter in place facility and the 911 dispatcher again instructed the staff caller to evacuate all residence.</p> <p>Evacuation was initiated and 6 residence and 1 family member on the second floor evacuated to the main parking lot. The nurse manager stopped evacuation and had the remaining residence to shelter in place. Seattle Fire Department arrived on scene and assessed the situation and advised staff not to evacuate any residence of the facility.</p> <p>It was determined that excess lint in the dryer caused the incident. No injuries were reported and the damaged dryer has been replaced.</p> <p>Upon inspection of the new dryer #7 on the second floor DSFM Scott Campos found the dryer lint trap free from any lint build up.</p> <p>NO IFC VIOLATIONS.</p>
---	---

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Nikkei Manor **Provider Number** 001186
Address 700 6TH AVE S, **Approval Status** Approved
City, State, Zip Seattle, WA 98104 **Facility Type** Residential Care

On 08/28/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Teri McLaughlin RW
Signature

TERI McLAUGHLIN / Health Services
Print Name and Title
Mgr.

Deputy State Fire Marshal Scott Campos
2803 156 AVE SE
Bellevue WA 98007
(360) 481-9360

[Signature]
Signature

This document was prepared by Residential Care Services for the Locator website.