



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rock Cove Assisted Living	Provider Number	001254
Address	986 NW ROCK CREEK DR ,	Approval Status	Approved
City, State, Zip	Stevenson, WA 98648	Facility Type	Residential Care

On 10/18/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

TERRY L ELLISON M.D.
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966


Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
 Fire Protection Bureau
 Phone: (360) 596-3900

Business Name	Rock Cove Assisted Living	Provider Number	001254
Address	986 NW ROCK CREEK DR ,	Approval Status	Disapproved
City, State, Zip	Stevenson, WA 98648	Facility Type	Residential Care

On 09/17/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin New Requirements

<p>For your information:</p> <p>703.2 Opening protectives. Opening protective shall be maintained in an operative condition in accordance with NFPA 80. NFPA 80 Chapter 19 Installation, Testing, and Maintenance of Fire Dampers. 19.4 Periodic Inspection and Testing. 19.4.1 Each damper shall be tested and inspected 1 year after installation. 19.4.1.1 The test and inspection frequency shall then be every 4 years, except in hospitals, where the frequency shall be every 6 years.</p> <p>EFFECTIVE JULY 1, 2018. 907.10 National Institute for Certification in Engineering Technologies. 907.10.1 Scope. This section shall apply to new and existing fire alarms systems. 907.10.2 Design review. All construction documents shall be reviewed by a NICET III in fire alarms or a licensed professional engineer (PE) in Washington prior to being submitted for permitting. The reviewing professional shall submit a stamped, signed, and dated letter; or a verification method approved by the local authority having jurisdiction indicating the system has been reviewed and meets or exceeds the design requirement of the Washington and the local jurisdiction (effective July 1, 2018). 907.10.3 Testing/maintenance: All inspection, testing maintenance and programing not defined as "electrical trade" by chapter 19.28 RCW shall be completed by a NICET II in fire alarms (effective July 1, 2018).</p>	<p>Facility failed to provide 4 year fire damper inspection report.</p> <p>Report shall include the following items location of damper, name of inspector and deficiencies discovered.</p> <p>The documentation shall have a space to indicate when and how the deficiencies were corrected.</p>
---	--

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rock Cove Assisted Living	Provider Number	001254
Address	986 NW ROCK CREEK DR ,	Approval Status	Disapproved
City, State, Zip	Stevenson, WA 98648	Facility Type	Residential Care

On 09/17/2018 the Office of the State Fire Marshal conducted an inspection at your facility.


Code Requirement

Statement of Violation

Next inspection scheduled on or after: 10/17/2018

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

TERRY L ELLISON M.D.
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966


Signature



This document was prepared by Residential Care Services for the Locator website.