



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name Normandy Park Assisted Living	Provider Number 001688
Address 16625 1st AVE S,	Approval Status Approved
City, State, Zip Normandy Park, WA 98148	Facility Type Residential Care

On 07/16/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 3658131

Here's a complaint of Fire alarm went of because of faulty thermal detector

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

1. The cause of the fire? N/A
2. If the sprinklers were activated? N/A
3. If there was an evacuation / how many were evacuated? N/A
4. If there were injuries / how many? N/A
5. Did the fire department respond? Yes

The facility had a faulty smoke detector. They went into a short 30 minute fire watch until their local Burien Fire Marshal stated that because there were other detectors in the area that functioned appropriately, they didn't have to do a fire watch. The detector was taken down and replaced.

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


 Signature

 Print Name and Title

Deputy State Fire Marshal Dylan Montgomery
 2505 112TH ST E
 Tacoma WA 984455104
 (425) 577-0362


 Signature

This document was prepared by Residential Care Services for the Locator website.