



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900


This document was prepared by Residential Care Services for the Locator website.

Business Name	Sessions Residential Care Inc	Provider Number	1999
Address	22 N ADAMS RD ,	Approval Status	Approved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care

On 05/13/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative


Signature

Dianna Black Resident
Print Name and Title
CARE
Manager

Deputy State Fire Marshal David Rogers
PO Box 19130
Spokane WA 992199130
(509) 954-2746


Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name	Sessions Residential Care Inc	Provider Number	1999
Address	22 N ADAMS RD ,	Approval Status	Disapproved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care

On 04/23/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Inspection, testing and maintenance.

<p>Fire detection, alarm, and extinguishing systems, mechanical smoke exhaust systems, and smoke and heat vents shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Nonrequired fire protection systems and equipment shall be inspected, tested and maintained or removed.</p> <p>(IFC 901.6 2012, 2015)</p>	<p>The following violation was observed:</p> <p>The sprinkler head in resident room #1 and the sprinkler head in the Fire Alarm Control Panel room were both covered in and appearing to be seeping a black liquid (possibly glycol).</p>
--	---

2 Fire Drills

<p>In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group.R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.</p> <p>(WAC 212-12-044)</p>	<p>The following violation was observed:</p> <p>The facility was unable to provide documentation indicating a night shift fire drill was conducted for 1st quarter 2019 and that a night shift fire drill was conducted for 4th quarter 2018.</p> <p>The facility will need to conduct and document an additional night shift fire drill prior to reinspection.</p>
--	---



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name	Sessions Residential Care Inc	Provider Number	1999
Address	22 N ADAMS RD ,	Approval Status	Disapproved
City, State, Zip	Spokane Valley, WA 99216	Facility Type	Residential Care


On 04/23/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------


Next inspection scheduled on or after: 05/23/2019

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative




 Signature



 Print Name and Title
 Resident Care
 Manager

Deputy State Fire Marshal David Rogers
 PO Box 19130
 Spokane WA 992199130
 (509) 954-2746



 Signature