



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

<b>Business Name</b>	Sunrise of Mercer Island	<b>Provider Number</b>	2164
<b>Address</b>	2959 76TH AVE ,	<b>Approval Status</b>	Approved
<b>City, State, Zip</b>	Mercer Island, WA 98040	<b>Facility Type</b>	Residential Care

On 12/13/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Kim MacDonald ED

Print Name and Title

Deputy State Fire Marshal Don West  
2502 112TH ST E  
Tacoma WA 98445  
(253) 538-3124

Signature

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol  
 Fire Protection Bureau  
 Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

<b>Business Name</b>	Sunrise of Mercer Island	<b>Provider Number</b>	2164
<b>Address</b>	2959 76TH AVE ,	<b>Approval Status</b>	Disapproved
<b>City, State, Zip</b>	Mercer Island, WA 98040	<b>Facility Type</b>	Residential Care

On 11/13/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

**1 Door Operation**

Swinging fire doors shall close from the full-open position and latch automatically. The door closer shall exert enough force to close and latch the door from any partially open position.

(IFC 703.2.3)

During the facility tour on November 13, 2018 it was observed that the facility failed to maintain the fire rated doors in the building. The findings were:

1. Resident room door #342 failed to close and latch automatically.
2. Resident room door #114 failed to close and latch automatically.
3. The double doors into the first floor dinning room failed to close and latch when the coordinator was used.
4. The double doors into the first floor TV room failed to close and latch when the coordinator was used.

Next inspection scheduled on or after: 12/13/2018

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

  
 Signature

Kim MacDonald, ED  
 Print Name and Title

Deputy State Fire Marshal Don West  
 2502 112TH ST E  
 Tacoma WA 98445  
 (253) 538-3124

  
 Signature