



Washington State Patrol
Fire Protection Bureau

Phone: (360) 596-3900

This document was prepared by Residential Care Services for the Locator website.

Business Name	Sunrise of Mercer Island	Provider Number	2164
Address	2959 76TH AVE ,	Approval Status	Approved
City, State, Zip	Mercer Island, WA 98040	Facility Type	Residential Care

On 07/09/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Opening protectives.

Opening protectives shall be maintained in an operative condition in accordance with NFPA 80. Where allowed by the fire code official, the application of field-applied labels associated with the maintenance of opening protectives shall follow the requirements of the approved third-party certification organization accredited for listing the opening protective. Fire doors and smoke barrier doors shall not be blocked or obstructed, or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Fire door assemblies shall not be modified.

IFC 703.2

During the facility tour on 7/9/2019 it was observed that the facility failed to maintain the cross corridor fire separation doors. The finding was:

1. The fire doors by resident room #108 failed to latch closed. (this door was corrected at the time of the inspection)

Next inspection scheduled on or after: 09/29/2020


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


Signature

FRANK SPINNER
Print Name and Title

Deputy State Fire Marshal Don West
2803 156th AVE SE
Bellevue MI 98007
(425) 890-9873


Signature