



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name	Franklin Place	Provider Number	2189
Address	5713 PARKER RD E,	Approval Status	Approved
City, State, Zip	Sumner, WA 983902791	Facility Type	Residential Care

On 11/18/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

<p>* Can be done with a phone interview</p> <p>COMPLAINT # 3676088</p> <p>Here's a complaint of fire sprinkler system was serviced 11/1/2019 - report claims fire watch was done.</p> <p>Please include the answers to the following questions in your report in FDM.</p> <ol style="list-style-type: none"> 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No 	<p>On 11/18/2019, I conducted a complaint investigation for ID# 3676088 at Franklin Place Assisted Living located at 5713 Parker Rd E, Sumner, WA. The complaint was in regards to pre-planned fire sprinkler system repair and maintenance.</p> <p>Interview and record review were conducted with the facility's Assistant Director and over the phone with Western State Fire Protection, Co. According to the interviews and record review the facility had scheduled repairs and maintenance for the dry sprinkler system, on 11/1/19 from 7:30 AM to 3:00 PM (7 1/2 hrs). The sprinkler company drained the dry sprinkler system, installed a new air compressor, replaced old pipe, and cleared pipe obstructions. Facility staff conducted fire watch every 15 minutes for the entire duration of the repairs/maintenance.</p> <p>No violations were observed with the facility's fire watch policy or documentation, and no IFC violations were observed in the sprinkler riser room.</p>
---	--

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Fuavai
 Signature

Figita Fuavai Resident Care Coordinator
 Print Name and Title

Deputy State Fire Marshal Lysandra Davis
 2502 112 ST
 Tacoma WA 984455104
 (360) 890-1622

[Signature]
 Signature

This document was prepared by Residential Care Services for the Locator website.