



**Washington State Patrol**  
**Fire Protection Bureau**  
 Phone: (360) 596-3900

<b>Business Name</b> Louisa Place	<b>Provider Number</b> 2191
<b>Address</b> 2240 MAIN ST ,	<b>Approval Status</b> Approved
<b>City, State, Zip</b> Ferndale, WA 98248	<b>Facility Type</b> Residential Care

On 06/19/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

**1 Admin Complaint**

<p>COMPLAINT # 3653346</p> <p>Here's a complaint of a repair to a leaking pipe, facility is on Fire Watch</p> <p>Please include the answers to the following questions in your report in FDM.</p> <ol style="list-style-type: none"> <li>1. The cause of the fire?</li> <li>2. If the sprinklers were activated?</li> <li>3. If there was an evacuation / how many were evacuated?</li> <li>4. If there were injuries / how many?</li> <li>5. Did the fire department respond? Yes, No</li> </ol>	<p>On 6/19/2019 a complaint inspection was conducted by a representative of the Washington State Patrol, State Fire Marshal's Office, this inspection was in regards to a water leak in the dry sprinkler system on 6/11/2019.</p> <ol style="list-style-type: none"> <li>1. There were no injuries to staff or residents.</li> <li>2. No building damage.</li> <li>3. No evacuations.</li> <li>4. There was no fire.</li> <li>5. The fire department did respond.</li> </ol> <p>CAUSE;</p> <p>The cause was a pin hole leak in the dry pipe caused by microbial damage to the steel pipe.</p> <p>The sprinkler pipe has been replaced and the system is in service at this time.</p> <p>No further action required by the State Fire Marshal's Office.</p>
---	---



Washington State Patrol  
Fire Protection Bureau  
Phone: (360) 596-3900

<b>Business Name</b> Louisa Place	<b>Provider Number</b> 2191
<b>Address</b> 2240 MAIN ST ,	<b>Approval Status</b> Approved
<b>City, State, Zip</b> Ferndale, WA 98248	<b>Facility Type</b> Residential Care

On 06/19/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Jeff Jackson / Executive Director  
Print Name and Title

Deputy State Fire Marshal Don West  
2502 112TH ST E  
Tacoma WA 98445  
(253) 538-3124

Signature