



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

RECEIVED

OCT 12 2018

FIRE PREVENTION
DIVISION

Business Name	Hampton at Salmon Creek Memory Care	Provider Number	2227
Address	2305 NE 129TH ST ,	Approval Status	Approved
City, State, Zip	Vancouver, WA 98686	Facility Type	Residential Care

On 10/10/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

All violations noted during previous related inspection(s) have been corrected.

Owner or Owner's Representative

Signature

Brady Nelson Physical Plant Director
Print Name and Title

Deputy State Fire Marshal Nicholas Wolden
1823 BAKER WAY
Kelso WA 98626
(360) 852-0966

Signature

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

RECEIVED

OCT 12 2018

FIRE PREVENTION
 DIVISION

Business Name Hampton at Salmon Creek Memory Care	Provider Number 2227
Address 2305 NE 129TH ST ,	Approval Status Disapproved
City, State, Zip Vancouver, WA 98686	Facility Type Residential Care

On 10/10/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 System Test

<p>Systems shall be inspected and tested for proper operation at 6-month intervals. Tests shall include a check of the detection system, alarms and releasing devices, including manual stations and other associated equipment. Extinguishing system units shall be weighed and the required amount of agent verified. Stored pressure-type units shall be checked for the required pressure. The cartridge of cartridge-operated units shall be weighed and replaced at intervals indicated by the manufacturer.</p> <p>(IFC 904.5.1 (2009, 2012, 2015))</p>	<p>Facility fails to provide semi annual hood system inspection</p>
--	---

Next inspection scheduled on or after: 11/09/2018

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative



 Signature

Brady Nelson Physical Plant Director

 Print Name/and Title

Deputy State Fire Marshal Nicholas Wolden
 1823 BAKER WAY
 Kelso WA 98626
 (360) 852-0966



 Signature