



Washington State Patrol
 Fire Protection Bureau
 Phone: (360) 596-3900

RECEIVED

OCT 17 2019

~~FIRE PREVENTION~~
 DIVISION

Business Name Brookdale Monroe	Provider Number 2284
Address 15465 179th AVE ,	Approval Status Approved
City, State, Zip Monroe, WA 98272	Facility Type Residential Care

On 10/14/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 3672559

Here's a complaint of resident started a fire on purpose, set off the sprinklers, and flooded room.

Please include the answers to the following questions in your report in FDM.

1. The cause of the fire?
2. If the sprinklers were activated?
3. If there was an evacuation / how many were evacuated?
4. If there were injuries / how many?
5. Did the fire department respond? Yes, No

On October 14th, 2019 I conducted a complaint investigation on complaint I.D. # 3672559. An interview was conducted with the Executive Director.

According to the interview, on [REDACTED] at approximately 10pm the facility fire alarm started sounding. When staff looked at fire alarm panel it alerted them to a resident room. Staff responded to the room and found smoke and an activated sprinkler head in the bathroom. The staff removed the resident and closed the door to the room and evacuated the remainder of the wing to the other side of the fire doors. The fire department responded and confirmed the fire was out, shut off sprinkler system and began clean up of the water in the resident room.

While the fire department was evacuating the water, the facility staff went into immediate fire watch and contacted the sprinkler and alarm system vendor. The system vendor responded to the facility and replaced the sprinkler head and reset the fire alarm and sprinkler system. The facilities emergency system was back in operation by 2:30am October 9th, 2019.

No injuries reported, although the resident of the room involved was transported to the hospital for a mental evaluation and will not be returning to the facility.

Only minor smoke and water damage to the facility.

The fire department was alerted to the facility via the alarm company.

No violations of IFC regulations were observed.

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Brookdale Monroe	Provider Number	2284
Address	15465 179th AVE ,	Approval Status	Approved
City, State, Zip	Monroe, WA 98272	Facility Type	Residential Care

On 10/14/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Print Name and Title

Deputy State Fire Marshal Jamie Youngblood
16778 146 ST SE
Monroe WA 98272
(425) 551-0758

Signature 

This document was prepared by Residential Care Services for the Locator website.