



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name Brookdale Renton	Provider Number 2296
Address 71 VICTORIA ,	Approval Status Approved
City, State, Zip Renton, WA 98055	Facility Type Residential Care

On 12/31/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

<p>COMPLAINT # 3685441</p> <p>Here's a complaint of baseboard heater fire.</p> <p>Please include the answers to the following questions in your report in FDM.</p> <ol style="list-style-type: none"> 1. The cause of the fire? 2. If the sprinklers were activated? 3. If there was an evacuation / how many were evacuated? 4. If there were injuries / how many? 5. Did the fire department respond? Yes, No 	<ol style="list-style-type: none"> 1. The cause of the fire? Malfunctioning base board heater 2. If the sprinklers were activated? N/A 3. If there was an evacuation / how many were evacuated? N/A 4. If there were injuries / how many? N/A 5. Did the fire department respond? Yes <p>The facility has replaced the broken heater and there have been no issues after the event.</p>
--	--

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

EMALIED

 Signature

 Print Name and Title

Deputy State Fire Marshal Dylan Montgomery
 2505 112TH ST E
 Tacoma WA 984455104
 (425) 577-0362

Dylan Montgomery

 Signature

This document was prepared by Residential Care Services for the Locator website.