



Washington State Patrol
 Fire Protection Bureau
 Phone: (360) 596-3900

Business Name Aspen Quality Care	Provider Number 2307
Address 9626 N COLFAX RD ,	Approval Status Approved
City, State, Zip Spokane, WA 99218	Facility Type Residential Care

On 09/18/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Fire Drills

<p>In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.</p> <p>(WAC 212-12-044)</p>	<p>Facility e-mailed me copies of recent fire drills to show that staff on the night shift have participated in fire drills. Facility will need to ensure that fire drills are conducted at varying times and under varying conditions and maintain copies of fire drills to show that all shifts are participating in fire drills.</p>
--	---

Next inspection scheduled on or after: 09/30/2019

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative




 Signature

Jonathan Bess owner

 Print Name and Title

Deputy State Fire Marshal Clifton A. Rogers
 PO Box 19130
 Spokane WA 99219
 (509) 227-6567



 Signature

Initials of Authorized Facility Representative: _____

This document was prepared by Residential Care Services for the Locator website.



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name Aspen Quality Care	Provider Number 2307
Address 9626 N COLFAX RD ,	Approval Status Disapproved
City, State, Zip Spokane, WA 99218	Facility Type Residential Care

On 08/22/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Fire Drills

In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.

(WAC 212-12-044)

During this Fire and Life Safety Inspection and review of Fire Drill Records, the facility was lacking fire drills on all shifts. Facility has two shifts, a 13 hour and 10 hour (6a to 8p is day shift and 8p to 6a is night shift). Facility needs to vary their fire drills to ensure staff on all shifts participate in the drills. Eight day shift drills and four swing shift drills have been done in the last year, no night shift drills.

Next inspection scheduled on or after: 09/19/2018


Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative


 Signature

Jonathan Bess owner
 Print Name and Title

Deputy State Fire Marshal Clifton A. Rogers
 PO Box 19130
 Spokane WA 99219
 (509) 227-6567


 Signature

This document was prepared by Residential Care Services for the Locator website.