







**Washington State Patrol**  
**Fire Protection Bureau**  
 Phone: (360) 596-3900

<b>Business Name</b>	Aegis of Queen Anne on Galer	<b>Provider Number</b>	2339
<b>Address</b>	223 W GALER ST ,	<b>Approval Status</b>	Disapproved
<b>City, State, Zip</b>	Seattle, WA 981193331	<b>Facility Type</b>	Residential Care

On 07/16/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

**4 Portable Fire Extinguishers - General Requirements**

Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Exceptions:

1. The distance of travel to reach an extinguisher shall not apply. The travel distance to reach an extinguisher shall not apply to the spectator seating portions of Group A-5 occupancies.
2. Thirty-day inspections shall not be required and maintenance shall be allowed to be once every three years for dry-chemical or halogenated agent portable fire extinguishers that are supervised by a listed and approved electronic monitoring device, provided that all of the following conditions are met:
  - 2.1. Electronic monitoring shall confirm that extinguishers are properly positioned, properly charged and unobstructed.
  - 2.2. Loss of power or circuit continuity to the electronic monitoring device shall initiate a trouble signal.
  - 2.3. The extinguishers shall be installed inside of a building or cabinet in a noncorrosive environment.
  - 2.4. Electronic monitoring devices and supervisory circuits shall be tested every three years when extinguisher maintenance is performed.
  - 2.5. A written log of required hydrostatic test dates for extinguishers shall be maintained by the owner to verify that hydrostatic tests are conducted at the frequency required by NFPA 10.
3. In Group I-3, portable fire extinguishers shall be permitted to be located at staff locations.

During the facility tour on July 17, 2019 it was observed that the facility failed to maintain the portable fire extinguishers in the building. The finding was:

1. Fire extinguishers are due for annual service.

IFC 906.2 2015 This document ~~551~~



**Washington State Patrol**  
**Fire Protection Bureau**  
 Phone: (360) 596-3900

<b>Business Name</b>	Aegis of Queen Anne on Galer	<b>Provider Number</b>	2339
<b>Address</b>	223 W GALER ST ,	<b>Approval Status</b>	Disapproved
<b>City, State, Zip</b>	Seattle, WA 981193331	<b>Facility Type</b>	Residential Care

On 07/16/2019 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

**5 Fire Drills**

In all Group I, Group E, and Group R2 Occupancies licensed by the state, at least twelve planned and unannounced fire drills shall be held every year. Drills shall be conducted quarterly on each shift in Group I and Group R2, Occupancies and monthly in Group E Occupancies to familiarize personnel with signals and emergency action required under varied conditions. A detailed written record of all fire drills shall be maintained and available for inspection at all times. When drills are conducted between 9:00 p.m. and 6:00 a.m., a coded announcement may be used instead of audible alarms. Fire drills shall include the transmission of a fire alarm signal and simulation of emergency conditions. The fire alarm monitoring company shall be notified prior to the activation of the fire alarm system for drill purposes and again at the conclusion of the transmission and restoration of the fire alarm system to normal mode.

(WAC 212-12-044)


During review of the facility records on July 17, 2019 it was observed that the facility failed to maintain the records of fire drills for the past year. The finding was:

1. There are no records available for the fourth quarter of 2018.

**Next inspection scheduled on or after: 08/15/2019**

**Right of appeal.** Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

  
 Signature

 7-17-19.  
 Print Name and Title

Deputy State Fire Marshal Don West  
 2803 156th AVE SE  
 Bellevue MI 98007  
 (425) 890-9873

  
 Signature

This document was prepared by Residential Care Services for the Locator website.