

NOTICE OF CONDITIONS ON LICENSE

April 17, 2019

Based on the Statement of Deficiencies dated **April 9, 2019**, the Department of Social and Health Services imposes the following conditions on the license of *Cherrywood Place, License #2434, located at 100 E Dalke Ave, Spokane, Washington.*

The licensee must ensure the assisted living facility, meets the following conditions by April 22, 2019 as follows:

- *Treat affected rooms for bed bugs by a professional exterminator with knowledge of eliminating bed bug infestations.*
- *Follow all recommendations of the professional exterminator.*
- *Repair the water heating system to ensure hot water temperatures are consistently maintained between 105°F and 120°F.*
- *Hot water temperatures are checked weekly, documented, and made available to the department upon request.*
- *The kitchen refrigerator is in working condition and food temperatures are maintained at 41°F or lower.*
- *Staff are trained about residents' rights to report to the department without fear of retaliation or reprisal.*
- *The licensee must post this Notice of Conditions of Operation, with the license, in a visible location in a common use area.*

These conditions are effective on **April 17, 2018**, and remain in effect until lifted by formal Department of Social and Health Services notice.



Shirlee Steiner, B.S., RD
Regional Administrator
Residential Care Services