



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name Cherrywood Place	Provider Number 2434
Address 100 DALKE ,	Approval Status Approved
City, State, Zip Spokane, WA 99208	Facility Type Residential Care

On 08/13/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

<p>COMPLAINT # 3548018</p> <ol style="list-style-type: none"> 1. The cause of the fire? Resident placed a styrofoam plate in the microwave. 2. If the sprinklers were activated? No sprinkler activation occurred 3. If there was an evacuation / how many were evacuated? No evacuation conducted, the facility conducted shelter-in-place procedures. 4. If there were injuries / how many? No injuries were reported 5. Did the fire department respond? City of Spokane FD responded. 	<p>On 8/13/18 I conducted a complaint investigation for complaint ID# 3548018 at Cherrywood Place located at 100 E. Dalke Ave in Spokane, WA.</p> <p>Interviews were conducted with the facility Administrator and the Maintenance Director and a review was conducted of written statements by facility care staff.</p> <p>According to the statements, fire alarm activation occurred in room #307 at approximately 1745 hours on 7-28-18 when a resident placed a Styrofoam plate in the microwave, causing the release of smoke, activating the integrated smoke detector in the unit. On site care-staff heard the fire alarm activate and went to the annunciator panel to determine the location.</p> <p>Care Staff member #1 then entered room #307 with a fire extinguisher and observed there was no active fire, and removed the resident from the room. The facility conducted shelter-in-place procedures and verified all resident room fire doors were shut.</p> <p>The City of Spokane FD responded and determined there was no active fire. The microwave was removed and the facility has conducted an assessment of the resident. No injuries were reported.</p> <p>No violations observed.</p>
--	--



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Cherrywood Place	Provider Number	2434
Address	100 DALKE ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99208	Facility Type	Residential Care

On 08/13/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative




 Signature

Shannon Flores Executive Director

 Print Name and Title

Deputy State Fire Marshal David Rogers
 PO Box 19130
 Spokane WA 992199130
 (509) 954-2746



 Signature