



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name	Rose Pointe Assisted Living	Provider Number	2452
Address	13013 MISSION ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99216	Facility Type	Residential Care

On 03/25/2021 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

1 Admin Complaint

<p>COMPLAINT # 3761462</p> <ol style="list-style-type: none"> 1. Suspected charging cellphone caused fire event. 2. Fire sprinkler activation did not occur. 3. The entire facility conducted total evacuation. 4. 1 resident complained of a burned hand, with a hospital visit was declined by the resident. 5. The City of Spokane Valley FD responded to the event. 	<p>On 3/25/2021 I conducted a remote-telephonic complaint investigation for DSHS complaint ID#3761462 at Rose Pointe Assisted Living located at 13013 E. Mission Ave in Spokane Valley. An on-site visit could not be conducted due to Covid restrictions. The complaint was in regards to a fire incident occurring within a resident room.</p> <p>Telephone interviews were conducted with the Facility Maintenance Director and record review was conducted of the facility incident reports and Spokane Valley Fire Department's (FD) responding NFIRS report.</p> <p>According to the interview and record review, the integrated smoke detector in resident room [REDACTED] activated the building fire alarm system at approximately 2015 hours on 3/16/21. The facility began total evacuation procedures and responding staff discovered smoke present in the resident room and one female occupant within who complained of a minor burn to their hand. Fire Sprinkler activation did not occur.</p> <p>According to the Spokane Valley FD NFIRS report, the responding FD personnel arrived on location during resident evacuation and were informed by staff the resident room was filled with smoke. FD investigated and determined there was no active fire event in the building and conducted ventilating procedures. Minor scorching of the carpet in resident room [REDACTED] was observed by the FD who authorized the residents to re-occupy the building.</p> <p>Both the facility incident report and Spokane Valley FD report indicated a malfunctioning charging cell phone was the suspected cause of the incident. The resident stated they had suffered an injured hand, but declined Medical response or a hospital visit.</p> <p>No violations of the International Fire Code by the facility were observed regarding the conditions of the complaint.</p>
--	---

This document was prepared by Residential Care Services for the locator website.



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name	Rose Pointe Assisted Living	Provider Number	2452
Address	13013 MISSION ,	Approval Status	Approved
City, State, Zip	Spokane, WA 99216	Facility Type	Residential Care

This document was prepared by Residential Care Services for the Locator website.

On 03/25/2021 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement

Statement of Violation

Next inspection scheduled on or after:

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Signature

Tendre Chamberlain, ED

Print Name and Title

Deputy State Fire Marshal David Rogers
PO Box 19130
Spokane WA 992199130
(509) 954-2746

David Rogers

Digitally signed by David Rogers
DN: cn=David Rogers, o=WA State Fire Marshal's Office, ou=Plan
Review Section, email=david.rogers@wsp.wa.gov, c=US
Date: 2021.03.31 17:02:09 -0700

Signature