



Washington State Patrol
Fire Protection Bureau
 Phone: (360) 596-3900

Business Name Upriver Place	Provider Number 1000001
Address 9111 E UPRIVER DR ,	Approval Status Approved
City, State, Zip Spokane, WA 99206	Facility Type Enhanced Services Facilities

On 11/27/2017 the Office of the State Fire Marshal conducted an inspection at your facility.

Code Requirement	Statement of Violation
------------------	------------------------

1 Admin Complaint

COMPLAINT # 3460136

1. The cause of the fire? No fire. Smoke released due to overcooked popcorn in a microwave.
2. If the sprinklers were activated? No sprinkler evacuation.
3. If there was an evacuation? All ESF residents were evacuated.
4. If there were injuries / how many? No injuries.
5. Did the fire department respond? Spokane Valley Fire Department responded.

On 11/27/17 I conducted a complaint investigation for Complaint ID# 3460136.

Interviews were conducted with the facility Maintenance Director and reviews were conducted of facility incident reports.

According to interviews and record review, at approximately 1800 hours on 11-3-17 facility staff overcooked a bag of popcorn in the admin area prep-kitchen. When staff opened the microwave, smoke escaped, activating the smoke detector that is installed above the microwave. When the alarm activated, the facility conducted a full evacuation. Spokane Valley FD responded and determined there was no fire, authorizing re-entry of residents.

No injuries were reported, and no violations of the IFC were observed.

Next inspection scheduled on or after: *N/A*

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Wesley Davis

 Signature

Donald K. Harris

 Print Name and Title

Deputy State Fire Marshal David Rogers
 PO Box 19130
 Spokane WA 992199130
 (509) 954-2746

[Signature]

 Signature