



Washington State Patrol
Fire Protection Bureau
Phone: (360) 596-3900

Business Name Upriver Place
Address 9111 E UPRIVER DR,
City, State, Zip Spokane, WA 99206
Provider Number 1000001
Approval Status Approved
Facility Type Enhanced Services Facilities

On 05/10/2018 the Office of the State Fire Marshal conducted an inspection at your facility.

Table with 2 columns: Code Requirement, Statement of Violation

1 Extension Cords.

Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances.

(IFC 605.5)

During this Fire and Life Safety Inspection we observed a extension cord being used in lieu of permanent wiring or approved power strips in the following location:

- 1. Upriver Office (Cord was removed while I was still present)

2 Door Operation

Swinging fire doors shall close from the full-open position and latch automatically. The door closer shall exert enough force to close and latch the door from any partially open position.

(IFC 703.2.3)

During this Fire and Life Safety Inspection we observed the following door not closing and latching as required:

- 1. Resident Room #3 failed to close and latch as required. (Door was adjusted to properly close and latch as required while I was still present)

Next inspection scheduled on or after: 06/09/2019 - CH

Right of appeal. Any person may appeal any decision made by the Fire Protection Bureau in accordance with WAC 212-12.

Owner or Authorized Representative

Handwritten signature of Donald K. Harris

Signature

Print Name and Title: Donald K. Harris

Deputy State Fire Marshal Clifton A. Rogers
PO Box 19130
Spokane WA 99219
(509) 227-6567

Handwritten signature of Clifton A. Rogers

Signature