

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 08/21/2015  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>50G047</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MAIN BUILDING 01</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>08/21/2015</b>
NAME OF PROVIDER OR SUPPLIER <b>RAINIER SCHOOL PAT C</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>RYAN ROAD BUCKLEY, WA 98321</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>Surveyor: 19192 On August 21, 2015 an unannounced complaint inspection was conducted at Rainier State School Pat "C" located at Ryan Road Buckley Wa 98321, by a representative of the Washington State Patrol, State Fire Marshal's Office, the complaint intake number is #3133271 and is regards to a phone line that was dug up by a contractor working on site causing the lose of the automatic fire alarm monitoring. The phone line is repaired and the facility is in compliance at this time. <i>B</i></p> <p>Deputy State Fire Marshal <i>Donald L West</i> Donald L West</p>	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

*[Signature]*

*PMZ*

*8/21/15*

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.