DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING	(X3) DATE SURVEY COMPLETED
	505417		04/10/2014

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
SAINT ANNE NURSING AND REHABILITATIO	3540 NORTHEAST 110TH STREET SEATTLE, WA 98125

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS Surveyor: 19192 This report is the result of an unannounced Fire and Life Safety re-certification survey conducted at the Saint Anne Nursing And Rehabilitation Center on 4/10/2014 by a representative of the Washington State Patrol, Fire Protection Bureau. The survey was conducted in concert with the Washington State Department of Social and Health Services (DSHS) health survey teams. The facility has a total of 47 beds and at the time of this survey the census was 44. The existing section of the 2000 Life Safety Code was used in accordance with 42 CFR 483.70. The facility is a single story structure with a partial basement for support services of Type V-A construction with exits to grade. The facility is protected by a Type 13 fire sprinkler system throughout and an automatic fire alarm system with corridor smoke detection. All exits are to grade with paved exit discharges to the public way. The facility is in compliance with the 2000 Life Safety Code as adopted by the Centers for Medicare & Medicaid Services. The surveyor was: Donald L West, Deputy State Fire Marshal	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE: MARKETING | (X6) DATE: 4/10/14

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.