DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 03/13/2015
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING	(X3) DATE SURVEY COMPLETED
	505009		03/13/2015

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
PARK RIDGE CARE CENTER	1250 NORTHEAST 145TH STREET SEATTLE, WA 98155

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	INITIAL COMMENTS An unannounced Life Safety Code Survey was conducted at Park Ridge Care Center, Shoreline Washington, on March 13, 2015 by staff from the Washington State Patrol, Fire Protection Bureau, WSP- Bellevue District Headquarters. The 2000 existing section of the Life Safety Code was utilized for the survey in accordance to 42 CFR 483.70: Requirements for Long Term Care. Park Ridge is a 115 bed facility with a census of 103 consisting of a Type V-A; 1 story structure built in 1964 and has a basement. The facility is fully sprinkled with an automatic fire alarm system in place. Exit discharge points are to grade and have an all-weather surface and lead to a public way. There were no deficiencies identified during this survey. The facility is in compliance with the Life Safety Code 2000 Edition as adopted by CMS. The Surveyor was: Phil Cane Deputy State Fire Marshal Washington State Patrol, Fire Protection Bureau WSP- Bellevue District Headquarters	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
Dana Markey	Administrator	3.13.15

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.