


STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>505341</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MAIN BUILDING 01</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>03/30/2015</b>
--	---	---	---

NAME OF PROVIDER OR SUPPLIER <b>DISCOVERY NURSING &amp; REHAB OF VANCOU</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>5220 NORTHEAST HAZEL DELL AVENUE VANCOUVER, WA 98663</b>
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p><b>INITIAL COMMENTS</b></p> <p>Surveyor: 29197 This report is the result of an unannounced Fire and Life Safety complaint survey conducted at Discovery Nursing and Rehab on 3/30/15 by a representative of the Washington State Patrol, Fire Protection Bureau. The survey was conducted to confirm the K144 waivers was completed. The existing section of the 2000 Life Safety Code was used in accordance with 42 CFR 483.70. The facility is a one story structure of Type V construction with exits to grade. The facility is protected by a Type 13 fire sprinkler system throughout and an automatic fire alarm system with corridor smoke detection. All exits are to grade with paved exit discharges to the public way. The K144 waiver was for the installation of the remote stop switch on the generators.</p> <p>The facility is in compliance with the 2000 Life Safety Code as adopted by the Centers for Medicare &amp; Medicaid Services.</p> <p>The surveyor was:  Dan Young Deputy State Fire Marshal</p>	K 000		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE 	TITLE <b>Admin</b>	(X6) DATE <b>3/30/15</b>
---	-----------------------	-----------------------------

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.