

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 02/12/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 505431	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 02/12/2013
--	---	---	---

NAME OF PROVIDER OR SUPPLIER BOTHELL HEALTH CARE	STREET ADDRESS, CITY, STATE, ZIP CODE 707 - 228TH SOUTHWEST BOTHELL, WA 98021
--	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000

INITIAL COMMENTS

K 000

An unannounced Life Safety Code Survey was conducted at Bothell Health Care, Bothell, Washington, on February 12, 2013 by staff from the Washington State Patrol, Fire Protection Bureau, Oak Harbor Detachment. The 2000 existing edition of the Life Safety Code was utilized for the survey in accordance to 42 CFR 483.70: Requirements for Long Term Care.


The LTC 99 bed facility with a census of 80, consisted of a Type V-111, 1 story structure, with a partial basement used as storage and was built in 1962. The facility is fully sprinkled with an automatic fire alarm system in place. Exit discharge points are to grade and have an all weather surface and lead to a public way.

A Federal Life Safety Survey was conducted February 12, 2013. The Maintenance Director accompanied the Deputy State Fire Marshal throughout the facility tour and paperwork verification from 7:30 AM to 9:45 AM. While conducting the survey on February 12, 2013, no deficiencies were found.

The facility is in compliance with the Life Safety Code 2000 Edition as adopted by C.M.S.

Paul V. Schroer 
Deputy State Fire Marshal

RECEIVED
FEB 19 2013
FIRE PROTECTION
BUREAU

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE	TITLE	(X6) DATE
	Administrator	2/12/13

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.