

RECEIVED

Printed: 08/04/2015  
FORM APPROVED  
OMB NO. 0938-0391

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES


AUG 10 2015

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>505074</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - NEW WING - 2008 <b>FIRE PREVENTION DIVISION</b> B. WING _____	(X3) DATE SURVEY COMPLETED  <b>08/04/2015</b>
--	---	--	---

NAME OF PROVIDER OR SUPPLIER <b>PARK MANOR REHABILITATION CTR</b>	STREET ADDRESS, CITY, STATE, ZIP CODE <b>1710 PLAZA WAY WALLA WALLA, WA 99362</b>
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------

K 000	<p><b>INITIAL COMMENTS</b></p> <p>Surveyor: 28239 This report is a result of an unannounced Fire and Life Safety re-certification survey conducted on 08/04/2015 at Park Manor Rehabilitation Center SNF located at 1710 Plaza Way, Walla Walla, WA by a representative of the Washington State Fire Marshal. This inspection was conducted in cooperation with the Survey Team from the Washington State Department of Health and Human Services (DSHS).</p> <p>This report is for the new section of the SNF, built in 2008 (South Wing - Rehab). The new section of the 2000 Life Safety Code was used in accordance with 42 CFR 483.70. This facility consists of a single story structure of Type V (111) Construction. All exits from the building are to grade. The census today is 77 with a capacity for 99. The building is protected throughout by a Type 13 Automatic Fire Sprinkler System and an Automatic Fire Alarm System with corridor smoke detection as well as smoke detection in the patient rooms of the SNF. Manual-pull stations are located at each exit as well as each nurses' station.</p> <p>No deficiencies were cited as for this survey. The facility is found to be in compliance with 42 CFR Part 483, "Requirements for Long Term Care Facilities." The Surveyor was:  Doug DeGraff Deputy State Fire Marshal Life Safety Code Inspector 28239</p> <p>The Surveyor was from: Washington State Patrol</p>	K 000		
-------	--	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE 	TITLE <b>ADMINISTRATOR</b>	(X6) DATE <b>8-4-2015</b>
--	-------------------------------	------------------------------

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

RECEIVED

Printed: 08/04/2015  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>505074</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING 02 - NEW WING - 2008  B. WING _____	AUG 10 2015 FIRE PREVENTION DIVISION	(X3) DATE SURVEY COMPLETED  <b>08/04/2015</b>
NAME OF PROVIDER OR SUPPLIER <b>PARK MANOR REHABILITATION CTR</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>1710 PLAZA WAY WALLA WALLA, WA 99362</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 Fire Protection Bureau 143302 E Law Lane Kennewick, WA 99337 Telephone: (709) 734-5806 FAX: (709) 734-5846 doug.degraff@wsp.wa.gov   Doug DeGraff, DSEM 28239	K 000			