

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 09/19/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 505422	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____	(X3) DATE SURVEY COMPLETED 09/19/2014
--	---	---	---

NAME OF PROVIDER OR SUPPLIER NEWPORT COMMUNITY HOSPITAL LTC	STREET ADDRESS, CITY, STATE, ZIP CODE 714 WEST PINE STREET NEWPORT, WA 99156
---	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
--------------------	--	---------------	---	----------------------


K 000	<p>INITIAL COMMENTS</p> <p>This report is the result of an unannounced Fire and Life Safety re-certification survey conducted at Newport Community Hospital Long Term Care in Newport, Washington on 9/19/14 by a representative of the Washington State Patrol, Fire Protection Bureau. The survey was conducted in concert with the Washington State Department of Social and Health Services (DSHS) health survey teams. During the physical tour of the facility I was accompanied by the Plant Operations Director who witnessed any deficiency noted during this survey.</p> <p>The existing section of the 2000 Life Safety Code was used in accordance with 42 CFR 482.41. This facility is a one story structure of Type V- (1) hour construction with exits to grade and is protected by a Type 13 sprinkler system and an Automatic / Manual Fire Alarm System with corridor smoke detection. The Long Term Care is seperated from the adjacent hospital by a 2 hour fire barrier. The facility is licensed for 50 patients.</p> <p>The facility is in substantial compliance with the 2000 Life Safety Code as adopted by the Centers for Medicare & Medicaid Services.</p> <p>The surveyor was:</p> <p>David Rogers Deputy State Fire Marshal Nursing Home Surveyor 32863</p> <p>The surveyor was from: Washington State Patrol Office of the State Fire Marshal Fire Protection Bureau PO Box 19130</p>	K 000	<p>RECEIVED</p> <p>OCT 1 2014</p> <p>FIRE PREVENTION DIVISION</p>	
-------	--	-------	--	--

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE <i>Allen Humma</i>	TITLE <i>ENGINEER</i>	(X6) DATE <i>9-19-14</i>
---	--------------------------	-----------------------------

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

Printed: 09/19/2014
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 505422	(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - MAIN BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 09/19/2014
NAME OF PROVIDER OR SUPPLIER NEWPORT COMMUNITY HOSPITAL LTC		STREET ADDRESS, CITY, STATE, ZIP CODE 714 WEST PINE STREET NEWPORT, WA 99156		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	Continued From page 1 Spokane WA 99219-9130 Telephone: (509) 954-2746 Fax: (509) 227-6639  DSFM D.A. Rogers	K 000	RECEIVED OCT 1 2014 FIRE PREVENTION DIVISION	