

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES


Printed: 10/08/2014  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>505493</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>01 - MAIN BUILDING 01</b>  B. WING _____	(X3) DATE SURVEY COMPLETED  <b>10/08/2014</b>
NAME OF PROVIDER OR SUPPLIER <b>PARK SHORE</b>		STREET ADDRESS, CITY, STATE, ZIP CODE <b>1630 43RD AVENUE EAST SEATTLE, WA 98112</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE
K 000	<p><b>INITIAL COMMENTS</b></p> <p>An unannounced Life Safety Code Survey was conducted at Park Shore Skilled Nursing, Seattle Washington, on October 8, 2014 by staff from the Washington State Patrol, Fire Protection Bureau, WSP- Bellevue District Office.</p> <p>The 2000 existing section of the Life Safety Code was utilized for the survey in accordance to 42 CFR 483.70: Requirements for Long Term Care.</p> <p>Park Shore Skilled Nursing is a 28 bed facility with a census of 23 consisting of a Type I (332); 14 story structure built in 1963 and has a basement and below grade parking structure. The Skilled Nursing area of the building is located on floor two. The facility is fully sprinkled with an automatic fire alarm system in place. Exit discharge points are to grade and have an all-weather surface and lead to a public way.</p> <p>There were no deficiencies identified during this survey. The facility is in compliance with the Life Safety Code 2000 Edition as adopted by CMS.</p> <p>The Surveyor was:</p>  <p>Phil Cane Deputy State Fire Marshal</p>	K 000	<p><b>RECEIVED</b></p> <p><b>OCT 13 2014</b></p> <p>FIRE PREVENTION DIVISION</p>	

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE



Administrator 10/8/14

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.