

**WASTE TREATMENT AND IMMOBILIZATION PLANT  
CHAPTER 4.0  
PROCESS INFORMATION  
CHANGE CONTROL LOG**

Change Control Logs ensure that changes to this unit are performed in a methodical, controlled, coordinated, and transparent manner. Each unit addendum will have its own change control log with a modification history table. The “**Modification Number**” represents Ecology’s method for tracking the different versions of the permit. This log will serve as an up to date record of modifications and version history of the unit.

Modification History Table

<b>Modification Date</b>	<b>Modification Number</b>
07/01/2019	8C.2019.2F
10/01/2018	24590-WTP-PCN-ENV-18-003 (8C.2018.Q4)
09/05/2017	8C.2017.6F
12/15/2016	8C.2016.Q3
06/20/2016	8C.2016.4F

This page intentionally left blank.

DRAFT

1  
2  
3  
4  
5

**CHAPTER 4.0**  
**PROCESS INFORMATION**

DRAFT

1  
2  
3  
4  
5

This page intentionally left blank.

DRAFT

**CHAPTER 4.0**  
**PROCESS INFORMATION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

**TABLE OF CONTENTS**

4.0 PROCESS INFORMATION..... 5

4.1 Process Description ..... 5

4.1.1 Process Overview ..... 6

4.2 Tank Systems ..... 9

4.2.1 Design, Installation, and Assessment of Tank Systems ..... 10

4.2.2 Ancillary Equipment Requirements ..... 11

4.2.3 Integrity Assessments..... 16

4.2.4 Additional Requirements for Existing Tanks ..... 16

4.2.5 Additional Requirements for New Tanks..... 16

4.2.6 Variances from Secondary Containment Requirements..... 23

4.2.7 Tank Management Practices ..... 23

4.2.8 Routinely Non-Accessible Area..... 23

4.2.9 Air Emissions ..... 24

4.2.10 Management of Ignitable, Reactive and Incompatible Waste in Tanks ..... 26

4.3 Waste Treatment Plant Miscellaneous Treatment Sub-Systems [WAC 173-303-680 and WAC 173-303-806(4)(i)] ..... 27

4.3.1 Melter Capacity and Production..... 27

4.3.2 Description of Melter Units [WAC 173-303-806(4)(i)(i)]..... 27

4.3.3 Automatic Waste Feed Cut-Off System..... 29

4.3.4 Offgas Treatment System..... 30

4.3.5 Miscellaneous Unit Emissions Performance ..... 30

4.3.6 Physical and Chemical Characteristics of Waste [WAC 173-303-680(2)(a)(i)]..... 31

4.3.7 Environmental Performance Standards for Melter Systems [WAC 173-303-680(2)] ..... 31

4.3.8 Treatment Effectiveness Report [WAC 173-303-806(4)(i)(iv)]..... 32

4.3.9 Approach to Risk Assessment [WAC 173-303-680(2)(c)(i) through (vii)] ..... 32

4.4 Other Waste Management Units ..... 33

4.4.1 Waste Piles ..... 33

4.4.2 Surface Impoundments..... 33

4.4.3 Incinerators..... 33

4.4.4 Landfills ..... 33

1 4.4.5 Land Treatment ..... 33  
2 4.4.6 Air Emissions Control ..... 33  
3 4.4.7 Waste Minimization ..... 35  
4 4.4.8 Groundwater Monitoring for Land-Based Units ..... 35  
5 4.4.9 Functional Design Requirements ..... 35

6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

**CHAPTER 4 SUBCHAPTERS TABLE OF CONTENTS**

CHAPTER 4A ..... 4A  
Figures and Drawings ..... 4A-1  
CHAPTER 4C ..... 4C  
Compliance with Uniform Building Code ..... 4C-1  
CHAPTER 4D ..... 4D  
Pretreatment Facility Process Description ..... 4D-1  
CHAPTER 4E ..... 4E  
Low-Activity Waste Vitrification Facility Process Description ..... 4E-1  
CHAPTER 4F ..... 4F  
High-Level Waste Vitrification Facility Process Description ..... 4F-1  
CHAPTER 4G ..... 4G  
Direct-Feed Low Activity Waste Facility (EMF) Process Description ..... 4G-1  
CHAPTER 4H ..... 4H  
Analytical Laboratory Process Description ..... 4H-1  
CHAPTER 4I ..... 4I  
Balance of Facilities Process Description ..... 4I-1

1 **4.0 PROCESS INFORMATION**

2 **4.1 Process Description**

3 The Hanford Tank Waste Treatment and Immobilization Plant (WTP) is a Treatment, Storage, and  
4 Disposal (TSD) Facility, permitted as Operating Unit Group 10 under the Hanford Dangerous Waste  
5 Permit. The WTP includes six major facilities. These facilities are the Low-Activity Waste (LAW)  
6 Vitrification Facility, the High-Level Waste (HLW) Vitrification Facility, the Pretreatment Facility (PTF),  
7 the Analytical Laboratory (Lab), the Direct-Feed Low-Activity Waste (DFLAW) Effluent Management  
8 Facility (EMF), and the Balance of Facilities (BOF).

9 The WTP manages mixed and dangerous wastes using tank systems, containment buildings, container  
10 storage areas, [containment miscellaneous units](#), and miscellaneous unit systems. The floors and lower  
11 portions of the black cells and hot cell walls are lined with stainless steel for secondary containment.  
12 Black cells and hot cells are equipped with an instrumented sump or sumps for leak detection. Liquids  
13 are removed from the black cell sumps by steam ejectors.

14 The WTP uses two separate waste process system configurations during mixed waste treatment  
15 operations. These configurations are the Baseline configuration, and the DFLAW configuration.

16 Baseline Configuration

17 In the Baseline configuration, characterized LAW and HLW are sent directly from the Hanford Tank  
18 Farms to the PTF. The mixed waste is pretreated in the PTF and sent to either the HLW Vitrification  
19 Facility or the LAW Vitrification Facility for processing, depending on the waste characterization.  
20 Underground waste transfer lines allow for the transfer of waste from the Hanford Tank Farms to the  
21 PTF, and to and from the LAW Vitrification Facility, HLW Vitrification Facility, Lab, and other TSD  
22 Facilities.

23 The PTF, in the Baseline configuration, uses tank systems, miscellaneous unit systems (defined in  
24 Operating Unit Group 10, Section III.10.G of this Permit), and containment buildings to prepare waste  
25 feed from the Hanford Tank Farms for vitrification.

26 The LAW Vitrification Facility uses miscellaneous treatment unit sub-systems and equipment (defined in  
27 Operating Unit Group 10, Section III.10.H and III.10.I of this Permit), tank systems, and containment  
28 buildings to vitrify LAW feed.

29 The HLW Vitrification Facility uses miscellaneous treatment unit sub-systems and equipment (defined in  
30 Operating Unit Group 10, Section III.10.J and III.10.K of this Permit), tank systems, containment  
31 buildings, and container storage areas to vitrify HLW feed.

32 A tank system and a container storage area are used at the Lab. Container storage is used in the BOF for  
33 waste management activities.

34 Direct-Feed Low-Activity Waste Configuration

35 In the DFLAW configuration, treated LAW from the [Tank Operations Contractor \(TOC\) Hanford Tank](#)  
36 [Farms LAW Pretreatment System \(LAWPS\)](#) is transferred to the LAW Vitrification Facility via an  
37 underground waste transfer line. ~~The LAWPS is permitted as a separate TSD Facility under the Hanford~~  
38 ~~Site Wide Dangerous Waste Permit (Site wide DWP).~~ The DFLAW configuration consists of the EMF,  
39 which includes the DFLAW EMF Process System (DEP), a dedicated ventilation system, and dedicated  
40 utilities, and underground waste transfer lines that allow for the transfer of waste to and from the  
41 ~~TOCLAW Vitrification Facility~~, Lab, and other TSD Facilities. The DFLAW configuration is  
42 independent of the Baseline configuration, and is only used prior to PTF startup and in the event of a  
43 prolonged PTF outage. ~~The EMF uses tank systems and miscellaneous treatment unit sub-systems and~~  
44 ~~equipment, defined in Operating Unit Group 10, Section III.10.M.~~

## 1 Waste Management

2 Waste management activities are discussed in the following sections and in Chapter 4D for the PTF,  
3 Chapter 4E for the LAW Vitrification Facility, Chapter 4F for the HLW Vitrification Facility, Chapter 4G  
4 for the EMF, Chapter 4H for the Lab, and Chapter 4I for the BOF.

## 5 Integrated Control Network

6 WTP operates an Integrated Control Network (ICN). The ICN provides a real-time control and data  
7 acquisition system platform responsible for the operation and control, and alarm management, of WTP  
8 processes during normal operating conditions. The ICN integrates the WTP control systems, such as the  
9 Process Control System (PCJ), the Mechanical Handling Control System (MHJ), and the Autosampling  
10 Control System (ASJ). The ICN includes network hardware devices (switches and routers), linking  
11 devices, computer servers, operating consoles and workstations, local operator interfaces, panels,  
12 enclosures, and an operating system software platform.

13 The WTP control systems serve as the controller logic that generate control outputs to the WTP  
14 processes, including mechanical handling, autosampling, and ventilation. The control systems conduct  
15 various functions, including:

- 16 • Monitoring and/or controlling the electrical services.
- 17 • Monitoring environmental and stack discharge equipment.
- 18 • Controlling non-safety services and utilities.

19 The control systems send data to the ICN where it is passed to the plant information network. The plant  
20 information network is a network designed to store plant operating system data and information  
21 applicable to the WTP Dangerous Waste Permit (DWP). The following are examples of the plant  
22 information network capabilities:

- 23 • Capture and store information related to WTP DWP sample requests, sample statuses, and sample  
24 results.
- 25 • Capture and store information related to the tracking of dangerous/mixed waste containers  
26 throughout the facilities, from point of generation to off-site shipment; including containers  
27 located in permitted container storage areas, containment miscellaneous units, central 90-day  
28 accumulation areas, and satellite accumulation areas.

29 More information on the ICN and plant information network will be provided prior to the initial receipt of  
30 dangerous and/or mixed waste, as required in WTP DWP Permit Condition III.10.D.10.c.v.

### 31 **4.1.1 Process Overview**

32 In the DFLAW configuration, waste from the Hanford ~~TOCank Farms is pumped to the LAWPS where it~~  
33 is processed to meet contractual requirements for transfer of waste directly to the LAW Vitrification  
34 Facility. ~~The LAWPS Facility is permitted as a separate TSD Facility under the Site Wide DWP.~~ After  
35 sampling the waste stream, and confirmation by the WTP that it meets LAW waste acceptance criteria, it  
36 is then pumped directly to the LAW Vitrification Facility.

37 In the Baseline configuration, the WTP will store and treat waste feed from the Hanford Tank Farms in  
38 the PTF. The PTF will separate the waste into two feed streams for the LAW and HLW Vitrification  
39 facilities. Feed from the Hanford Tank Farms is expected to be of four major waste feed types, or waste  
40 feed envelopes A, B, C, and D. For the DFLAW configuration, waste feed will come from waste feed  
41 envelope E. These waste feed envelopes are described as follows:

- 42 • **Envelope A.** This waste feed envelope will contain cesium at concentrations high enough to  
43 warrant removal of these radionuclides during pretreatment, to ensure that the Immobilized  
44 Low-Activity Waste (ILAW) glass will meet applicable requirements.



- 1 • **Envelope B.** This waste feed envelope will contain higher concentrations of cesium than  
2 envelope A. Cesium must be removed to comply with the ILAW specifications. This envelope  
3 may also contain concentrations of chlorine, chromium, fluorine, phosphates, and sulfates that are  
4 higher than those found in envelope A, which may limit the waste incorporation rate into the  
5 glass.
- 6 • **Envelope C.** This waste feed envelope will contain organic compounds containing complexed  
7 strontium and transuranics (TRU) that will require removal in a processing step unique to this  
8 waste envelope. As with envelopes A and B, cesium will also require removal in the pretreatment  
9 process to ensure that ILAW glass meets applicable requirements.
- 10 • **Envelope D.** HLW feed will be in the form of a slurry containing approximately 10 to 200 grams  
11 of unwashed solids per liter. The liquid fraction of the slurry will be separated from the solids  
12 and classified as envelope A, B, or C waste. The solid fraction will be envelope D waste.
- 13 • **Envelope E.** Direct feed from Low-Activity Waste Pretreatment System, with a nominal sodium  
14 concentration of 5 to 8 molar.

15 The WTP treatment processes are designed to immobilize the waste constituents in a glass matrix by  
16 vitrification and to treat the offgas from the processes to a level that protects human health and the  
17 environment.

18 ~~Two similarly designed vitrification systems are used in the WTP in the Baseline configuration. One~~  
19 ~~system immobilizes the pretreated LAW feed and the second immobilizes the pretreated HLW feed. The~~  
20 ~~dangerous waste constituents in the melter feed is destroyed, removed, or immobilized in a glass matrix~~  
21 ~~through the vitrification process.~~

22 ~~The ILAW and Immobilized High Level Waste (IHLW) produced by the WTP will be in the form of~~  
23 ~~glass. The glass is packaged in stainless steel containers for ILAW and stainless steel canisters for IHLW~~  
24 ~~and placed in permitted TSD Facilities.~~

25 Secondary waste streams (e.g., dangerous and/or mixed ~~solid waste, mixed waste and dangerous liquid~~  
26 ~~effluents~~) are characterized and recycled into the treatment process, transported to permitted TSD  
27 Facilities located on the Hanford Site, or transported off-site, as appropriate.

28 Nonradioactive dangerous waste ~~is will~~ also ~~be~~ generated by laboratory and maintenance activities. This  
29 waste ~~is will be~~ managed at the WTP until it can be transferred to an off-site TSD unit. There are six  
30 primary components of the WTP: PTF, LAW Vitrification Facility, HLW Vitrification Facility, EMF, the  
31 Lab, and the supporting BOF systems and utilities. The following discussion presents an overview of  
32 these waste treatment processes and BOF systems at the WTP. Figure 4A-1 in Chapter 4A presents a  
33 simplified process flow diagram of the WTP treatment processes.

#### 34 Pretreatment

35 In the Baseline configuration, waste feed is stored and subsequently treated in the PTF prior to  
36 vitrification. The processes in the PTF conditions the waste feed and removes cesium, strontium,  
37 TRU compounds, and entrained solids from the LAW fraction. The waste feed is also processed through  
38 ultrafiltration to separate the solids.

39 There are four types of waste management units in the PTF:

- 40 • Container storage areas.
- 41 • Tank systems.
- 42 • Containment buildings.
- 43 • Miscellaneous unit systems.

1 The structure of the PTF is supported by a reinforced concrete foundation. The superstructure is made of  
 2 structural steelwork with a metal roof. Typically, the process cells within the PTF are constructed of  
 3 reinforced concrete. Secondary containment is provided as required for tank systems and miscellaneous  
 4 unit systems managing dangerous or mixed waste. Secondary containment consists of either stainless  
 5 steel liners or special protective coatings. Table 4D-3 in Chapter 4D provides information on secondary  
 6 containment. Figure 4A-2 and 4A-2A in Chapter 4A present simplified process flow diagrams of the  
 7 pretreatment processes.

### 8 LAW Vitrification Facility

9 The LAW Vitrification Facility ~~will~~ houses the vitrification systems for production of the ILAW.  
 10 ~~Three~~Four types of waste management units ~~are~~will be located in the LAW Vitrification Facility, as  
 11 follows:

- 12 • ~~Container Storage Areas~~Containment miscellaneous units.
- 13 • Tank systems.
- 14 • ~~Containment buildings.~~
- 15 • Miscellaneous treatment unit sub-systems and equipment.

16 The LAW Vitrification Facility is constructed of reinforced concrete and structural steelwork. The  
 17 below-grade portion of the building structure is made of reinforced concrete, and the superstructure is  
 18 made of reinforced concrete and structural steelwork with a metal roof. The LAW Vitrification Facility  
 19 structure is supported by a reinforced concrete mat foundation.

20 Secondary containment is provided as required for tank systems and miscellaneous unit sub-systems and  
 21 equipment managing dangerous or mixed waste. Secondary containment consists of either stainless steel  
 22 liners or protective coatings. Table 4E-34 in Chapter 4E provides information on secondary containment.  
 23 Figure 4A-3 in Chapter 4A presents a simplified process flow diagram of the LAW Vitrification Facility  
 24 treatment processes.

### 25 High-Level Waste Vitrification Facility

26 The HLW Vitrification Facility houses the vitrification systems for producing Immobilized High-Level  
 27 Waste (IHLW). Four types of waste management units are located in the HLW Vitrification Facility, as  
 28 follows:

- 29 • Container storage areas.
- 30 • Tank systems.
- 31 • Containment buildings.
- 32 • Miscellaneous treatment sub-systems and equipment.

33 The HLW Vitrification Facility is constructed of reinforced concrete and structural steelwork. The lower  
 34 elevations of the building structure are reinforced concrete construction, and the upper elevations made of  
 35 structural steelwork with a metal roof. The HLW Vitrification Facility structure is supported by a  
 36 reinforced concrete mat foundation. Secondary containment is provided as required for tank systems and  
 37 miscellaneous unit sub-systems and equipment managing dangerous or mixed waste. Secondary  
 38 containment consists of either stainless steel liner or protective coating. Table 4F-3 in Chapter 4F  
 39 provides information on secondary containment. Figure 4A-4 in Chapter 4A presents a simplified process  
 40 flow diagram of the HLW Vitrification Facility treatment processes.

### 41 Direct Feed Low-Activity Waste Effluent Management Facility

42 The EMF consists of four primary buildings: the LAW Effluent Process Building, the LAW Effluent  
 43 Drain Tank Building, the LAW Effluent Electrical Building, and the LAW Effluent Utility Building. The  
 44 EMF contains an evaporator system, nine major process vessels, two supporting reagent product storage

1 tanks, heating, ventilation, and air conditioning (HVAC) equipment, and electrical utilities. The buildings  
2 are constructed of reinforced concrete and structural steelwork with a metal roof. The EMF structures are  
3 supported by a reinforced concrete mat foundation.

4 The EMF is designed with a minimum of a 48-hour effluent storage capacity, and includes underground  
5 waste transfer lines to transfer waste to and from the LAW Vitrification Facility, Lab, and other TSD  
6 Facilities. Secondary wastes generated by the EMF are managed as described in Chapter 4G.1

7 There are two types of waste management units in the EMF:

- 8 • Tank systems.
- 9 • Miscellaneous unit systems.

10 Secondary containment is provided as required for tank systems managing dangerous or mixed waste.  
11 Secondary containment consists of either stainless steel liner or protective coating. Table 4G-3 in  
12 Chapter 4G provides information on secondary containment.

### 13 Analytical Laboratory

14 The Lab houses the hot cells, laboratories, and systems for analyzing process samples and managing  
15 regulatory compliance samples. Two types of waste management units are located in the Lab:

- 16 • Container storage areas.
- 17 • Tank systems.

18 The Lab is constructed of reinforced concrete, structural steelwork, and a metal roof. The below-grade  
19 portions of the building structure are constructed of reinforced concrete. The Lab structure ~~is~~ will be  
20 supported by a reinforced concrete mat foundation. Secondary containment is provided as required for  
21 tank systems managing dangerous or mixed waste. Secondary containment consists of either stainless  
22 steel liner or protective coating. Table 4H-2 in Chapter 4H provides information on secondary  
23 containment.

### 24 Balance of Facilities

25 The BOF includes support systems and utilities required for the waste treatment processes within the  
26 PTF, LAW Vitrification Facility, HLW Vitrification Facility, EMF, and the Lab. BOF support systems  
27 and utilities include, but are not limited to, heating and cooling, process steam, process water, chilled  
28 water, primary and secondary power supplies, and compressed air. The BOF also includes the Glass  
29 Former Reagent system (GFR) that supplies glass former reagents to the LAW and HLW Vitrification  
30 facilities. Regulated waste management units within the BOF include:

- 31 • HLW Failed Melter Storage Facility.
- 32 • WTP Waste Storage Area.
- 33 • Transportation Staging Area.

## 34 **4.2 Tank Systems**

35 This section contains descriptive information for each tank system used for managing mixed waste. The  
36 term “tank systems” refers to mixed waste storage or treatment tanks, including primary containment  
37 sumps, and their associated ancillary equipment and containment systems. Figures and permit drawings  
38 depicting design features of tank systems are found in DWP Operating Unit Group 10.

39 The following text uses the terms “vessel” and “tank”. The term “vessel” is an engineering term and  
40 denotes more robust construction than a typical mixed waste storage or treatment tank. The term “vessel”  
41 is included due to the use of the term in the American Society of Mechanical Engineers (ASME) codes  
42 and specifications that are followed for most tank construction at the WTP.

## 4.2.1 Design, Installation, and Assessment of Tank Systems

This section describes the attributes of tank systems containing mixed waste. Tanks and ancillary equipment containing only additives or reagents, such as glass-forming chemicals, precipitation reagents, or unused resin, are not regulated under the Resource Conservation and Recovery Act (RCRA) or the Washington State Dangerous Waste Program, and are therefore not included.

Tank systems containing mixed waste are designed to comply with worst-case scenarios, such as extreme pH, temperature, and pressure conditions. The WTP is entirely new construction, and there are no “existing tanks” in the plant.

Tank systems, with the exception of the two outside tanks at the PTF and the eight outside vessels at the EMF, are located indoors and within process cells, process rooms, or caves with controlled access.

### 4.2.1.1 Design Requirements

#### Tanks

~~Most of the tanks that come in contact with the waste are operated under atmospheric pressure conditions at the WTP.~~ The mixed waste tanks at the WTP are designed, at a minimum, to *Boiler and Pressure Vessel Code* (ASME 2000), the American Petroleum Institute (API) codes, or other appropriate design codes and will be operated under atmospheric pressure conditions. Tank integrity is reinforced by additional requirements of the tank group and seismic category assignment to each tank.

The vessels are designed for seismic loading in accordance with the Uniform Building Code (UBC) standard for Zone 2B (UBC 1997).

The codes and standards that are followed for design, construction, and inspection for the tanks are identified below, as applicable:

- ANSI American National Standards Institute.
- API American Petroleum Institute.
- ASME American Society of Mechanical Engineers.
- ASNT American Society of Non-Destructive Testing.
- ASTM American Society for Testing and Materials.
- ~~• EPA US Environmental Protection Agency.~~
- NACE National Association of Corrosion Engineers.
- NBBPVI The National Board of Boilers and Pressure Vessel Inspectors.
- OSHA Occupational Safety and Health Administration.
- PFI Pipe Fabrication Institute.
- UBC Uniform Building Code.
- ~~• WRC Welding Research Council.~~
- ~~• Permit documents describing tank design requirements are located in DWP Operating Unit Group 10, Appendix 7.7:~~
- ~~• Specification for Pressure Vessel Design and Fabrication, 24590-WTP-3PS-MV00-T0001.~~
- ~~• Seismic Qualification Criteria for Pressure Vessels, 24590-WTP-3PS-MV00-T0002.~~
- ~~• Specification for Pressure Vessel Fatigue Analysis, 24590-WTP-3PS-MV00-T0003.~~

## 1 Piping and Pipe Support Design

2 The design code of the WTP piping and pipe supports is ASME B31.3 Code (ASME 1996), as well as the  
3 United States Department of Energy (DOE) seismic requirements. In compliance with DOE seismic  
4 requirements (DOE 1996), response spectrum method, or UBC (UBC 1997) static method is used for the  
5 seismic analysis of the piping systems.

6 ~~Additional information for piping and pipe support design is included in the following documents, which  
7 are included in DWP Operating Unit Group 10 Appendices as indicated:~~

- 8 ~~• *Material for Ancillary Equipment, 24590 WTP PER M 02 002 (Appendix 7.9).*~~
- 9 ~~• *Piping Material Class Description, 24590 WTP PER PL 02 001 (Appendix 7.2).*~~
- 10 ~~• *Ancillary Equipment Pipe Support Design, 24590 WTP PER PS 02 001 (Appendix 7.5).*~~

### 11 **4.2.1.2 Physical Information for Tanks**

12 Tables in Chapters 4D, 4E, 4F, 4G, and 4H list current tank design information (capacity, materials of  
13 construction, and dimensions). The tank systems are grouped by plant and process system.

14 Tank operation is generally automated. However, operator intervention can be used when human  
15 decisions or approval are required for initiation and termination of a process operation. Descriptions of  
16 tank system operation for major WTP process systems are identified in Chapters 4D, 4E, 4F, 4G, and 4H.

## 17 **4.2.2 Ancillary Equipment Requirements**

18 Information concerning ancillary equipment is provided in the following subsections.

### 19 **4.2.2.1 Transfer or Pressure Control Devices**

20 Several fluid transfer devices are used in the WTP. These devices include mechanical pumps, reverse  
21 flow diverters, and steam ejectors. Breakpots and seal pots, although not fluid transfer devices, are an  
22 important component of vessel operations. These components are discussed in the following sections.

#### 23 Mechanical Pumps

24 Mechanical pumps are used for operations that require high-flow pumps (such as through the evaporator  
25 circuits) or high-pressure head pumps (such as for pumping a waste stream through ultrafiltration  
26 circuits). Mechanical pumps are located in process cells, process rooms, or caves. In general, mechanical  
27 pumps are repaired in place, or removed to a maintenance area. However, remotely maintained pumps  
28 are used in areas where maintenance activities would result in a significant radiation dose to the operators.

29 For normal process operating sequences, mechanical pumps and associated valves are controlled by the  
30 process control system. In systems where off-normal conditions require pump shutdown, the design  
31 includes an alarm mechanism that also trips the transfer device. The pump system is designed to allow  
32 for the drainage of liquid from the pump, and for the introduction of flush liquids at the end of transfers to  
33 reduce residual contamination.

#### 34 Reverse Flow Diverters

35 Reverse flow diverters provide for the maintenance-free pulsed or metered transfer of liquids or slurries  
36 throughout the treatment process. A reverse flow diverter does not need to be fully submerged in order to  
37 remove the contents of a vessel, and it maintains a small and predictable volume of tank contents  
38 following its use. Operation of the reverse flow diverter is cyclical, following timed phases: suction  
39 phase, drive phase, and blowdown. The following paragraphs describe a typical reverse flow diverter  
40 system arrangement.

1 **Suction phase:** In the suction phase, the secondary automatic valve A is open, admitting air to the suction  
2 jet pump. Valve B is shut and liquid is drawn from the supply tank through the reverse flow diverter and  
3 into the charge vessel. The suction ejector is designed so that it cannot produce a vacuum capable of  
4 lifting liquid higher than a certain valve known as the “suction lift.” After a short time, the liquid reaches  
5 this “suction lift” height and stops, then valve A is shut.

6 **Drive phase:** When valve A is shut, valve B is opened, admitting air to the drive nozzle. Air passes  
7 through the nozzle and pressurizes the charge vessel. Liquid is forced across the reverse flow diverter and  
8 into the delivery pipe. The delivery pipe is quickly filled with liquid that flows into the delivery vessel.

9 **Blowdown phase:** When the charge vessel is nearly empty, valve B is shut; no air is supplied to either jet  
10 pump. The compressed air in the charge vessel passes back through the paired jet pumps, down the vent  
11 pipe, and into vessel vent system.

12 Shortly after blowdown begins, the pressure in the charge vessel falls below the delivery head, and the  
13 flow of liquid into the delivery vessel is halted.

14 The liquid in the delivery vessel then falls back down the pipe, across the reverse flow diverter, and into  
15 the charge vessel. After a short time, the pressure in the charge vessel falls to zero (gauge). The cycle is  
16 now complete.

### 17 Steam Ejectors

18 Steam ejectors are used to transfer process liquids, or to reduce the operating pressure of a system by gas  
19 removal. They empty liquid from vessels by means of suction lift, using a simple control system.

20 An automated control valve supplies high-pressure steam to the steam ejector. This steam accelerates  
21 through a nozzle, creating a differential pressure along a submerged suction leg within the vessel. The  
22 pressure then forces the liquid up the suction pipe. This effect is known as striking. The steam then  
23 conveys the liquid to the destination vessel, normally via a breakpot. Control is established using liquid  
24 level instrumentation in the vessel being emptied, and using a temperature indicator, such as a  
25 thermocouple, within the breakpot.

### 26 Seal Pots

27 A seal pot is a type of hydraulic seal. A hydraulic seal is used primarily to maintain a separation between  
28 vessel vent or offgas systems for feed and receipt vessels. This separation is necessary to prevent  
29 migration of airborne contamination between the vessels. Without the seal, airflow could occur due to the  
30 different pressures in the vent systems. The seal is a slug of liquid in the interconnecting pipe work that  
31 remains after each liquid transfer is completed, blocking airflow between vessels.

32 The seal can be provided by constructing a simple “U” shape in the piping. Different piping  
33 arrangements are used for different purposes. A seal pot is a small vessel with one (inlet or outlet) pipe  
34 submerged in the liquid slug in the lower part of the pot, while the other pipe terminates in the top of the  
35 pot, above the static liquid level. The pot may be provided with a level indicator or alarm, if necessary, to  
36 ensure adequate liquid level. Periodic liquid additions may be needed to maintain the seal, especially if  
37 the pipeline is infrequently used.

### 38 Breakpots

39 The main function of the breakpot is to reduce the amount of mixed waste material entrained into the  
40 vessel ventilation system. Breakpots are provided on transfer lines that use steam ejectors for moving  
41 liquids by pressure flow. These types of transfers create the potential for air entrainment of mixed waste  
42 contamination. Breakpots function to convert steam from pressure flow to liquid gravity flow, thereby  
43 reducing both the effluent loading on the downstream vessel ventilation treatment system and the mixed  
44 waste contamination levels in the vessel vent ductwork. Breakpots also serve a secondary purpose by  
45 providing a siphon break for other transfer systems where siphoning could occur.

1 Breakpots are typically placed at a high point in the discharge line from the steam ejector. Liquid is  
2 pumped into the breakpot through an inlet nozzle in its wall. The incoming liquid is directed towards a  
3 baffle. Within the baffle, noncondensed steam and gases disengage. The breakpot is self-draining; the  
4 liquid drains through the breakpot discharge pipe to the destination vessel.

5 A packed bed where disenainment of the gas stream occurs is located above the inlet nozzle(s). The  
6 exiting gas from the packed section passes into the vessel ventilation system. The packed bed can be  
7 washed periodically using a wash ring permanently installed above the packed bed.

#### 8 **4.2.2.2 Bulges**

9 Bulges allow hands-on maintenance of equipment after process fluids are flushed from the bulge piping  
10 and components. Bulges provide shielding to personnel during process operation and allow vulnerable or  
11 failure prone components to be located outside the process environment. The cell wall provides shielding  
12 between the cell and the bulge interior. The bulge includes shielding and contamination control as  
13 needed, depending on the process fluid within the bulge piping.

14 A typical bulge consists of a metal frame attached to the outside wall of a process cell; the frame is used  
15 to support the piping and components as well as the shielding plates (usually steel), which are bolted to  
16 the frame. Bulges provide secondary containment for DWP ancillary equipment inside the bulge.

17 The ancillary equipment located inside the bulges are provided with leak detection or the bulge is  
18 provided with a drain line that flows to a sump equipped with leak detection. Leak detection can be  
19 provided internal to the bulge or in the sump associated with bulge drain line.

20 There are two classifications of bulges used at the WTP. One is a “process” bulge; the other is a  
21 “service” bulge. The process bulge contains valves, pumps, piping, etc. The service bulge contains  
22 valves used to transfer reagents, steam, etc., to the in-cell process equipment. The design of the two  
23 bulges is similar.

24 Bulges are equipped with several wash systems, facilitating washing both internal and external piping,  
25 components, and bulge confinement surfaces. Decontamination of the equipment internals and associated  
26 piping is achieved by externally connecting a flushing system located on the outside of the bulge. Wash  
27 fluids could be water or more aggressive media such as nitric acid, provided compatibility with the bulge  
28 materials is ensured.

29 Additional information on process bulges may be found in *Process Bulge Design and Fabrication*  
30 *(24590-WTP-3PS-MX00-T0001)*, located in DWP Operating Unit Group 10, Appendix 7.7 and  
31 Chapter 4A, Figure 4A-127.

#### 32 **4.2.2.3 Description of Waste Treatment Plant Piping System**

33 ~~Detailed information on piping is included in *Piping Material Class Description*~~  
34 ~~*(24590-WTP-PER-PL-02-001)*, located in DWP Operating Unit Group 10, Appendix 7.2.~~

#### 35 Interplant Piping Transfer Lines

36 In both the Baseline and DFLAW configurations, waste feed from the Hanford ~~TOCank Farms and the~~  
37 ~~LAWPS will be is~~ transported to the WTP via underground waste transfer lines.

38 The waste feed transfer lines are double-walled pipe. The inner pipe is constructed of stainless steel,  
39 while the outer secondary containment pipe is constructed of carbon steel. The carbon steel outer pipe is  
40 coated with a fusion bonded epoxy (FBE) coating. In addition, the coated outer pipe for the waste  
41 transfer lines are surrounded by an injected closed-cell polyurethane foam insulation and a high-density  
42 polyethylene outer jacket. This extra layer of protective material isolates the waste transfer lines from  
43 soil.

1 The inner pipe is supported by guides, saddles, support keys, or anchors within the outer pipe. The inner  
2 pipe transports waste and maintains the pressure boundary, while the outer pipe provides secondary  
3 containment for the inner pipe. The piping system is buried under a minimum depth of soil for radiation  
4 shielding. The minimum depth of soil was finalized at the detail design phase and will not be less than  
5 the 2 feet (ft) freeze depth. A heat trace system is not required for pipes buried below freeze depth.

6 In the baseline configuration, the waste transfer lines between the PTF and the other WTP process plants  
7 do not have this extra barrier from the soil, but are cathodically protected as described later in this section.

8 In the DFLAW configuration, the new effluent or process waste transfer lines between the TOCLAWPS  
9 and the EMF, starting at the DOE interface point at the WTP property boundary and ending at the LAW,  
10 and from the EMF back to the Hanford Tank Farms ending at DOE interface point at the WTP property  
11 boundary, utilize the High Density Polyethylene (HDPE) jacketed design to isolate the transfer lines from  
12 the soil environment. Similarly, the transfer lines between the LAW and EMF, the Lab and EMF, and the  
13 EMF to the intersection of the existing transfer line between the PTF and the Liquid Effluent Retention  
14 Facility/Effluent Treatment Facility (LERF/ETF) interface point, utilize the HDPE jacketed design. In  
15 the DFLAW configuration, the cathodically protected intra-facility piping system between the PTF and  
16 the other WTP facilities are will be isolated, and not used. ~~However, the cathodic protection system will~~  
17 ~~remain operational even though wastes are not being managed in these process transfer lines.~~

18 A leak detection system is provided for each of the underground waste transfer lines. A leak detection  
19 alarm will sends a signal to stop waste transfer pumps and terminate the transfer of waste feed.

20 The underground piping system has a continuous slope down toward the PTF from the Hanford Tank  
21 Farms in the Baseline configuration. In the DFLAW configuration all transfer lines slope to Leak  
22 Detection Boxes (LDBs) located in the LAW Effluent Drain Tank Building. The exception is the  
23 LERF/ETF transfer line LDBs which are located at the LERF/ETF interface point on the WTP property  
24 line. Any rReleased liquids resulting from leaks to the outer pipe will be removed as required by  
25 the Washington Administrative Code (WAC) 173-303-640(4)(b). The piping system is designed to allow  
26 water flushing to occur.

### 27 Liquid Effluent Transfer Lines

28 In the Baseline configuration, liquid effluent generated at the WTP is routed to the PTF for recycling  
29 through the WTP and then transferred to the LERF/ETF for treatment and disposal.

30 To support the Baseline configuration two HDPE jacketed waste effluent lines are routed from the PTF to  
31 the LERF/ETF interface point located northwest of the EMF along the WTP property line. In the  
32 DFLAW configuration two HDPE transfer lines intersect the existing LERF/ETF transfer lines between  
33 the PTF and the interface point. In this configuration the transfer line between the PTF and the line  
34 intersection is isolated to prevent fluids from flowing to the PTF. The pipes have a continuous  
35 downwards slope towards the LERF/ETF. A leak detection system is provided for the LERF/ETF waste  
36 transfer lines at their ir ~~LERF/ETF~~ interface point.

### 37 Intraplant Piping

38 Pipelines within the plants, associated with the tank systems located in process cells, black cells, bulges  
39 and pipe and pump pits, are typically single-walled pipelines. Secondary containment is provided by  
40 partially lined process cells, process rooms, or caves; and is provided. ~~Secondary containment to support~~  
41 ~~unique processes is provided~~ by pump and pipe pits, melter encasement assembly areas, and bulges or  
42 concrete ducts with liners at appropriate locations. The bulge or concrete ducts are provided with a low  
43 point which drains to process cells, process rooms, or caves. The leak detection equipment located within  
44 the process cells, process rooms, and caves provides warning of a piping leak through leak detection  
45 alarms.



1 Piping between plants and the two outdoor tanks at the PTF, and the eight EMF outdoor vessels, are  
 2 double-walled, FBE-coated, insulated, HDPE-jacketed lines. The majority of the transfer lines are  
 3 located below grade, and below the freeze line. The above ground segment of the lines to the associated  
 4 vessels are insulated and heat traced to prevent freezing.

### 5 Cathodic Protection

6 An impressed current cathodic protection system is used in the Baseline configuration for eliminating or  
 7 mitigating corrosion on underground piping. The cathodic protection system maintains a negative pipe to  
 8 soil potential on the protected pipe relative to a saturated copper/copper sulfate reference electrode.

9 The impressed current cathodic protection system uses direct current provided by a rectifier that is  
 10 powered from the plant's normal 480 Vac power system. The direct current from the rectifier is  
 11 connected across the buried anode wire and the protected pipe. The current flows from the anode wire,  
 12 which is positive, through the electrolyte, to the protected pipe, which is negative, and back to the rectifier  
 13 completing the electrical circuit.

14 An annual survey, recommended by NACE International (formerly the National Association of Corrosion  
 15 Engineers), is performed on the system provided with cathodic protection. Test stations are provided to  
 16 permit potential measurements. Additional information on inspections is provided in Operating Unit  
 17 Group 10, Chapter 6A.

18 ~~The following waste transfer lines are provided with cathodic protection at the WTP. The waste transfer~~  
 19 ~~lines are double encased and constructed of materials that are compatible with the waste:~~

- 20 ~~• Mixed waste transfer lines between the PTF and the HLW Vitrification Facility.~~
- 21 ~~• Mixed waste transfer lines between the PTF and the LAW Vitrification Facility.~~
- 22 ~~• Mixed waste transfer line between the Lab and the PTF.~~

### 23 Corrosion Protection

24 The following WTP waste transfer and effluent transfer lines that utilize FBE, thermal insulation, and an  
 25 HPDE jacket, are isolated from soil moisture with an external water resistant barrier to provide corrosion  
 26 protection:

- 27 • DOE waste feed pipelines from the Hanford Tank Farm interface point to the PTF.
- 28 • Radioactive/dangerous waste effluent transfer lines from the Pretreatment to the ETF/LERF  
 29 interface point.
- 30 • Mixed waste transfer lines from the TOCLAWPS to the EMF starting ~~at the DOE interface point~~  
 31 at the WTP property boundary and ending at the LAW Vitrification Facility.
- 32 • Mixed waste transfer lines from the EMF back to the Hanford Tank Farms beginning at EMF and  
 33 ending ~~at the DOE interface point~~ at the WTP property boundary.
- 34 • Mixed waste transfer lines from the LAW Vitrification Facility to the EMF.
- 35 • Mixed waste transfer lines from the Lab to the EMF.
- 36 • Mixed waste transfer lines from the EMF to an intersection point on the existing transfer line  
 37 from the PTF to the LERF/ETF interface point at the WTP property boundary.

38 The incoming ~~TOCDOE~~ waste feed pipelines that interface with the WTP pipelines are intentionally not  
 39 cathodically protected. Consistent with the existing Hanford Tank Farm waste transfer design, transfer  
 40 lines from the WTP ~~boundary interface point~~, the Waste Feed Receipt Process (FRP) transfer lines and the  
 41 LERF/ETF effluent coaxial transfer lines are furnished with additional corrosion protection by the  
 42 addition of an external water resistant barrier. This barrier isolates the lines from moisture in the  
 43 surrounding soils and provides corrosion protection in lieu of cathodic protection.

1 The barrier consists of a 2-inch layer of sprayed or injected closed-cell polyurethane foam with an  
2 external jacket of extruded HDPE jacket with a minimum thickness of 140 mils. This barrier is located  
3 over the fusion bonded epoxy coated carbon steel outer encasement pipe which provides secondary  
4 containment for the inner stainless steel process line.

5 The incoming waste transfer lines are also bonded at the crossing of the plant service air piping between  
6 the PTF and the HLW Vitrification Facility on the opposite end (which is cathodically protected piping).  
7 This area is defined as the “zone of influence.” Bonding is provided to minimize stray electrical currents  
8 that may occur in the zone of influence.

#### 9 **4.2.2.4—Description of Foundations**

10 ~~Tank systems containing mixed waste are located indoors in process cells or caves, which are an integral~~  
11 ~~part of the PTF, Lab, the LAW Vitrification Facility, HLW Vitrification Facility, and the EMF. The~~  
12 ~~exception being two outdoor PTF tanks and eight outdoor EMF vessels. Therefore, the design~~  
13 ~~requirements of the tank systems are met by the structural integrity of the plants. WTP compliance with~~  
14 ~~UBC seismic design requirements, found in DWP Operating Unit Group 10, Supplement 1, provides the~~  
15 ~~seismic design requirements for the WTP. The outdoor tanks and vessels are located outside of the PTF~~  
16 ~~and EMF on protectively coated concrete pads and concrete berms. The concrete pads for these tanks are~~  
17 ~~sufficient to support the tanks and vessels.~~

18 ~~Additional information on the design criteria, load definitions, load combinations, and methodology for~~  
19 ~~the structural design and analysis may be found in *Secondary Containment Design*~~  
20 ~~(24590 WTP PER CSA 02 001), located in DWP Operating Unit Group 10, Appendix 7.5.~~

#### 21 **4.2.3 Integrity Assessments**

22 Periodic integrity assessments are conducted on the WTP tank and miscellaneous treatment systems per  
23 the integrity assessment program and schedule in the DWP Operating Unit Group 10, Chapter 6A.  
24 Results of the integrity assessments will be included in the WTP Unit operating record until ten (10) years  
25 after post-closure, or corrective action is complete and certified, whichever is later. Written assessments  
26 of the adequacy of the design of tank systems and miscellaneous treatment systems are prepared on a  
27 system-by-system basis. Separate reports are prepared for tanks, tank system ancillary equipment, and  
28 associated secondary containment systems. Each assessment is reviewed and certified by an independent,  
29 qualified, registered professional engineer to attest that the tank and miscellaneous treatment systems are  
30 adequately designed for managing dangerous waste. Each assessment includes an evaluation of the  
31 foundation, structural support, seams, connections, pressure controls, compatibility of the waste with the  
32 materials of construction, and corrosion controls for each mixed waste management system, as  
33 appropriate. Integrity assessment reports are located in DWP Operating Unit Group 10, Appendix 7.5:  
34 “Civil, Structural, and Architectural Criteria and Typical Design Details.” Appendix 8.11 for the PTF,  
35 Appendix 9.11 for the LAW Vitrification Facility, Appendix 10.11 for the HLW Vitrification Facility,  
36 Appendix 11.11 for the Lab, and Appendix 13.11 for the EMF.

#### 37 **4.2.4 Additional Requirements for Existing Tanks**

38 Tanks and vessels that are permitted in the WTP are newly constructed; pre-existing tanks will not be  
39 used. Therefore, the requirements of this section do not apply.

#### 40 **4.2.5 Additional Requirements for New Tanks**

41 Tank system installation is performed in a manner designed to prevent damage to the tank system. The  
42 WTP uses an independent, qualified installation inspector, or an independent qualified registered  
43 professional engineer to perform tank system installation inspections, in accordance with WAC 173-303-  
44 810(13)(a). Inspection activities include testing tanks for tightness, verifying protection of ancillary  
45 equipment against physical damage and stress, and evaluating evidence of corrosion. The inspections  
46 document weld breaks, punctures, coating scrapes, cracks, corrosion, and other structural defects.

1 Installation inspections conform to permit requirements and consensus-recognized standards. Inspection  
2 findings and corrective actions, as appropriate, are documented in post-inspection reports.

3 ~~Additional information describing the installation of tank systems and associated inspections are provided  
4 in *Installation of Tank Systems and Miscellaneous Unit Systems*, 24590 WTP PER CON-02-001.~~

#### 5 **4.2.5.1 Additional Requirements for New AboveOn-Ground or UndergroundTanks**

6 The majority of the tanks and vessels to be constructed in the WTP are located within the PTF, the Lab,  
7 the LAW Vitrification Facility, and the HLW Vitrification Facility. Therefore, the requirements of this  
8 section do not apply to the indoor tanks.

9 The two outdoor Process Condensate Tanks located at the PTF (RLD-TK-00006A/B), and the eight  
10 outdoor vessels at the EMF (DEP-VSL-00002, DEP-VSL-00003A/3B/3C, DEP-VSL-00004A/4B, and  
11 DEP-VSL-00005A/5B), are located within a bermed and lined secondary containment system and are not  
12 be in direct contact with soil. The design of the outdoor tanks' concrete pad addresses backfill, soil  
13 saturation, seismic forces, and freeze thaw effects. A portion of the ancillary piping for the unit is in  
14 contact with the soil, and the effects of corrosion on the piping are addressed in the final design.

#### 15 ~~4.2.6—Secondary Containment and Release Detection for Tank Systems~~

16 ~~This section provides information about the secondary containment for tank systems that contain mixed  
17 waste in the WTP. Descriptions of equipment and procedures used for detecting and managing releases  
18 or spills from tank systems are also provided.~~

19 ~~A number of documents are provided in appendices to DWP Operating Unit Group 10 that provide  
20 detailed information regarding the design of the secondary containment system. These documents include  
21 the following:~~

- 22 ~~• *Secondary Containment Design*, 24590 WTP PER CSA-02-001, located in Appendix 7.5.~~
- 23 ~~• *Material Selection for Building Secondary Containment/Leak Detection*,  
24 *24590 WTP PER M-02-001*, located in Appendix 7.9.~~
- 25 ~~• *Leak Detection in Secondary Containment Systems*, 24590 WTP PER J-02-002, located in  
26 *Appendix 7.5*.~~
- 27 ~~• *Flooding Volume for PT Facility*, 24590 PTF PER M-02-005, located in Appendix 8.8.~~
- 28 ~~• *Flooding Volume for 28 Ft Level in PT Facility*, 24590 PTF PER M-03-001, located in  
29 *Appendix 8.8*.~~
- 30 ~~• *Flooding Volume for 56 Ft Level in PT Facility*, 24590 PTF PER M-04-001, located in  
31 *Appendix 8.8*.~~
- 32 ~~• *Flooding Volume for 77 Ft Level in PT Facility*, 24590 PTF PER M-04-0003, located in  
33 *Appendix 8.8*.~~
- 34 ~~• *Flooding Volume for Room P-0150 in the PT Facility*, 24590 PTF PER M-04-0008, located in  
35 *Appendix 8.8*.~~
- 36 ~~• *Flooding Volume for Room P-0119 in the PT Facility*, 24590 PTF PER M-04-0005, located in  
37 *Appendix 8.8*.~~
- 38 ~~• *Flooding Volume for Room P-0123A in the PT Facility*, 24590 PTF PER M-04-0007, located in  
39 *Appendix 8.8*.~~
- 40 ~~• *Dangerous Waste Permit (DWP) Liner Heights in the LAW Facility*, 24590 LAW PER M-02-  
41 *002*, located in *Appendix 9.8*.~~
- 42 ~~• *Flooding Volume for the HLW Facility*, 24590 HLW PER M-02-003, located in *Appendix 10.8*.~~

- 1 ~~• Dangerous Waste Permit (DWP) Liner Heights in the LAB Facility, 24590 LAB PER M 02 001,~~  
2 ~~located in Appendix 11.8.~~
- 3 ~~• Leak Detection Capability in the Pretreatment Facility, 24590 PTF PER M 04 0010, located in~~  
4 ~~Appendix 8.18.~~
- 5 ~~• Waste Removal Capability for the Pretreatment Facility, 24590 PTF PER M 04 0011, located in~~  
6 ~~Appendix 8.18.~~
- 7 ~~• Leak Detection Capability in the Low Activity Waste Facility, 24590 LAW PER M 05 002,~~  
8 ~~located in Appendix 9.18.~~
- 9 ~~• Waste Removal Capability for the LAW Vitrification Facility, 24590 LAW PER M 05 001,~~  
10 ~~located in Appendix 9.18.~~
- 11 ~~• Leak Detection Capability in the HLW Facility, 24590 HLW PER M 04 002, located in~~  
12 ~~Appendix 10.18.~~
- 13 ~~• HLW Facility Waste Removal Capability, 24590 HLW PER M 04 0001, located in Appendix~~  
14 ~~10.18.~~
- 15 ~~• Lab Minimum Leak Rate Detection Capabilities for Leak Detection Boxes, Cell Sumps, and Pit~~  
16 ~~Sumps, 24590 LAB PER M 04 0001, located in Appendix 11.18.~~
- 17 ~~• LAB Waste Removal Capability for the Effluent Vessels Cells, 24590 LAB PER M 04 0002,~~  
18 ~~located in Appendix 11.18.~~
- 19 ~~• System Logic Description for the Direct Feed LAW Effluent Management Facility Process~~  
20 ~~System (DEP), 24590 BOF PER J 16 001, located in Appendix 13.13.~~
- 21 ~~• Leak Detection Capability in the EMF Facility, 24590 BOF PER M 16 001, located in Appendix~~  
22 ~~13.18.~~
- 23 ~~• Waste Removal Capacity for the Direct Feed LAW Effluent Management Facility (EMF),~~  
24 ~~24590 BOF PER M 16 002, located in Appendix 13.18.~~
- 25 ~~• Dangerous Waste Permit (DWP) Liner Heights in the Effluent Management Facility (EMF),~~  
26 ~~24590 BOF PER M 16 003, located in Appendix 13.8.~~

#### 27 **4.2.6.14.2.5.2 Secondary Containment System Requirements**

28 Most of the tank systems containing mixed waste are located within the plants, although two tanks are  
29 located outside the PTF, and eight vessels are located outside of the EMF. Tank systems containing  
30 mixed waste that are located within the plants are arranged within process cells, process rooms, caves, or  
31 other areas provided with secondary containment liners or coatings. The outside tanks and vessels are  
32 located on a bermed, concrete pad, provided with special protective coatings and coverings or waterstops,  
33 or provided with stainless steel liners that provide secondary containment.

34 The secondary containment systems are designed, installed, and operated to prevent migration of waste or  
35 accumulated liquid to soil, groundwater, or surface water. The piping associated with the tank systems  
36 are located in the process cells, process rooms, caves, berms, or bulges. Secondary containment for  
37 piping systems is incorporated into the design.

38 Tank systems and wet miscellaneous treatment systems are provided with secondary containment that can  
39 contain 100% of the volume from the largest tank within the containment area. In the PTF, the 15 black  
40 cells and the hot cell at the 0' (ft) elevation are interconnected through hydraulic connections (open  
41 penetrations that interconnect adjacent cells) such that the combined secondary containment volume is  
42 available, if necessary, to contain a 100% leak from the largest tank. A leak to the hot cell floor, if large  
43 enough, drains to the overflow vessels in the pit at -45' (ft) elevation and ultimately to the -45' (ft) pit  
44 secondary containment if the volume of the overflow vessel(s) is exceeded. Secondary containment areas  
45 lined with stainless steel have a gradient (minimum 1%) designed to channel fluids to a sump. In some

1 cases, there may be more than a single sump. For example, the hot cell in the PTF has three instrumented  
2 sumps for leak detection. Fire suppression water is included as appropriate in determining the height of  
3 the secondary containment. Table 4D-3 in Chapter 4D, Table 4E-43 in Chapter 4E, Table 4F-3 in  
4 Chapter 4F, Table 4G-3 in Chapter 4G, and Table 4H-2 in Chapter 4H summarize the calculated  
5 minimum liner height at the four process plants and the Lab. The flooding volume documents identified  
6 above present the secondary containment height for each plant.

7 A concrete berm with protective coatings or stainless liners is used for the PTF and EMF outdoor tanks  
8 and vessels. These secondary containment areas are capable of holding 100% of the volume from the  
9 largest tank within the berm, plus the precipitation from a 25-year, 24-hour rainfall event, as required  
10 under WAC 173-303-640(4)(e)(i)(B).

11 The WTP uses selected industry standards to ensure secondary containment systems have sufficient  
12 strength, thickness, and compatibility with waste. The design includes an engineered structural base to  
13 protect against failure resulting both from excess force applied during catastrophic events or settlement,  
14 and from the stress of daily operation.

15 In the event of a spill or release, the secondary containment design prevents released mixed waste from  
16 reaching the environment, and safely contains the waste until it can be transferred to an appropriate  
17 collection tank.

18 The following subsections provide detailed descriptions of typical secondary containment systems that  
19 ~~are will be~~ used at the WTP.

## 20 Process Cells

21 Process cells are located within process plants. Process cells are typically constructed of concrete walls to  
22 protect plant operators and the environment from radiological exposure and to prevent migration of waste  
23 or accumulated liquid to soil, groundwater, or surface water. Operator access to the process cells is not  
24 allowed during normal operations. However, access is allowed for certain areas within WTP for  
25 nonroutine operations such as equipment replacement or maintenance. Process cells are provided with  
26 liners and special protective coatings as required. Systems within process cells that manage mixed waste  
27 have secondary containment (for example, process vessels and piping).

## 28 Black Cells

29 A black cell is a type of process cell that may contain vessels, evaporators, and piping systems that are  
30 used to support process waste stream storage and blending functions. No active equipment (i.e.,  
31 equipment with moving parts) components are located in the black cell. The design for the vessels and  
32 piping is all welded construction. Some instrumentation (e.g., thermocouples, radiation detectors) are  
33 remotely replaceable by insertion into sealed pipe wells. The black cell vessels and design do not possess  
34 design features for remote replacement. The black cell concept is used in areas where the risk of vessel or  
35 piping failure due to corrosion or erosion is low. The PTF contains fifteen black cells and the HLW  
36 Vitrification Facility contains three black cells.

## 37 Hot Cell

38 Alternatively, a hot cell is a type of process cell that contains active equipment and periodically needs to  
39 be remotely accessed for equipment maintenance or replacement.

40 All process cells are provided with secondary containment as required. The floor is sloped to a collection  
41 sump to allow for collection and removal of accumulated liquid within the sump.

## 42 Caves

43 Caves are located within process plants. Caves typically are constructed with concrete walls thick enough  
44 to protect personnel from exposure to mixed waste. Caves house mechanical handling equipment  
45 designed for remote operation and maintenance. They generally have viewing windows and closed

1 circuit television to allow observation of the cave operations and for overseeing remote maintenance. The  
2 cave floors and portions of the walls are provided with secondary containment as required. The floor of  
3 the cave is sloped to a collection sump to allow for collection and removal of accumulated liquid within  
4 the sump.

### 5 Berms

6 Concrete berms are used at the LAW Vitrification Facility for the Caustic Collection Tank  
7 (LVP-TK-00001). The berms are of sufficient structural strength and height to contain the 100% of the  
8 volume of the largest tank.

9 Vault-like structures are used for the two outdoor Process Condensate Tanks (RLD-TK-00006A/B) at the  
10 PTF, and the eight outdoor vessels at EMF (DEP-VSL-00002, DEP-VSL-00003A/B/C, DEP-VSL-  
11 00004A/B, and DEP-VSL-00005A/B). These vault-like structures are of sufficient structural strength and  
12 height to contain the 100% of the volume of the largest tank plus, for the outdoor Process Condensate  
13 Tanks, the amount of precipitation that results from the 24-hour, 25-year storm event.

14 A protective coating is applied to the concrete pad and a portion of the berms and vault-like structures to  
15 prevent contaminant penetration into the concrete. The containment system is designed to allow for the  
16 discharge of storm water after visual or other testing.

### 17 Drip Pan

18 The ancillary equipment/piping may be provided with a drip pan, sloped, or otherwise designed to  
19 perform the secondary containment functions, including leak detection. One such drip pan is located in  
20 the HLW Vitrification Facility Drum Transfer Tunnel (H-B015). ~~Design details of the HLW drip pan are  
21 provided in the Secondary Containment Design, 24590 WTP PER CSA 02 001, located in Operating  
22 Unit Group 10 Appendix 7.5.~~

### 23 Low-Activity Waste Melter Feed Line Encasement Assembly

24 The feed lines that transfer wastes from the LAW Melter Feed Process system to the melters are housed in  
25 the LAW Melter Feed Line Encasement Assemblies (LMP-LDB-00001/00002). The encasement  
26 assemblies are a sloped bellows encasement that contains the feed line where they travel between the  
27 process cells and the melter gallery. The encasement assemblies are equipped with leak detection cables  
28 that run under the feed lines and into the bellows. The assemblies are equipped with drain lines to flow to  
29 sumps in the LAW process cells.

### 30 Autosampling System Samplers

31 The Autosampling System (ASX) samplers in the PTF, HLW Vitrification, and LAW Vitrification  
32 facilities contain both upper and lower secondary containment liners and leak detection systems. The  
33 upper containment area is designed to collect a potential leak from the incoming sample feed and return  
34 lines where they connect to the ISOLOK<sup>®</sup> sampling device. If a leak occurs in the upper containment  
35 area, the leak flows to the sloped liner which diverts the leak to the annular space of the coaxial sample  
36 return lines. Leaks flow down the secondary containment pipe and discharge to secondary containment  
37 with leak detection, typically a sump with a radar level detector. The ASX sample feed and sample return  
38 lines, and the routing of potential leaks in the annular space of the return lines are shown on the associated  
39 process system piping and instrumentation diagrams (P&IDs) ~~provided in Operating Unit Group 10,  
40 Appendix 8.2, 9.2, and 10.2.~~

41 The sloped stainless steel liner in the lower containment area is designed to divert liquids to a sloped  
42 collection trough. The trough contains a removable weir that allows liquids to collect and activate the  
43 thermal level detection switch and alarms to indicate that a leak has occurred. Effluent from a leak flows  
44 to the same drain line that manages ISOLOK flush solutions. The ISOLOK flush lines terminate below  
45 the top of the trough drain to ensure that the leak detection system is not activated when flushing the

1 ISOLOK. The ASX lower containment area drain lines are shown on the associated process system  
2 P&IDs, ~~provided in Operating Unit Group 10, Appendix 8.2, 9.2, and 10.2.~~

### 3 Sump and Leak Detection Boxes and Secondary Containment Drain Systems

4 Sumps, LDBs, and secondary containment drain systems for the four process plants and the Lab are listed  
5 in Table 4D-4 in Chapter 4D, Table 4E-~~54~~ in Chapter 4E, Table 4F-4 in Chapter 4F, Table 4G-4 in  
6 Chapter 4G, and Table 4H-~~53~~ in Chapter 4H and described in the following sections. Systems monitor  
7 and collect liquids managed in the system. Sumps, LDBs, and secondary containment drains are provided  
8 with a stainless steel liner or equivalent to act as the secondary containment. The sumps and LDBs within  
9 the process areas provide a low point for each secondary containment. The sumps and LDBs serve the  
10 following functions:

- 11 • Low point containment.
- 12 • Removal of material by means of sump emptying ejectors or pumps.
- 13 • Sampling of sump contents by means of sump sampling ejectors.

14 The following sections describe the type of sump used at the WTP and the secondary containment drains.

#### 15 Sumps and Leak Detection Boxes

16 Sumps and LDBs are part of the secondary containment system provided for tank systems and wet  
17 miscellaneous treatment systems. Sumps and LDBs are located at a low point in the secondary  
18 containment systems, and are equipped with leak detection instrumentation and corresponding alarm.  
19 Mechanical or fluidic pumps are used to remove liquid that may accumulate in a sump or LDB.

20 ~~A typical sump design is shown in *Secondary Containment Design, 24590 WTP PER CSA 02-001,*~~  
21 ~~located in Operating Unit Group 10 Appendix 7.5. Design details of each sump and LDB, such as the~~  
22 ~~sump size, capacity, level detection instrumentation, and pumps or ejectors are included in Table 4D-4 in~~  
23 ~~Chapter 4D, Table 4E-4 in Chapter 4E, Table 4F-4 in Chapter 4F, Table 4G-4 in Chapter 4G, and Table~~  
24 ~~4H-3 in Chapter 4H and shown on the P&IDs for the Radioactive Liquid Waste Disposal (RLD) and/or~~  
25 ~~Plant Wash and Disposal (PWD) systems, located in Operating Unit Group 10 Appendices 8.2, 9.2, 10.2,~~  
26 ~~and 11.2.~~

27 Four sumps located in the HLW Vitrification Facility Melter Cave 1 and 2 (HSH-SUMP-00003/7/8/9) are  
28 equipped with stainless steel sump baskets. Sump baskets capture and retain small objects which may be  
29 inadvertently dropped into the sump, and prevent them from entering the piping. The baskets are  
30 provided with a lifting bail for the crane to remove from the sump and handles for the power manipulator  
31 to empty into a waste bucket. ~~A typical sump basket design is shown in *Secondary Containment Design,*~~  
32 ~~24590 WTP PER CSA 02-001, Figure 10, located in Operating Unit Group 10 Appendix 7.5. Sump~~  
33 ~~baskets are also identified on the P&IDs for the HLW RLD system, located in Operating Unit Group 10~~  
34 ~~Appendix 10.2. Sumps in the PTF, LAW, Lab, and EMF are provided with screened or perforated covers~~  
35 ~~to prevent small objects from falling into, or accumulating in the sump. An example of a typical sump~~  
36 ~~screened cover is shown *Secondary Containment Design, 24590 WTP PER CSA 02-001, Figure 20,*~~  
37 ~~located in Operating Unit Group 10 Appendix 7.5. Secondary Containment Drains.~~

38 Many of the bulges, the autosamplers, and some process areas have secondary containment drains. This  
39 type of liquid collection system is located in a low spot in the cell formed by the sloping floor. Liquid  
40 detection instrumentation is provided for the secondary containment drains. Collected liquids  
41 gravity-drain to a collection vessel with a tank level indicator. The managed liquids could be waste  
42 released from a tank system, including ancillary equipment, or water used to wash the exterior of tanks or  
43 the walls of the containment area. Design details of each secondary containment drain/drain line are  
44 included in Table 4D-4 in Chapter 4D, Table 4E-~~54~~ in Chapter 4E, Table 4F-4 in Chapter 4F, Table 4G-4  
45 in Chapter 4G, Table 4H-~~53~~ in Chapter 4H, and shown on the P&IDs for the Radioactive Liquid Waste

1 Disposal (RLD) and/or Plant Wash and Disposal (PWD) systems, ~~located in Operating Unit Group 10~~  
2 ~~Appendices 8.2, 9.2, 10.2, and 11.2.~~

### 3 Design Requirements

4 The process cells, process rooms, or caves with mixed waste vessel or tank systems ~~are~~will be partially  
5 lined with stainless steel or special protective coating, which ~~will covers~~ the floor and extend up the sides  
6 of the process cell or cave to a height that can contain 100 percent of the volume from the largest tank  
7 within the process cell or cave. Table 4D-3 in Chapter 4D, Table 4E-~~43~~ in Chapter 4E, Table 4F-3 in  
8 Chapter 4F, Table 4G-4 in Chapter 4G, and Table 4H-2 in Chapter 4H present the calculated minimum  
9 secondary containment liner height at the four process plants and the Lab.

10 A concrete berm with special protective coatings or stainless liner are used for the PTF and EMF outdoor  
11 tanks and vessels. These secondary containment areas are capable of holding 100% of the volume from  
12 the largest tank within the berm, plus the precipitation from a 25-year, 24-hour rainfall event, as required  
13 under WAC 173-303-640(4)(e)(i)(B).

14 The WTP uses consensus-recognized standards to ensure that the process cells, process rooms, caves, or  
15 berms provide secondary containment with sufficient strength, thickness, and compatibility with waste.  
16 The design includes an engineered structural base to protect the cells, caves, berms, and tank systems  
17 against failure resulting both from excess force applied during catastrophic events or settlement, and from  
18 the stress of daily operation. In the event of a spill or release, the structural and foundation design for  
19 tank and process cells, process rooms, caves, and berms prevents released mixed waste from reaching the  
20 environment, and safely contains the waste until it can be transferred to an appropriate collection tank.

### 21 4.2.6.24.2.5.3 Management of Release or Spill to Sump and Secondary Containment 22 Drain Systems

23 The WTP uses dry sumps and LDBs as part of the secondary containment and leak detection systems.  
24 Sumps and LDBs are instrumented to inform the operator to investigate the cause of the liquid detected in  
25 the sump or LDB. Secondary containment systems are sloped to direct flow of leaks or spills to the sump  
26 or LDB. To remove liquid from the sumps or LDBs in a timely fashion, sumps and LDBs are equipped  
27 with mechanical or fluidic pumps.

28 A detection alarm indicating that there is liquid in the sump or LDB will be investigated to determine if  
29 the alarm is valid. If the alarm is valid, the incident will be corrected. Mixed waste released from the  
30 primary system and collected in a sump or LDB will be removed within 24 hours, or in as timely a  
31 manner as possible. If the released material cannot be removed within 24 hours, the Washington State  
32 Department of Ecology (Ecology) will be notified.

33 Any secondary containment system from which there has been a leak or a spill, or which is unfit for use,  
34 will be removed from service immediately and will satisfy requirements per WAC 173-303-640(7).

### 35 4.2.6.34.2.5.4 Additional Requirements for Secondary Containment

36 The WTP dangerous waste storage tanks have vault-type secondary containments that have either  
37 chemical-resistant water stops and special protective coatings or the following configurations that  
38 Ecology has approved as equivalent to a coating/water stop system:

- 39 • An impermeable interior coating that is compatible with the stored waste and a polymeric filler  
40 material at interior corners and construction joints that performs a function equivalent to a water  
41 stop.
- 42 • A welded stainless steel liner attached to walls and floors.

43 Ancillary equipment such as piping is addressed within Section 4.2. Other types of ancillary equipment  
44 such as pumps, seal pots, and reverse flow diverters are provided with secondary containment. Inspection  
45 of ancillary equipment is addressed in Operating Unit Group 10, Chapter 6.A9.



1 **4.2.74.2.6** Variations from Secondary Containment Requirements

2 No variations from secondary containment requirements are sought for the WTP tank systems. Tank  
3 systems are provided with secondary containment as identified in the flooding volume documents  
4 described in the previous sections.

5 **4.2.84.2.7** Tank Management Practices

6 The following provides the basic philosophy for the WTP vessel overflow systems. Three types of  
7 barriers exist to prevent overflow of process equipment: preventive controls, detectors, and regulators.  
8 Preventive controls promote controlled filling within normal process ranges. Detectors recognize if a  
9 vessel is being overfilled and alert an operator. Lastly, if preventive controls and detectors fail to stop  
10 overflow from occurring, regulators trip a control sequence that stops inflow and/or initiates outflow. The  
11 principal design concept to control vessel overflow is to prevent an overflow from occurring. The  
12 engineering design minimizes the likelihood of tank, ancillary equipment, and containment system  
13 overflows, and over-pressurization, ruptures, leaks, corrosion, and other failures.

14 In general, overflows are prevented by inventory control in conjunction with level monitoring. The fluid  
15 levels in a vessel are maintained within low- and high-level ranges. Appropriate alarm settings are used  
16 to note deviations from the designed settings. Automatic trip action is designed to shut down feed to the  
17 vessel when the high-level settings are exceeded. These automatic trip actions are provided for vessels  
18 with the potential for high operational and environmental impact in case of an accident or release.

19 Most of the WTP tank systems are designed to incorporate minimal or zero maintenance requirements  
20 and are based on a design life of approximately 40 years. The design emphasis of zero maintenance  
21 minimizes the likelihood of spills and overflows in the tank systems. In the event that the process  
22 controls fail to prohibit vessel overflowing, engineered overflows are provided to prevent liquid from  
23 entering the vessel ventilation systems. Vessels that are nominally operating at atmospheric pressure  
24 have a suitable gravity or engineered overflow system, unless an overflow can be shown not to be  
25 possible. Vessels or systems that normally operate at above atmospheric pressures are not be provided  
26 with overflows.

27 The following principles apply when designing an engineered overflow system:

- 28 • The overflow system for vessels must be instantaneously and continuously available for use.
- 29 • Overflowed process streams must be returned to the waste treatment process.
- 30 • Overflow systems must meet the requirements of WAC 173-303, Dangerous Waste Regulations,  
31 Section 640, *Tank systems*. In meeting these requirements, overflowing direct to the cell floor is  
32 only considered as the last overflow in a cascaded system. Where an overflow is from a vessel to  
33 the cell, the overflow system maintains segregation of the cell and vessel ventilation systems.  
34 The compatibility of the overflowing liquid and the recipient vessel is considered.
- 35 • A vessel overflow line is sized to handle the maximum inflow to the vessel without the liquid  
36 level in the overflowing tank reaching an unacceptably high level. No valves or other restrictions  
37 are permitted in the overflow line. This line is also designed to prevent the buildup of material  
38 that could cause blockages.
- 39 • The overflow receiver is sufficiently sized to contain the overflow.
- 40 • Inspections are performed on the various tank and overflow systems, using the example schedules  
41 described in DWP Operating Unit Group 10, Chapter 6A.

42 **4.2.94.2.8** Routinely Non-Accessible Area Labels or Signs

43 ~~Tanks managing mixed or dangerous waste are labeled according to the requirements of DWP permit~~  
44 ~~conditions DWP III.10.E.5.e, for routinely non-accessible tanks, and DWP III.10.E.5.f, for tanks not~~  
45 ~~addressed in DWP III.10.E.5.e. The labels inform employees and emergency personnel of the types of~~

1 ~~waste present, warn of the identified risks, and provide other pertinent information.~~ Tanks, vitrification  
2 sub-systems, or miscellaneous unit equipment that manage mixed or dangerous waste will be provided  
3 with a sign or label according to Permit Condition III.10.E.5.e. The label, or sign, will be posed at the  
4 entry of the non-accessible room or cell, and be legible at a distance of at least fifty (50) feet, and bear a  
5 legend that identifies the waste in a manner which adequately warns employees, and emergency response  
6 personnel of the major risk(s) associated with the waste being stored or treated in the room or process  
7 cell. Personnel may be required to access these areas on a case-by-case basis such as an emergency  
8 response event. The list of routinely non-accessible rooms to support the DFLAW configuration is  
9 provided in Table 6A-3d, DWP Operating Unit Group 10, Chapter 6A.

#### 10 **4.2.104.2.9 Air Emissions**

##### 11 **4.2.10.14.2.9.1 Tank System Emissions**

12 Most of the tanks are connected to a vessel ventilation system to collect vapors. Vessel vents are located  
13 on process vessels and tanks, breakpots, and other small vessels. Exhaust from reverse flow diverters and  
14 pulse jet mixers are also collected.

##### 15 **4.2.10.24.2.9.2 Process Vents**

16 The air emission regulations, specified under WAC 173-303-690 and 40 Code of Federal Regulations  
17 (CFR) 264 Subpart AA, apply to process vents associated with distillation, fractionation, thin-film  
18 evaporation, and air or steam stripping operations that manage mixed waste with total organic carbon  
19 concentrations of at least 10 parts per million by weight. The WTP does not use these regulated  
20 processes; therefore, this regulation does not apply to the WTP.

##### 21 **4.2.10.34.2.9.3 Equipment Leaks**

22 Regulations provided in WAC 173-303-691 and 40 CFR 264 Subpart BB contain the *Air Emission*  
23 *Standards for Equipment Leaks*. These air emission standards do not apply to the WTP because waste  
24 feed entering the WTP contains less than 10% total organic carbon by weight and is excluded under  
25 40 CFR 264.1050(b).

##### 26 **4.2.10.44.2.9.4 Tanks and Containers**

27 The regulations specified under WAC 173-303-692 and 40 CFR 264 Subpart CC do not apply to the WTP  
28 mixed waste tank systems and containers. These tanks and containers qualify as waste management units  
29 that are "...used solely for the management of radioactive mixed waste in accordance with all applicable  
30 regulations under the authority of the Atomic Energy Act and the Nuclear Waste Policy Act" and are  
31 excluded under 40 CFR 264.1080(b)(6). Containers bearing nonradioactive, dangerous waste, such as  
32 maintenance and laboratory waste, that is not excluded under 40 CFR 264.1080 (b)(2) or  
33 40 CFR 264.1080(b)(8), will comply with the tank and container standards specified under 40 CFR 264  
34 Subpart CC.

#### 35 **4.2.9.5 Identification of Containers**

36 All dangerous and/or mixed waste containers are labeled in a manner that adequately identifies the major  
37 risk(s) associated with the contents. When labeling, ensure labels are not obscured or otherwise  
38 unreadable, waste containers are oriented so as to allow inspection of the labels identified with the  
39 container tracking number, and, to the extent possible, any labels which the generator placed upon the  
40 container, empty dangerous and mixed waste containers must have their dangerous and/or mixed waste  
41 labels destroyed or otherwise removed immediately upon being rendered empty.

42 For purposes of container labeling, hazards include the following:

43 A) Persistent (if a WP01 or WP02 waste code).

44 B) Toxic (if a WT01, WT02, or D waste code other than D001, D002, or D003).

1 C) Ignitability (if a D001 and other waste codes).

2 D) Corrosive (if a D002 and other waste codes).

3 E) Reactive (if a D003 and other waste codes).

4 This does not apply to ILAW containers and IHLW canisters, in accordance with Permit Condition  
 5 III.10.D.5.

6 **4.2.10.54.2.9.6 Ventilation Control**

7 This section describes air emissions from vessel ventilation systems and reverse flow diverter exhausts.  
 8 Organic emissions from vents associated with evaporator or distillation units are also discussed.

9 In compliance with the Washington Administrative Code, (WAC) 173-303-695, WTP facilities have been  
 10 designed to prevent fugitive emissions of contaminants from containment buildings within the WTP  
 11 permitted facilities through pathways other than high-efficiency particulate air (HEPA)-filtered and  
 12 monitored discharge points to the environment. WTP HVAC systems, in conjunction with the building  
 13 structures provide the confinement system needed to prevent exit of contaminants from WTP facilities  
 14 through doors, windows, building cracks or other unmonitored and unfiltered exit paths directly to the  
 15 environment.

16 The WTP facilities are designed such that they are segregated into confinement zones for ventilation  
 17 control purposes. WTP confinement zones consist of barriers or barrier systems, which includes walls,  
 18 floors and roofs, and the associated HVAC systems.

19 WTP facilities' ventilation confinement zones consist of the following:

20

Confinement Zone	Contamination Classification	Ventilation Design Philosophy Definitions
Primary	C5	Plant areas and associated ventilation ductwork that are in direct contact with airborne contaminants to adjacent zones under both normal and abnormal operating conditions. Maintained at approximately (-) 1.0 to (-) 1.4 inches of water relative to C3 areas.
Secondary	C3	Contaminated areas where work requires protective clothing. Maintained at maximum negative pressure of (-) 0.4-inches of water relative to surrounding C2 areas.
Tertiary	C2	Controlled Area. Operating areas of the process building that have direct interfaces with contaminated areas and have the potential to be contaminated. Maintained at a slight negative pressure with respect to atmosphere.

21  
 22 Information regarding specific facilities can be found in Chapters 4D.3, 4E.3, and 4F.3.

23 Airborne contaminants in C2 areas will cascade to C3 areas or be removed by C2 exhaust system HEPA  
 24 filters prior to discharge to the environment. Airborne contaminants in C3 areas will cascade to C5 areas  
 25 or be removed by C3 exhaust system HEPA filters prior to discharge to the environment, including  
 26 releases from containment buildings within C3 areas. Airborne contaminant in C5 areas will be removed  
 27 by C5 exhaust system HEPA filters prior to discharge to the environment, including releases from  
 28 containment buildings within C5 areas.

1 The systems are interlocked such that the exhaust system serving areas of lesser contamination potential  
 2 cannot operate without the exhaust systems serving areas of higher contamination potential operating.  
 3 This precludes pressurization of WTP areas and possible fugitive dust emissions from the facility through  
 4 doors, windows, building cracks, or other unmonitored and unfiltered exit paths.

5 The following design features and operational measures will be used to prevent fugitive dust from  
 6 escaping from containment buildings resulting in unfiltered and unmonitored releases to the environment,  
 7 and control fugitive emissions such that openings will not exhibit visible emissions:

- 8 • Cascading air flow from areas of least potential contamination to areas of greatest potential  
 9 contamination (i.e., C2 to C3 to C5 areas).
- 10 • Greater negative pressure in confinement areas compared to outside environment pulls air into the  
 11 area preventing backflow.
- 12 • Intake from one confinement zone to another through air in-bleed units, with isolation and  
 13 backflow control type features.
- 14 • HEPA filtration of exhausted air is monitored prior to atmosphere discharge through the exhaust  
 15 stack. C2 and C3 exhaust systems have one stage of HEPA filters. C5 exhaust systems have two  
 16 stages of HEPA filters.
- 17 • Redundant exhaust fans maintain negative pressure and cascading airflow during normal  
 18 operation, routine fan maintenance and repair conditions.
- 19 • Personnel ingress and egress through airlocks and subchange rooms.
- 20 • Dedicated HEPA-filter systems will be provided for each maintenance area, workshop, and  
 21 decontamination room where local process-generated airborne contaminants will be collected to  
 22 prevent spread outside of the area.
- 23 • Containment buildings (i.e., cells or areas) are typically located within C3 or C5 areas for control  
 24 of airborne contamination.
- 25 • Containment buildings are located within ventilation-controlled process facilities.

#### 26 **4.2.114.2.10 Management of Ignitable, Reactive and Incompatible Waste in Tanks**

27 In the Baseline configuration, mixed waste from the Hanford Tank Farms is initially designated as both  
 28 ignitable (D001) and reactive (D003). The D001 and D003 waste numbers are ~~as~~ described in the waste  
 29 analysis plan in DWP Operating Unit Group 10, [Chapter 3C Appendix 3A](#). The PTF process vessels are  
 30 located in a manner that meets the National Fire Protection Association (NFPA) buffer zone requirements  
 31 for process vessels, as contained in Tables 2-1 through 2-6 of the *NFPA-30 Flammable and Combustible*  
 32 *Liquids Code* (NFPA 1981). The process vessels are designed to store the waste in such a way that it is  
 33 protected from materials or conditions that could cause the contents to ignite or react. Vessel contents  
 34 will be constantly mixed and will be actively vented to process stacks, which will be equipped with vapor  
 35 collection and treatment systems that ~~will~~ manage emissions. Further information on waste numbers is  
 36 contained in DWP Operating Unit Group 10, [Appendix 3A Chapter 3C](#).

37 In the DFLAW configuration, the treated LAW received from ~~LAWPS~~ [the TOC](#) will not demonstrate the  
 38 characteristics of ignitable or reactive waste.

39 Ignitable or reactive waste may be generated from laboratory or maintenance activities. This waste is  
 40 accumulated and managed in compliance with regulatory requirements, in approved containers.  
 41 Potentially incompatible waste generated from laboratory or maintenance activities will not be stored in  
 42 the tank systems.

43 A potential for incompatibility may exist, for example when nitric acid is used to elute waste components  
 44 from ion-exchange column resins that were previously regenerated with sodium hydroxide. To minimize  
 45 a reaction, water flushes are performed between batches.

1 Process reagents that could react with waste in the tank systems are stored in areas that are separated by  
 2 physical barriers from process tanks. Potentially incompatible wastes generated from laboratory or  
 3 maintenance activities will not be stored in proximity to each other in the tank systems.

#### 4 **4.3 ~~Low-Activity Waste and High-Level Waste~~Waste Treatment Plant Miscellaneous** 5 **Treatment Sub-Systems [WAC 173-303-680 and WAC 173-303-806(4)(i)]**

6 The ~~WTP miscellaneous treatment units~~LAW vitrification system and HLW vitrification system consist  
 7 of the vitrification melters, offgas treatment equipment, evaporators and associated equipment. The  
 8 melters immobilize mixed waste in a glass matrix. ~~The LAW vitrification system and the HLW~~  
 9 ~~vitrification system contain two melters each.~~The following sections provide additional information on  
 10 the vitrification systems.

11 Other miscellaneous treatment sub-systems, and their associated process control features, are described in  
 12 Section 4.2.

##### 13 **4.3.1 Melter Capacity and Production**

14 For the melters, throughput is defined on the basis of quantity of glass waste produced. In turn, the  
 15 quantity of glass waste produced depends on the degree to which the feed can be incorporated into the  
 16 glass matrix. The maximum design throughput of the LAW Melter systems is approximately 15 metric  
 17 tons per day of glass waste for each melter and approximately 30 metric tons per day. The production  
 18 rate of the HLW Melters is approximately 3 metric tons per day for each melter and approximately  
 19 6 metric tons per day throughput.

20 In the event that two LAW melters do not meet the combined production of 30 metric tons of glass a day  
 21 then the existing LAW Building will retain capacity to install the third melter before or after hot start up.  
 22 No melter support vessels or support systems should be deleted from process cell design that could  
 23 preclude later melter installation. A third melter would not be proposed if a third LAW melter would  
 24 exceed the capacity of the container handling system or the ventilation system in the LAW Building.

##### 25 **4.3.2 Description of Melter Units [WAC 173-303-806(4)(i)(i)]**

26 The LAW Melter systems are located in the melter galleries and the HLW Melters are housed within the  
 27 melter caves as depicted in the general arrangement plan and section permit drawings, ~~which are found in~~  
 28 ~~DWP Operating Unit Group 10, Appendix 9.4 for the LAW Vitrification Facility and Appendix 10.4 for~~  
 29 ~~the HLW Vitrification Facility.~~

30 The following subsections provide detailed descriptions of the melter units.

##### 31 Low-Activity Waste Melter Units

32 Figure 4A-48 in Chapter 4A provides a sketch of a LAW Melter. Each LAW Melter  
 33 (LMP-MLTR-00001/2) is a rectangular shell, lined with refractory material. An additional outer steel  
 34 casing with access panels is provided to enclose the LAW Melter. This outer steel casing is designed to  
 35 provide local shielding and containment. Each LAW Melter has a nominal design capacity of  
 36 approximately 15 metric tons of glass waste per day. Each has a molten glass surface area of  
 37 approximately 107 square feet (ft<sup>2</sup>). Each of the two LAW melters has external dimensions of  
 38 approximately 31 × 21 × 16 ft high, and weighs approximately 295 metric tons empty and 318 metric tons  
 39 with glass. The operating temperature of the melter is between 1050°C and 1200°C.

40 The locally shielded LAW Melter (LMP-MLTR-00001/2) is operated and maintained in a personnel  
 41 access area. The melter is maintained at a lower pressure than the surrounding room to prevent escape of  
 42 contaminants. Consumable melter parts are replaced through access panels. The melters are transported  
 43 in and out of the gallery on a rail system. ~~A transporter moves the melters to and from the LAW~~  
 44 ~~Vitrification Facility.~~

1 The melter refractory package is designed to serve as a mechanical, thermal, and electrical barrier  
2 between the molten glass residing in the melter and the melter shell. The refractory package is housed in  
3 a steel shell and provides containment for the molten glass. Active cooling on the outside of the  
4 refractory package is provided by water jackets. The water jackets are in the intermediate loop of a  
5 two-loop system that transfers heat from the LAW Melter through heat exchangers to cooling towers.  
6 The intermediate loop containing the water jacket is a closed system that isolates the water circulating  
7 through the water jacket from the water in the cooling water loop circulating to the cooling tower. Mixed  
8 waste material leaking into the intermediate loop cooling water is prevented from becoming an  
9 inadvertent discharge via the cooling tower. The refractory package provides adequate containment if  
10 there is a temporary loss of cooling. Penetrations in the melter system are sealed using appropriate  
11 gaskets and flanges. This system is designed for plenum temperatures of up to 1,100°C. The LAW  
12 melter lid is composed of steel and refractory material layers.

13 Each LAW Melter (LMP-MLTR-00001/2) uses two independent discharge chambers. An air lift pumps  
14 molten glass from the bottom of the melter pool, through a riser, into a discharge chamber, and pours it  
15 into an ILAW container. The ILAW is then allowed to cool, forming a highly durable borosilicate glass  
16 waste form within the container.

17 Spent LAW Melters are initially be-managed within the LAW melter gallery containment building unit.  
18 Spent LAW Melters are removed from the melter gallery and transported using a transport and rail  
19 system. If necessary, the melter exterior surfaces will be decontaminated prior to transfer to a Hanford  
20 Site TSD unit.

### 21 High Level Waste Melter Units

22 Figure 4A-27 in Chapter 4A provides a sketch of an HLW Melter. ~~In addition, the HLW melter~~  
23 ~~mechanical assembly drawings (24590 HLW MF HMP 00001/2/3) are located in Operating Unit~~  
24 ~~Group 10, Appendix 10.6.~~ Each HLW Melter (HMP-MLTR-00001/2) is a rectangular shell, lined with  
25 refractory material. They have four compartments: a glass tank, two discharge chambers, and a plenum  
26 just above the glass tank. The tanks are lined with refractory material designed to withstand corrosion by  
27 molten glass.

28 The HLW Melter systems consist of two melters. Each HLW Melter (HMP-MLTR-00001/2) is designed  
29 for glass production rates up to 3 metric tons per day (MTG/d). The normal operating temperature of the  
30 melter is between 950°C and 1250°C. The HLW Melters have a molten glass surface area of  
31 approximately 40 ft<sup>2</sup>. The HLW Melters have external dimensions of approximately 11 ft high × 14 ft  
32 deep × 14 ft wide. The glass contained in a full HLW Melter has a volume of approximately 145 ft<sup>3</sup> and  
33 weighs approximately 9.1 metric tons. An entire melter, including the supporting structure and transport  
34 mechanism, weighs approximately 90 metric tons empty and approximately 99 metric tons full.

35 The HLW Melters (HMP-MLTR-00001/2) are designed to be remotely operated and maintained. Remote  
36 maintenance is performed by a power manipulator, overhead crane, and auxiliary hoist, or by  
37 through-wall master-slave manipulators. The melter is positioned within the HLW Vitrification Facility  
38 for ease of access and viewing of both discharge chambers during operations, and for viewing access to  
39 the melter lid to facilitate removal and replacement of subcomponents, if needed. A rail and bogie  
40 transport system facilitates remote removal and replacement of the entire melter structure.

41 The HLW Melters (HMP-MLTR-00001/2) uses a refractory package similar to the LAW melter to  
42 contain the molten glass. The refractory package is designed to serve as a mechanical, thermal, and  
43 electrical barrier between the molten glass inside the melter and the melter shell.

44 The HLW Melters also use an outer shell, which, with the refractory package, contains the molten glass  
45 and melter offgas. Active cooling on the exterior of the melter is provided by a water jacket, which is in a  
46 two-loop system that transfers heat from the HLW Melter through heat exchangers to cooling towers.  
47 The loop containing the water jacket is a closed system that isolates the water circulating through the

1 water jacket from the water in the cooling water loop circulating to the cooling tower. Mixed waste  
2 material leaking into the intermediate loop cooling water is prevented from becoming an inadvertent  
3 discharge through the cooling tower. The refractory package provides adequate containment should there  
4 be a loss of cooling. The HLW Melter lid is constructed of a steel outer shell and insulated from the  
5 melter plenum by refractory material.

6 The HLW Melter uses two independent discharge chambers. Discharge is achieved by transferring the  
7 molten glass from the bottom of the melter pool, through a riser, and then poured into a stainless steel  
8 IHLW canister. Glass waste transfer is accomplished through air lifting. The IHLW is then be allowed to  
9 cool, forming a highly durable borosilicate glass waste form.

10 Spent HLW Melters are removed from the melter cave and placed in an overpack. The spent melter is  
11 treated as newly generated waste, and is initially managed within the HLW melter containment buildings.  
12 If necessary, the overpack will be decontaminated using a dry process. Failed HLW Melters are stored in  
13 the failed melter storage building.

#### 14 **4.3.3 Automatic Waste Feed Cut-Off System**

15 The LAW and HLW Melters are equipped with the ability to cut off waste feed. Automatic waste feed  
16 cut-off systems terminate feed to the melter if a specified operating condition is exceeded. This design  
17 approach is consistent with the WAC 173-303-680 regulatory requirements.

18 The LAW (LMP-MLTR-00001/2) and HLW (HMP-MLTR-00001/2) Melters are fed via air displacement  
19 slurry pumps that utilize pressurized air as the motive force. These pumps supply feed to the melters in  
20 slugs that act to keep lines from plugging. The feed is injected into the melters through the feed nozzles  
21 on top of the melter creating a “cold cap”, where waste feed undergoes several physical and chemical  
22 changes. The glass product in the melter is then “air lifted” through the discharge chamber and into the  
23 glass container. Melter offgas is generated from the vitrification of LAW and HLW of which the rate of  
24 generation is dynamic and not steady state. The offgas is then carried away and treated via a dedicated  
25 offgas system.

26 The melter systems are designed to minimize the need for automatic waste feed cut-off functions.  
27 Control of melter level and plenum pressure, process alarming, and optimized operating procedures are in  
28 place to reduce the occurrences of interlocking. Given the processing speeds and the relatively slow rates  
29 of change in the operating states of the melter, operators should have adequate time to react to upset  
30 conditions. An example of the slow rate of change can be seen in the volume of feed per air displacement  
31 slurry pump feed cycle when increasing melter level. Each pump cycle adds approximately one gallon of  
32 slurry into the melter. At one gallon of volume, the liquid level rises no greater than 0.01 inch inside the  
33 melter. This provides ample time for operator response.

34 Previous operating experience with similar melter systems has shown the following operating conditions  
35 may warrant automatic waste feed cut off:

- 36 • Maximum melter chamber pressure.
- 37 • Minimum off-gas temperature at the thermo catalytic oxidizer bed inlet.
- 38 • Maximum carbon bed adsorber bed temperature.
- 39 • Maximum stack gas flow rate.
- 40 • Maximum stack gas carbon monoxide.

41 These interlocks have been sufficient to allow continued melter operations without inadvertent feed cut  
42 off signals, yet provide a sufficient safety margin, and can be found in Permit eCondition tTable  
43 III.10.H.F.

1 **4.3.4 Offgas Treatment System**

2 The offgas treatment system treats or removes steam, aerosols, entrained particulates, decomposition  
 3 products, and volatile contaminants that are generated from the vitrification processes and the vessel  
 4 ventilation systems. The typical constituents contained in the melter offgas stream are as follows:

- 5 • Nitrogen oxides from decomposition of metal nitrates in the melter feed.
- 6 • Chloride, fluoride, and sulfur as oxides, acid gases, and salts.
- 7 • Entrained feed material and glass.

8 A detailed description of the current offgas treatment trains for the LAW (LMP-MLTR-00001/2) and  
 9 HLW (HMP-MLTR-00001/2) Melters is provided in Chapter 4E and Chapter 4F, respectively.

10 **4.3.5 Miscellaneous Unit Emissions Performance**

11 The WTP melter systems are thermal treatment units classified as miscellaneous units in Washington  
 12 Administrative Code (WAC 173-303-680). The dangerous waste regulations require that permits for  
 13 miscellaneous units include such terms, conditions, and provisions that are necessary to protect human  
 14 health and the environment and are appropriate for the miscellaneous unit being permitted. Ecology has  
 15 determined that regulations that are most appropriate to apply to the melters and offgas systems (melter  
 16 systems) are found in the tank requirements (WAC 173-303-640) and applicable sections of the  
 17 incinerator requirements (WAC 173-303-670) and 40 CFR Section 63.1203. As applied to the melter  
 18 systems, the tank regulations primarily provide requirements for structural integrity, material  
 19 compatibility, secondary containments, etc.

20 The incinerator regulations primarily provide operational requirements for parameters such as  
 21 temperature, pressure, feed rate, demonstration testing, and performance standards, etc. Ecology  
 22 determined and incorporated into the final WTP DWP issued in September 2002 the standards specified  
 23 in 40 CFR Section 63.1203 in the following table apply to the WTP melter system miscellaneous units.

24

<b>Miscellaneous Unit Emissions Performance Standards</b>	
<b>Pollutant</b>	<b>Ecology-Directed Requirement</b>
PODC	99.99% destruction and removal efficiency (DRE)
Dioxins and Furans	0.20 ng TEQ/dscm
Mercury	45 µg/dscm
Lead and Cadmium	120 µg/dscm, combined emissions
Arsenic, Beryllium, Chromium	97 µg/dscm, combined emissions
Carbon Monoxide and Hydrocarbons	Carbon monoxide not in excess of 100 ppm <sub>dv</sub> over an hourly rolling average, <u>monitored continuously with a continuous emissions monitoring system.</u> <u>Hydrocarbons not in excess of 10 ppm<sub>dv</sub> during DRE test runs, over an hourly rolling average (monitored with a continuous emissions monitoring system during test runs), corrected to 7 percent oxygen, and reported as propane, dry basis, and hydrocarbons not in excess of 10 ppm<sub>v</sub> over an hourly rolling average, dry basis, and reported as propane, at any time during the DRE test runs or their equivalent, or hydrocarbons not in excess of 10 ppm<sub>v</sub>, over an hourly rolling average, dry basis, and reported as propane</u>



Miscellaneous Unit Emissions Performance Standards	
Pollutant	Ecology-Directed Requirement
Hydrochloric Acid and Chlorine Gas	21 ppmv, combined emissions, expressed as hydrochloric acid equivalents, dry basis
Particulate Matter	34 mg/dscm

PODC is Principle Organic Dangerous Constituent.

TEQ is dioxin/furan toxicity equivalence defined in 40 CFR 63.1201(a).

dscm is dry standard cubic meter.

ppmv is parts per million by volume.

Rolling average is the average of all 1-minute averages over the averaging period [40 CFR 63.1201(a)].

1  
2 DOE intends that the melter systems be designed and constructed so that they operate in compliance with  
3 the appropriate and applicable standards. Environmental performance demonstrations during cold  
4 commissioning of the HLW and LAW Vitrification facilities are used to verify compliance with the  
5 Destruction and Removal Efficiency (DRE) and other applicable air emission standards. ~~The final WTP  
6 Dangerous Waste Permit issued in September 2002 also requires periodic demonstration testing be  
7 performed after the WTP has begun processing radioactive wastes (Ecology, 2001).~~

#### 8 **4.3.6 Physical and Chemical Characteristics of Waste [WAC 173-303-680(2)(a)(i)]**

9 A description of the waste characteristics of the LAW and HLW feeds is presented in DWP Operating  
10 Unit Group 10, Chapters ~~3-A and 3-C0 (see Appendix 3A)~~. The immobilized waste generated by the  
11 vitrification processes is in the form of glass that maintains its chemical and physical integrity during  
12 long-term storage. ~~Chapters 3-A and 3-C The Waste Analysis Plan (Appendix 3A) describes the types and  
13 frequency of analysis that are will be performed on the glass waste.~~

#### 14 **4.3.7 Environmental Performance Standards for Melter Systems [WAC 173-303-680(2)]**

15 An environmental performance demonstration will be conducted to demonstrate the efficiency of the  
16 LAW and HLW Melter systems and their respective air pollution control systems. Emissions from the  
17 LAW and HLW systems will be sampled and analyzed during an environmental demonstration performed  
18 during cold commissioning. The data developed during the environmental performance demonstration  
19 supports the screening-level risk assessment, which supports the development of environmental  
20 performance standards for the LAW and HLW Melter systems.

21 The operational activities of the WTP include methods intended to ensure proper performance of  
22 equipment and processes. ~~These methods include sampling of materials, use of direct process controls,  
23 development of equipment life specifications and ongoing maintenance.~~

#### 24 **4.3.7.1 Protection of Groundwater, Subsurface Environment, Surface Water, Wetlands 25 and Soil Surface [WAC 173-303-680(2)(a) and (b)]**

26 The LAW Melters are located in the LAW Melter Gallery (L-0112) within the LAW Vitrification  
27 Facility. The HLW Melters are located in the HLW Melter caves (H-0117, H-0106) within the HLW  
28 Vitrification Facility. Both plants are designed to comply with standards that ensure protection of the  
29 surface and subsurface environments. The vitrification plants are completely enclosed and are designed  
30 to have sufficient structural strength and corrosion protection to prevent collapse or other structural  
31 failure. In addition, the melter systems, melter feed systems, and related piping are provided with  
32 secondary containment, to minimize the potential for release. The LAW Melter Gallery (L-0112) and the  
33 HLW Melter caves (H-0117, H-0106) will be permitted as containment buildings and are described in  
34 Chapter 4E and Chapter 4F, respectively.

1 Floors within the vitrification plants are protected in a manner consistent with the intended usage of the  
2 space. The floor and portions of the walls of HLW Melter cave are partially lined with stainless steel.  
3 Nonradioactive materials usage areas requiring heavy equipment have concrete floors with hardener and  
4 sealer finishes.

5 The *Hanford Facility Dangerous Waste Permit Application General Information Portion*, Section 5.4  
6 (DOE-RL 1998), provides climatological data, topography, hydrogeological and geological  
7 characteristics, groundwater flow quantity and direction, groundwater quality data, and surface water  
8 quantity and quality data for the area around the WTP.

#### 9 **4.3.7.2 Protection of the Atmosphere [WAC 173-303-680(2)(c)]**

10 A risk assessment is performed to evaluate the impacts of the WTP emissions on human and ecological  
11 receptors. Actual offgas emissions is measured during an environmental performance demonstration that  
12 is performed as part of the WTP commissioning activities. The data is used during a screening-level risk  
13 assessment that is performed to determine ecological and human health risk. The emissions data and the  
14 results of the screening level risk assessment are used to establish operating conditions for the melters that  
15 do not endanger human health and the environment.

#### 16 **4.3.8 Treatment Effectiveness Report [WAC 173-303-806(4)(i)(iv)]**

17 A treatment effectiveness report evaluating the performance of the miscellaneous treatment sub-systems,  
18 and their effectiveness in treating the LAW and HLW, will be located in DWP Operating Unit Group 10,  
19 [Appendix 9 for LAW and Appendix 10 for HLW](#). The report uses the results of the environmental  
20 performance demonstration and the risk assessment activities to document treatment effectiveness of  
21 miscellaneous treatment sub-systems.

#### 22 **4.3.9 Approach to Risk Assessment [WAC 173-303-680(2)(c)(i) through (vii)]**

23 A screening level risk assessment is being conducted to evaluate any possible human health and  
24 ecological risk posed by the thermal treatment of mixed wastes. The risk assessment provides  
25 information about the potential terrestrial, aquatic, and food pathways for exposure of human and  
26 ecological receptors to dangerous waste constituents. This risk assessment presents the quantitative  
27 methods, detailed assumptions, and numerical parameters that are used to estimate the nature, extent, and  
28 magnitude of potential risks from operation of the WTP. The primary regulatory guidance followed for  
29 this risk assessment is found in the *Human Health Risk Assessment Protocol for Hazardous Waste  
30 Combustion Facilities* (EPA 1998a) and the *Screening-Level Ecological Risk Assessment Protocol for  
31 Hazardous Waste Combustion Facilities* (EPA 1999a)

32 Treated air emissions through the stack are the only planned direct releases into the environment from the  
33 WTP. Other waste streams are transferred to a permitted facility and are not released directly into the  
34 environment. ~~Thus, the overall risk assessment process focuses primarily on air emissions.~~

35 Major components of the human health and ecological risk assessment process for evaluating airborne  
36 emissions are as follows:

- 37 • Risk assessment work plan.
- 38 • Pre-demonstration test risk assessment.
- 39 • Final risk assessment.

40 The overall approach for the risk assessment is to identify potential risks associated with various  
41 receptors, their locations, exposure pathways, and activity patterns in two broad exposure scenarios, as  
42 follows:

- 43 • Plausible exposure scenario.
- 44 • Worst-case exposure scenario.

1 The plausible exposure scenarios are based on where potential receptors currently exist or may reasonably  
2 be expected to exist within the foreseeable future. The worst-case assumptions are based on locations of  
3 maximum concentration even though it is not expected that such receptors will ever actually exist at these  
4 locations. Both scenarios ~~will~~ reflect current uses of the surrounding land and habitat and reasonable  
5 assumptions about future uses of the land and habitat.

6 During the environmental performance demonstration, emission samples are collected and analyzed, and  
7 the data used to evaluate risk to the human population and ecological (such as wildlife) receptors.  
8 Operating conditions are established for the WTP, which limit risks to human health and the environment  
9 to acceptable levels.

#### 10 **4.4 Other Waste Management Units**

11 Sections 4.4.1 through 4.4.5 discuss the applicability of the requirements for waste management units that  
12 have not been discussed up to this point in the permit. Sections 4.4.6 through 4.4.9 describe the  
13 applicability of air emission controls, waste minimization, groundwater monitoring, and functional design  
14 requirements to the WTP. References to other sections of the permit are provided as appropriate.

##### 15 **4.4.1 Waste Piles**

16 The operation of the WTP does not involve the placement of dangerous waste in waste piles. Therefore,  
17 the requirements of WAC 173-303-660, *Waste piles*, do not apply to the WTP.

##### 18 **4.4.2 Surface Impoundments**

19 The operation of the WTP does not involve the placement of dangerous waste in surface impoundments.  
20 Therefore, the requirements of WAC 173-303-650, *Surface impoundments*, do not apply to the WTP.

##### 21 **4.4.3 Incinerators**

22 The WTP does not include a dangerous waste incinerator. However, applicable sections of the incinerator  
23 requirements in WAC 173-303-670, and 40 CFR Section 63.1203 apply to the WTP.

##### 24 **4.4.4 Landfills**

25 The operation of the WTP does not involve the placement of dangerous waste in landfills. Therefore, the  
26 requirements of WAC 173-303-665, *Landfills*, do not apply to the WTP.

##### 27 **4.4.5 Land Treatment**

28 The operation of the WTP does not involve the land treatment of dangerous waste. Therefore, the  
29 requirements of WAC 173-303-655, *Land Treatment*, do not apply to the WTP.

##### 30 **4.4.6 Air Emissions Control**

31 Information regarding air emissions control is provided in the following sections:

- 32 • PTF Vessel Vent Process and Exhaust System (PVP/PVV) - Chapter 4D, Section 4D.4.2.
- 33 • LAW Vitrification Facility offgas treatment system description - Chapter 4E, Section 4E.4.2.
- 34 • HLW Vitrification Facility offgas treatment system description - Chapter 4F, Section 4.2.
- 35 • DFLAW EMF Vessel Vent Process System (DVP) - Chapter 4G, Section 5.1.
- 36 • Process vents (40 CFR 264 Subpart AA) - Section 4.2.~~910~~.2.
- 37 • Equipment leaks (40 CFR 264 Subpart BB) - Section 4.2.~~910~~.3.
- 38 •   Tanks and containers (40 CFR 264 Subpart CC) - Section 4.2.~~910~~.4.

### C1 Ventilation (C1V) System

C1 areas are normally occupied and are expected to remain free of contamination. C1 areas will be operated slightly pressurized relative to atmosphere and other adjacent areas. The C1V system consists of air handling units, change rooms exhaust fan, ductwork, and accessories. Areas served by this system include:

- Office spaces.
- Control Room.
- Incident Command Post (ICP) (During DFLAW operations).
- Lunch Room.
- Restrooms.
- Change Rooms.
- Truck Bays.
- LAW Switchgear Building.

### C2 Ventilation (C2V) System

C2 areas will typically consist of non-process operating areas, equipment rooms, stores, access corridors, and plant rooms adjacent to areas with higher contamination potential. The C2V is served by dedicated air handling units and exhaust fans. Ventilation air supplied to C2 areas will be exhausted by the C2 exhaust system and cascaded into adjacent C3 areas. The C2 areas will maintain a nominal negative pressure relative to atmosphere. C2 exhaust will pass through one stage of HEPA filters and be discharged to the atmosphere by the exhaust fans. Supply and exhaust fans are provided with variable frequency drives.

### C3 Ventilation (C3V) System

C3 areas are normally unoccupied, but allow operator access, for instance during maintenance. C3 areas will typically consist of filter plant rooms, workshops, maintenance areas, and monitoring areas. Air will generally be drawn from C2 areas and, wherever possible, cascaded through the C3 areas into C5 areas, or alternatively exhausted from the C3 areas by the C3 exhaust system. In general, air cascaded into the C3 areas will be from adjacent C2/C3 subchange rooms. C3 exhaust will pass through one stage of HEPA filters and be discharged to the atmosphere by the exhaust fans. C3 exhaust fans are provided with variable frequency drives.

### C5 Ventilation (C5V) System

Where there is in-bleed air from the C3 system to the C5 system, fan cascade trip interlocks protect the system from backflow. Air will be cascaded into the C5 areas and exhausted by the C5 exhaust system. The C5 exhaust will pass through two stages of HEPA filters and be discharged to the atmosphere by the exhaust fans. C5 exhaust fans are provided with variable frequency drives.

The C5 areas in the LAW Vitrification Facility will be composed of the following:

- Pour caves.
- Container transfer tunnel.
- Buffer storage area.
- C3/C5 drains/sump collection vessel room.
- Process cells.
- Finishing line.

1 Containment will be achieved by maintaining C5 areas at the greatest negative pressure, with airflows  
2 cascaded through engineered routes from C2 areas to C3 areas and on to the C5 areas. The cascade  
3 system, in which air passes through more than one area, will reduce the number of separate ventilation  
4 streams and hence the amount of air requiring treatment. Adherence to this concept in the design and  
5 operation of the LAW Vitrification Facility will ensure that the ventilation air does not become a  
6 significant source of exposure to operators, and that the air emissions do not endanger human health or  
7 the environment.

8 Ventilation system duct work is not required to be doubly contained within the WTP Unit. However,  
9 upon discovery of accumulation of liquids within the duct work, a compliance plan will be submitted  
10 within sixty (60) days of discovery to correct the problems.

#### 11 **4.4.7 Waste Minimization**

12 Waste minimization information is presented in Operating Unit Group 10 of the permit.

#### 13 **4.4.8 Groundwater Monitoring for Land-Based Units**

14 The groundwater monitoring requirements found in WAC 173-303-645, *Releases from Regulated Units*,  
15 do not apply to the WTP, since it is not operated as a regulated dangerous waste surface impoundment,  
16 landfill, land treatment area or waste pile, as defined in WAC 173-303-040. Therefore, groundwater  
17 monitoring is not required.

#### 18 **4.4.9 Functional Design Requirements**

19 The WTP ~~is~~will be designed to comply with applicable design codes and specifications. The documents  
20 referenced in this chapter appendices and contained in DWP Operating Unit Group 10 identify the codes  
21 and standards to which the WTP system, structures, and components are being constructed.

1  
2  
3  
4  
5

This page intentionally left blank.

DRAFT