

Issuance Date: October 14, 2019  
Effective Date: November 1, 2019  
Expiration Date: October 31, 2024  
Modification Date: April 22, 2020

**National Pollutant Discharge Elimination System  
Waste Discharge Permit No. WA0991024**

State of Washington  
DEPARTMENT OF ECOLOGY  
Industrial Section  
PO Box 47600  
Olympia, WA 98504-7600

In compliance with the provisions of  
The State of Washington Water Pollution Control Law  
Chapter 90.48 Revised Code of Washington  
and  
The Federal Water Pollution Control Act  
(The Clean Water Act)  
Title 33 United States Code, Section 1342 et seq.

Solvay Chemicals, Inc.  
3500 Industrial Way  
Longview, Washington 98632

is authorized to discharge in accordance with the Special and General Conditions that follow.

Facility Location: 3500 Industrial Way Longview, Washington 98632	Industry Type: Hydrogen Peroxide Manufacturing
Significant Industrial User POTW/Privatey Owned Treatment Works	SIC Code: 2819 – Industrial Inorganic Chemicals, Not Elsewhere Classified
Receiving Discharge: Three Rivers Regional Wastewater Authority (TRRWA) Wastewater Treatment Plant	NAICS Code: 325180 – Other Basic Inorganic Chemical Manufacturing
Nippon Dynawave Packaging Company, LLC	Receiving Water: Consolidated Diking Improvement District #1, Ditch #5
Treatment Type: Settling, oil-water separator, pH Adjustment	



---

James DeMay, P.E.  
Industrial Section Manager  
Washington State Department of Ecology

## Table of Contents

<b>Summary of Permit Report Submittals .....</b>	<b>4</b>
<b>Special Conditions .....</b>	<b>6</b>
<b>S1. Discharge Limits .....</b>	<b>6</b>
S1.A. Discharges to Three Rivers Regional Wastewater Authority (TRRWA) Wastewater Treatment Plant 6	
S1.B. Process Wastewater Discharges to Nippon Dynawave Packaging Company, LLC's (Nippon Dynawave) Industrial Wastewater Treatment Plant .....	6
S1.C. Sanitary Wastewater Discharge to Nippon Dynawave's Sanitary Wastewater Treatment Plant 6	
S1.D. Cooling Tower Blowdown, Reverse Osmosis (RO) Reject Water, and Filter Backwash Discharges to Consolidated Diking Improvement District #1 (CDID) Ditch #5 .....	6
<b>S2. Monitoring Requirements.....</b>	<b>9</b>
S2.A. Monitoring Schedule .....	9
S2.B. Sampling and Analytical Procedures.....	12
S2.C. Flow Measurement, Field Measurement, and Continuous Monitoring Devices .....	12
S2.D. Laboratory Accreditation.....	13
S2.E. Request for Reduction in Monitoring.....	13
<b>S3. Reporting and Recording Requirements.....</b>	<b>14</b>
S3.A. Discharge Monitoring Reports .....	14
S3.B. Permit Submittals and Schedules .....	15
S3.C. Records Retention .....	16
S3.D. Recording of Results .....	16
S3.E. Additional Monitoring by the Permittee.....	16
S3.F. Reporting Permit Violations.....	16
S3.G. Other Reporting.....	18
S3.H. Maintaining a Copy of this Permit .....	18
S3.I. Dangerous Waste Discharge Notification .....	18
S3.J. Spill Notification .....	18
S3.K. Changes in Contract .....	19
<b>S4. Operation and Maintenance .....</b>	<b>19</b>
S4.A. Operations and Maintenance (O&M) Manual.....	19
S4.B. Bypass Procedures.....	20
<b>S5. Solid Wastes .....</b>	<b>22</b>
S5.A. Solid Waste Handling.....	22
S5.B. Leachate.....	22
S5.C. Solid Waste Control Plan .....	22
<b>S6. Prohibited Discharges .....</b>	<b>22</b>
S6.A. General Prohibitions.....	22
S6.B. Specific Prohibitions .....	22
S6.C. Prohibited Unless Approved.....	23
<b>S7. Dilution Prohibited .....</b>	<b>23</b>
<b>S8. Application for Permit Renewal or Modification for Facility Changes .....</b>	<b>24</b>
<b>S9. Non-Routine and Unanticipated Wastewater .....</b>	<b>24</b>

<b>S10. Spill Control Plan .....</b>	<b>25</b>
S10.A. Spill Control Plan Submittals and Requirements .....	25
S10.B. Spill Control Plan Components .....	25
<b>S11. Slug Discharge Control Plan.....</b>	<b>25</b>
S11.A.Slug Discharge Control Plan Submittal and Requirements.....	25
S11.B.Slug Discharge Control Plan Components .....	26
<b>S12. Receiving Water Study .....</b>	<b>26</b>
<b>S13. Dangerous Wastes – Permit by Rule Requirements.....</b>	<b>27</b>
<b>S14. Stormwater Management Plan (SWMP).....</b>	<b>28</b>
<b>S.15 Compliance Schedule.....</b>	<b>29</b>
<b><i>General Conditions .....</i></b>	<b><i>31</i></b>
<b>G1. Signatory Requirements.....</b>	<b>31</b>
<b>G2. Right of Inspection and Entry .....</b>	<b>32</b>
<b>G3. Permit Actions.....</b>	<b>32</b>
<b>G4. Reporting Planned Changes .....</b>	<b>33</b>
<b>G5. Plan Review Required .....</b>	<b>33</b>
<b>G6. Compliance with Other Laws and Statutes.....</b>	<b>34</b>
<b>G7. Transfer of This Permit.....</b>	<b>34</b>
<b>G8. Reduced Production for Compliance.....</b>	<b>34</b>
<b>G9. Removed Substances .....</b>	<b>34</b>
<b>G10. Duty to Provide Information .....</b>	<b>35</b>
<b>G11. Other Requirements of 40 CFR.....</b>	<b>35</b>
<b>G12. Additional Monitoring.....</b>	<b>35</b>
<b>G13. Payment of Fees .....</b>	<b>35</b>
<b>G14. Penalties for Violating Permit Conditions.....</b>	<b>35</b>
<b>G15. Upset.....</b>	<b>35</b>
<b>G16. Property Rights .....</b>	<b>36</b>
<b>G17. Duty to Comply .....</b>	<b>36</b>
<b>G18. Toxic Pollutants .....</b>	<b>36</b>
<b>G19. Penalties for Tampering.....</b>	<b>36</b>
<b>G20. Reporting Requirements Applicable to Existing Manufacturing, Commercial, Mining, and Silvicultural Dischargers .....</b>	<b>36</b>
<b>G21. Compliance Schedules .....</b>	<b>37</b>
<b><i>Appendix A.....</i></b>	<b><i>38</i></b>

## Summary of Permit Report Submittals

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit Section	Submittal	Frequency	First Submittal Date
S1.D	Outfall 002 Diversion Summary Report	As necessary	
S3.A	Discharge Monitoring Report (DMR)	Monthly	December 15, 2019
S3.A	DMR – Priority Pollutant Metals – Single Sample Data, Outfall 002	Biannual	January 15, 2021
S3.A	DMR - Priority Pollutant Data - Single Sample Data, Process Wastewater	1/permit cycle	January 15, 2023
S3.A	DMR - Priority Pollutant Data - Single Sample Data, Outfall 002	1/permit cycle	January 15, 2021
S3.F	Reporting Permit Violations	As necessary	
S4.A	Operations and Maintenance Manual	1/permit cycle	November 1, 2020
S4.A	Operations and Maintenance Manual Update or Review Confirmation Letter	Annually	November 1, 2021
S4.B	Reporting Bypasses	As necessary	
S5.C	Solid Waste Control Plan	1/permit cycle	November 1, 2021
S5.C	Modification to Solid Waste Plan	As necessary	
S5.C	Solid Waste Control Plan Update	1/permit cycle	November 1, 2023
S8	Application for Permit Renewal	1/permit cycle	November 1, 2023
S9	Non-Routine and Unanticipated Discharges	As necessary	
S10	Spill Control Plan	1/permit cycle, updates submitted as necessary	November 1, 2020
S11	Slug Discharge Control Plan	1/permit cycle, updates submitted as necessary	November 1, 2020
S11	Slug Discharge Control Plan Update or Certification	1/permit cycle	November 1, 2023
S12	Receiving Water and Effluent Study Sampling and Quality Assurance Plan	1/permit cycle	November 1, 2020
S12	Receiving Water and Effluent Study Results	1/permit cycle	1 year after Receiving Water and Effluent Study Sampling and Quality Assurance Plan approval
S14	Stormwater Management Plan	1/permit cycle	November 1, 2020
S14	Corrective Action Report – Stormwater Discharge from Process Areas	As necessary	
G1	Notice of Change in Authorization	As necessary	

<b>Permit Section</b>	<b>Submittal</b>	<b>Frequency</b>	<b>First Submittal Date</b>
G4	Permit Application for Substantive Changes to the Discharge	As necessary	
G5	Engineering Report for Construction or Modification Activities	As necessary	
G7	Notice of Permit Transfer	As necessary	
G10	Duty to Provide Information	As necessary	
G21	Compliance Schedules	As necessary	

## Special Conditions

### S1. Discharge Limits

All discharges and activities authorized by this permit must be consistent with the terms and conditions of this permit.

The discharge of any of the following pollutants more frequently than, or at a level in excess of that identified and authorized by this permit violates the terms and conditions of this permit.

#### S1.A. Discharges to Three Rivers Regional Wastewater Authority (TRRWA) Wastewater Treatment Plant

Beginning on the effective date, the Permittee is authorized to discharge process wastewater and sanitary wastewater to the City of Longview sewer system and the TRRWA Wastewater Treatment Plant subject to the following limits:

**Effluent Limits: Outfall 001A**  
**Latitude 46.139482 – Longitude 122.981193**

Parameter	Daily Minimum	Daily Maximum
Flow Rate	Not applicable	353,190 gallons per day
pH	6.0 standard units	9.0 standard units

#### S1.B. Process Wastewater Discharges to Nippon Dynawave Packaging Company, LLC's (Nippon Dynawave) Industrial Wastewater Treatment Plant

Beginning on the effective date, the Permittee is authorized to discharge process wastewater to the Nippon Dynawave Industrial Treatment Plant subject to the following limits:

**Effluent Limits: Outfall 001B**  
**Latitude 46.135739 – Longitude 122.982717**

Parameter	Daily Minimum	Daily Maximum
pH	4.0 standard units	12.2 standard units

#### S1.C. Sanitary Wastewater Discharge to Nippon Dynawave's Sanitary Wastewater Treatment Plant

Beginning on the effective date, the Permittee is authorized to discharge sanitary wastewater to the Nippon Dynawave sanitary wastewater treatment plant.

There are no effluent limits for this discharge.

#### S1.D. Cooling Tower Blowdown, Reverse Osmosis (RO) Reject Water, and Filter Backwash Discharges to Consolidated Diking Improvement District #1 (CDID) Ditch #5

Beginning on the effective date of this permit, the Permittee is authorized to discharge cooling tower blowdown, RO reject water, and filter backwash to the CDID Ditch #5 at the permitted location, subject to the following conditions:

The following interim effluent limits apply to the discharge beginning on the effective date of this permit and lasting until November 1, 2021:

**Interim Effluent Limits: Outfall 002  
 Latitude 46.1354 – Longitude 122.983**

Parameter	Average Monthly <sup>a</sup>	Maximum Daily <sup>b</sup>
Chlorine, Total Residual	0.2 milligrams per liter (mg/L)	0.5 milligrams per liter (mg/L)
Chloride	518 mg/L	756 mg/L
Ammonia	4.6 mg/L	6.8 mg/L
Total Suspended Solids (TSS)	30 mg/L	45 mg/L

Footnotes:

- a. Average monthly effluent limit means the highest allowable average of daily discharges over a calendar month. To calculate the discharge value to compare to the limit, you add the value of each daily discharge measured during a calendar month and divide this sum by the total number of daily discharges measured.
- b. Maximum daily effluent limit is the highest allowable daily discharge. The daily discharge is the average discharge of a pollutant measured during a calendar day. For pollutants with limits expressed in units of mass, calculate the daily discharge as the total mass of the pollutant discharged over the day. The average daily measurement does not apply to pH or temperature.

Parameter	Minimum	Maximum
pH	6.0 standard units	9.0 standard units

The following final effluent limits apply to the discharge beginning on November 1, 2021:

**Final Effluent Limits: Outfall 002  
 Latitude 46.1354 – Longitude 122.983**

Parameter	Average Monthly <sup>a</sup>	Maximum Daily <sup>b</sup>
Chlorine, Total Residual	12.4 micrograms per liter (µg/L)	18.1 micrograms per liter (µg/L)
Chloride	259 milligrams per liter (mg/L)	378 milligrams per liter (mg/L)

Parameter	Average Monthly <sup>a</sup>	Maximum Daily <sup>b</sup>
Ammonia	2.3 mg/L	3.4 mg/L
Total Suspended Solids (TSS)	30 mg/L	45 mg/L

Footnotes:

- a. Average monthly effluent limit means the highest allowable average of daily discharges over a calendar month. To calculate the discharge value to compare to the limit, you add the value of each daily discharge measured during a calendar month and divide this sum by the total number of daily discharges measured.
- b. Maximum daily effluent limit is the highest allowable daily discharge. The daily discharge is the average discharge of a pollutant measured during a calendar day. For pollutants with limits expressed in units of mass, calculate the daily discharge as the total mass of the pollutant discharged over the day. The average daily measurement does not apply to pH or temperature.

Parameter	Minimum	Maximum
pH	6.0 standard units	9.0 standard units

**a. Diversion to TRRWA Wastewater Treatment Plant via Outfall 001A**

The Permittee is authorized to discharge cooling tower blowdown, RO reject water, and filter backwash water to TRRWA Wastewater Treatment Plant via Outfall 001A during maintenance activities or if upset conditions are identified in the named streams that may result in a violation of the permitted limits for Outfall 002 or cause a violation of the water quality standards in CDID Ditch #5. The Permittee must comply with the following requirements before diverting the named streams to Outfall 001A:

1. The limits and monitoring requirements for Outfall 001A must continue to be complied with during all times of diversion.
2. The Permittee must include a diversion summary report with the Discharge Monitoring Report (DMR) for each month that diversions occur. The diversion summary report must include the following, at a minimum:
  - i. Total duration of diversions during the month, including the dates that diversions occurred.
  - ii. Results for all samples collected during a diversion discharge which are not required under Special Condition S2.A. for Outfall 001A.

Ecology approval with respect to the requirements of Special Condition S6.C. will not be required for such a diversion if the Permittee complies with the requirements of this section.



## S2. Monitoring Requirements

### S2.A. Monitoring Schedule

The Permittee must monitor in accordance with the following schedule and the requirements specified in **Appendix A**.

#### Process Wastewater Discharges (Outfalls 001A & 001B)

Parameter	Units	Minimum Sampling Frequency	Sample Type
Flow	gallons per day (gpd)	Continuous <sup>a</sup>	Metered/recorded Report Daily Maximum and Monthly Average
pH <sup>b</sup>	standard units	Continuous <sup>a</sup>	Metered/recorded Report Instantaneous Maximum and Minimum Daily

Footnotes:

- a. Continuous means uninterrupted except for brief lengths of time for calibration, power failure, or unanticipated equipment repair or maintenance. The time interval for the associated data logger must be no greater than 30 minutes. The Permittee must sample daily when continuous monitoring is not possible.
- b. The Permittee must report the instantaneous maximum and minimum pH monthly. Do not average pH values.

#### Effluent Characterization – Process Wastewater Effluent (Outfalls 001A or 001B)

See Appendix A to identify the specific pollutants in the priority pollutants groups listed below

Parameter	Units	Minimum Sampling Frequency	Sample Type
Cyanide	micrograms per Liter (µg/L)	1/Permit Cycle	Grab <sup>a</sup>
Total Phenolic Compounds	µg/L	1/Permit Cycle	Grab <sup>a</sup>
Priority Pollutants (PP) – Total Metals	µg/L; nanograms per liter (ng/L) for mercury	1/Permit Cycle	24-Hour composite <sup>b</sup> Grab <sup>a</sup> for mercury
PP – Volatile Organic Compounds	µg/L	1/Permit Cycle	Grab <sup>a</sup>
PP – Acid-extractable Compounds	µg/L	1/Permit Cycle	24-Hour composite <sup>b</sup>

Parameter	Units	Minimum Sampling Frequency	Sample Type
PP – Base-neutral Compounds	µg/L	1/Permit Cycle	24-Hour composite <sup>b</sup>
PP – Pesticides/PCBs <sup>c</sup>	µg/L	1/Permit Cycle	24-Hour composite <sup>b</sup>

Footnotes:

- a. Grab means an individual sample collected over a fifteen (15) minute, or less, period.
- b. 24-hour composite means a series of individual samples collected over a 24-hour period into a single container, and analyzed as one sample.
- c. Sampling for Priority Pollutants (PP) – Pesticides/PCBs is not required if the Permittee confirms that pesticides have not been used at the facility during the permit term.

**Effluent Characterization – Cooling Tower Blowdown, RO Reject Water, & Filter Backwash (Outfall 002)**

Parameter	Unit	Minimum Sampling Frequency	Sample Type
Flow	gpd	Continuous <sup>a</sup>	Metered/recorded Report Daily and Maximum and Monthly Average
pH <sup>b</sup>	standard units	Continuous <sup>a</sup>	Metered/recorded Report Instantaneous Maximum and Minimum Daily
Iron	milligrams per liter (mg/L)	Monthly <sup>c</sup>	24-Hour composite <sup>d</sup>
Chloride	mg/L	Weekly	24-Hour composite <sup>d</sup>
Ammonia	mg/L	Weekly	24-Hour composite <sup>d</sup>
Temperature <sup>e</sup>	degrees Fahrenheit (°F)	Continuous <sup>a</sup>	Metered/recorded Report Daily and Maximum and Monthly Average
Total Residual Chlorine	mg/L	Weekly	Grab <sup>f</sup>
Turbidity	Nephelometric Turbidity Units (NTU)	Weekly	Grab <sup>f</sup>
Total Suspended Solids (TSS)	mg/L	Weekly	Grab <sup>f</sup>

Footnotes:

- a. Continuous means uninterrupted except for brief lengths of time for calibration, power failure, or unanticipated equipment repair or maintenance. The time interval for the associated data logger must be no greater than 30 minutes. The Permittee must sample daily when continuous monitoring is not possible.
- b. The Permittee must report the instantaneous maximum and minimum pH monthly. Do not average pH values.
- c. Monthly means one every calendar month.
- d. 24-hour composite means a series of individual samples collected over a 24-hour period into a single container, and analyzed as one sample.
- e. The Permittee must determine and report a daily maximum temperature from half-hour measurements in a 24-hour period. Continuous monitoring instruments must achieve an accuracy of 0.4 degrees F and the Permittee must verify accuracy annually.
- f. Grab means an individual sample collected over a fifteen (15) minute, or less, period.

**Effluent Characterization – Cooling Tower Blowdown & RO Reject Water (Outfall 002)**

See Appendix A to identify the specific pollutants in the priority pollutant groups listed below

Parameter	Units	Minimum Sampling Frequency	Sample Type
Cyanide	µg/L	Once in the first year	Grab <sup>a</sup>
Total Phenolic Compounds	µg/L	Once in the first year	Grab <sup>a</sup>
Priority Pollutants (PP) – Total Metals	µg/L; ng/L for mercury	Biannual, fist analysis completed in the first year <sup>b</sup>	24-Hour composite <sup>c</sup> Grab <sup>a</sup> for mercury
PP – Volatile Organic Compounds	µg/L	Once in the first year	Grab <sup>a</sup>
PP – Acid-extractable Compounds	µg/L	Once in the first year	24-Hour composite <sup>c</sup>
PP – Base-neutral Compounds	µg/L	Once in the first year	24-Hour composite <sup>c</sup>
PP – Dioxin	pg/L	Once in the first year	24-Hour composite <sup>c</sup>
PP – Pesticides/PCBs	µg/L	Once in the first year	24-Hour composite <sup>c</sup>

Footnotes:

- a. Grab means an individual sample collected over a fifteen (15) minute, or less, period.
- b. Biannual means once every two years. The Permittee must collect the first sample within one year of the permit effective date.
- c. 24-hour composite means a series of individual samples collected over a 24-hour period into a single container, and analyzed as one sample.

**Receiving Water Study – CDID Ditch #5 (as specified in Special Condition S12)**

Parameter	Units	Minimum Sampling Frequency	Sample Type
Dissolved Oxygen (DO)	milligrams per liter (mg/L)	10/permit cycle	Grab <sup>a</sup>
Turbidity	Nephelometric Turbidity Units (NTU)	10/permit cycle	Grab <sup>a</sup>
TSS	mg/L	10/permit cycle	Grab <sup>a</sup>
Temperature	Degrees Fahrenheit (°F)	10/permit cycle	Grab <sup>a</sup>
pH	standard units	10/permit cycle	Grab <sup>a</sup>
Iron	mg/L	10/permit cycle	Grab <sup>a</sup>
Chloride	mg/L	10/permit cycle	Grab <sup>a</sup>
Ammonia	mg/L	10/permit cycle	Grab <sup>a</sup>
Hardness	mg/L	10/permit cycle	Grab <sup>a</sup>
Conductivity	mg/L	10/permit cycle	Grab <sup>a</sup>

Footnote:

- a. Grab means an individual sample collected over a fifteen (15) minute, or less, period.

**S2.B. Sampling and Analytical Procedures**

Samples and measurements taken to meet the requirements of this permit must represent the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets, and maintenance-related conditions affecting effluent quality.

Sampling and analytical methods used to meet the monitoring requirements specified in this permit must conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136 (or as applicable in 40 CFR subchapters N [Parts 400–471] or O [Parts 501-503]) unless otherwise specified in this permit. Ecology may only specify alternative methods for parameters without limits and for those parameters without an EPA approved test method in 40 CFR Part 136.

**S2.C. Flow Measurement, Field Measurement, and Continuous Monitoring Devices**

The Permittee must:

1. Select and use appropriate flow measurement, field measurement, and continuous monitoring devices and methods consistent with accepted scientific practices.

2. Install, calibrate, and maintain these devices to ensure the accuracy of the measurements is consistent with the accepted industry standard, the manufacturer's recommendation, and approved O&M manual procedures for the device and the wastestream.
3. Calibrate continuous monitoring instruments weekly unless it can demonstrate a longer period is sufficient based on monitoring records. The Permittee:
  - a. May calibrate apparatus for continuous monitoring of dissolved oxygen by air calibration.
  - b. Must calibrate continuous pH measurement instruments using a grab sample analyzed in the lab with a pH meter calibrated with standard buffers and analyzed within 15 minutes of sampling.
  - c. Must calibrate continuous chlorine measurement instruments using a grab sample analyzed in the laboratory within 15 minutes of sampling.
4. Calibrate micro-recording temperature devices, known as thermistors, using protocols from Ecology's Quality Assurance Project Plan Development Tool (*Standard Operating Procedures for Continuous Temperature Monitoring of Fresh Water Rivers and Streams Version 1.0 10/26/2011*). This document is available online at:  
<https://fortress.wa.gov/ecy/publications/documents/1803205.pdf>  
Calibration as specified in this document is not required if the Permittee uses recording devices certified by the manufacturer.
5. Use field measurement devices as directed by the manufacturer and do not use reagents beyond their expiration dates.
6. Establish a calibration frequency for each device or instrument in the O&M manual that conforms to the frequency recommended by the manufacturer.
7. Calibrate flow-monitoring devices at a minimum frequency of at least one calibration per year.
8. Maintain calibration records for at least three years.

#### **S2.D. Laboratory Accreditation**

The Permittee must ensure that all monitoring data required by Ecology for permit specified parameters is prepared by a laboratory registered or accredited under the provisions of chapter 173-50 WAC, *Accreditation of Environmental Laboratories*. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement. The Permittee must obtain accreditation for pH if it must receive accreditation or registration for other parameters.

#### **S2.E. Request for Reduction in Monitoring**

The Permittee may request a reduction of the sampling frequency after twelve (12) months of monitoring. Ecology will review each request and at its discretion grant the request when it reissues the permit or by a permit modification.

The Permittee must:

1. Provide a written request.
2. Clearly state the parameters for which it is requesting reduced monitoring.
3. Clearly state the justification for the reduction.

### **S3. Reporting and Recording Requirements**

The Permittee must monitor and report in accordance with the following conditions.

Falsification of information submitted to Ecology is a violation of the terms and conditions of this permit.

#### **S3.A. Discharge Monitoring Reports**

The first monitoring period begins on the effective date of the permit (unless otherwise specified). The Permittee must:

1. Summarize, report, and submit monitoring data obtained during each monitoring period on the electronic discharge monitoring report (DMR) form provided by Ecology within the Water Quality Permitting Portal. Include data for each of the parameters tabulated in Special Condition S2 and as required by the form. Report a value for each day sampling occurred (unless specifically exempted in the permit) and for the summary values (when applicable) included on the electronic form.

To find out more information and to sign up for the Water Quality Permitting Portal go to: <http://ecyapwq/wqwebportal/>

2. Ensure that DMRs are electronically submitted no later than the dates specified below, unless otherwise specified in this permit.
3. Submit DMRs for parameters with the monitoring frequencies specified in S2 (monthly, quarterly, annual, etc.) at the reporting schedule identified below. The Permittee must:
  - a. Submit **monthly** DMRs by the 15<sup>th</sup> day of the following month.
  - b. Submit **biannual** DMRs by January 15 every 2 years. The first biannual DMR must be submitted by January 15, 2021.
  - c. Submit Outfall 002 effluent characterization monitoring data in WQWebDMR as required in Special Condition S2 by January 15, 2021.
  - d. Submit permit renewal application monitoring data (effluent characterization) in WQWebDMR as required in Special Condition S2 by January 15, 2023.
4. Enter the “No Discharge” reporting code for an entire DMR, for a specific monitoring point, or for a specific parameter as appropriate, if the Permittee did not discharge wastewater or a specific pollutant during a given monitoring period.

5. Report single analytical values below detection as “less than the detection level (DL)” by entering < followed by the numeric value of the detection level (e.g. < 2.0) on the DMR. If the method used did not meet the minimum DL and quantitation level (QL) identified in the permit, report the actual QL and DL in the comments or in the location provided.
6. Report single analytical values between the detection level (DL) and the quantitation level (QL) by entering the estimated value, the code for estimated value/below quantitation limit (j) and any additional information in the comments. Submit a copy of the laboratory report as an attachment using WQWebDMR.
7. Report the test method used for analysis in the comments if the laboratory used an alternative method not specified in the permit and as allowed in Appendix A.
8. Calculate average values and calculated total values (unless otherwise specified in the permit) using:
  - a. The reported numeric value for all parameters measured between the detection value and the quantitation value for the sample analysis.
  - b. One-half the detection value (for values reported below detection) if the lab detected the parameter in another sample from the same monitoring point for the reporting period.
  - c. Zero (for values reported below detection) if the lab did not detect the parameter in another sample for the reporting period.
9. Report single-sample grouped parameters (for example: priority pollutants, PAHs, pulp and paper chlorophenolics, TTOs) on the WQWebDMR form and include: sample date, concentration detected, detection limit (DL) (as necessary), and laboratory quantitation level (QL) (as necessary).

The Permittee must also submit an electronic copy of the laboratory report as an attachment using WQWebDMR. The contract laboratory reports must also include information on the chain of custody, QA/QC results, and documentation of accreditation for the parameter.

### **S3.B. Permit Submittals and Schedules**

The Permittee must use the Water Quality Permitting Portal – Permit Submittals application (unless otherwise specified in the permit) to submit all other written permit-required reports by the date specified in the permit.

When another permit condition requires submittal of a paper (hard-copy) report, the Permittee must ensure that it is postmarked or received by Ecology no later than the dates specified by this permit. Send these paper reports to Ecology at:

Water Quality Permit Coordinator  
Department of Ecology  
Industrial Section  
PO Box 47600  
Olympia, WA 98504-7600

### **S3.C. Records Retention**

The Permittee must retain records of all monitoring information for a minimum of three (3) years. Such information must include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit. The Permittee must extend this period of retention during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by Ecology.

### **S3.D. Recording of Results**

For each measurement or sample taken, the Permittee must record the following information:

1. The date, exact place, method, and time of sampling or measurement.
2. The individual who performed the sampling or measurement.
3. The dates the analyses were performed.
4. The individual who performed the analyses.
5. The analytical techniques or methods used.
6. The results of all analyses.

### **S3.E. Additional Monitoring by the Permittee**

If the Permittee monitors any pollutant more frequently than required by Special Condition S2 of this permit, then the Permittee must include the results of such monitoring in the calculation and reporting of the data submitted in the Permittee's DMR unless otherwise specified by Special Condition S2.

### **S3.F. Reporting Permit Violations**

The Permittee must take the following actions when it violates or is unable to comply with any permit condition:

1. Immediately take action to stop, contain, and cleanup unauthorized discharges or otherwise stop the noncompliance and correct the problem.
2. If applicable, immediately repeat sampling and analysis. Submit the results of any repeat sampling to Ecology within thirty (30) days of sampling.

#### **a. Immediate Reporting**

The Permittee must immediately report to the Department of Ecology and the Department of Health, Drinking Water Program (at the numbers listed below), all:

- Collection system overflows discharging to a water body used as a source of drinking water.
- Plant bypasses discharging to a waterbody used as a source of drinking water.



Contact	Phone number
Ecology's Southwest Regional Office	360-407-6300
Department of Health's Drinking Water Program	800-521-0323 (business hours) 877-481-4901 (after business hours)

**b. Twenty-Four-Hour Reporting**

The Permittee must report the following occurrences of noncompliance by telephone, to Ecology's Southwest Regional Office at the telephone number listed above, within 24 hours from the time the Permittee becomes aware of any of the following circumstances:

1. Any noncompliance that may endanger health or the environment, unless previously reported under immediate reporting requirements.
2. Any unanticipated bypass that causes an exceedance of any effluent limit in the permit (See Special Condition S4.B., "Bypass Procedures").
3. Any upset that causes an exceedance of an effluent limit in the permit (See General Condition G.15, "Upset").
4. Any violation of a maximum daily or instantaneous maximum discharge limit for any of the pollutants in Special Condition S1 of this permit.
5. Any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limit in the permit. This requirement does not include industrial process wastewater overflows to impermeable surfaces which are collected and routed to the treatment works.

**c. Report within Five Days**

The Permittee must also submit a written report within five days of the time that the Permittee becomes aware of any reportable event under subparts a or b, above. The report must contain:

1. A description of the noncompliance and its cause.
2. The period of noncompliance, including exact dates and times.
3. The estimated time the Permittee expects the noncompliance to continue if not yet corrected.
4. Steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance.
5. If the noncompliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.

**d. Waiver of Written Reports**

Ecology may waive the written report required in subpart c, above, on a case-by-case basis upon request if the Permittee has submitted a timely oral report.

**e. All Other Permit Violation Reporting**

The Permittee must report all permit violations, which do not require immediate or within 24 hours reporting, when it submits monitoring reports for Special Condition S3.A ("Reporting").

The reports must contain the information listed in subpart c, above. Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

**S3.G. Other Reporting**

**a. Spills of Oil or Hazardous Materials**

The Permittee must report a spill of oil or hazardous materials in accordance with the requirements of RCW 90.56.280 and chapter 173-303-145. You can obtain further instructions at the following website: <https://ecology.wa.gov/About-us/Get-involved/Report-an-environmental-issue/Report-a-spill>.

**b. Failure to Submit Relevant or Correct Facts**

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to Ecology, it must submit such facts or information promptly.

**S3.H. Maintaining a Copy of this Permit**

The Permittee must keep a copy of this permit at the facility and make it available upon request to Ecology inspectors.

**S3.I. Dangerous Waste Discharge Notification**

The Permittee must notify the receiving treatment works, the collection system operator, if applicable, and Ecology in writing of the intent to discharge into the collection system and the receiving treatment works any substance designated as a dangerous waste in accordance with the provisions of WAC 173-303-070.

It must make this notification at least 90 days prior to the date that it proposes to initiate the discharge. The Permittee must not discharge this substance until authorized by Ecology, the receiving collection system, if applicable, and the receiving treatment works. It must also comply with the notification requirements of Special Condition S9 and General Condition G4.

**S3.J. Spill Notification**

The Permittee must notify the receiving treatment works and the collection system operator, if applicable, immediately (as soon as discovered) of all discharges that could cause problems to the collection system or the receiving treatment works, such as process spills and unauthorized discharges (including slug discharges).

The Permittee must notify Ecology and the Consolidated Diking Improvement District #1 (CDID) immediately (as soon as discovered) of unauthorized discharges and process spills which have the potential to reach the CDID Ditch #5.

### **S3.K. Changes in Contract**

The Permittee must notify Ecology immediately of any changes in the user agreement or contract with the City of Longview or the CDID.

## **S4. Operation and Maintenance**

The Permittee must, at all times, properly operate and maintain all facilities or systems of treatment and control (and related appurtenances), including, but not limited to, collection systems, which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes keeping a daily operation logbook (paper or electronic), adequate laboratory controls, and appropriate quality assurance procedures.

This provision of the permit requires the Permittee to operate backup or auxiliary facilities or similar systems only when the operation is necessary to achieve compliance with the conditions of this permit.

The Permittee must schedule any facility maintenance, which might require interruption of wastewater treatment and degrade effluent quality, during non-critical water quality periods and carry this maintenance out according to the approved O&M manual or as otherwise approved by Ecology.

### **S4.A. Operations and Maintenance (O&M) Manual**

#### **a. O&M Manual Submittal and Requirements**

The Permittee must:

1. Prepare an O&M Manual that meets the requirements of WAC 173-240-150 and submit it to Ecology for approval by November 1, 2020.
2. Review the O&M Manual at least annually and confirm this review by letter to Ecology by November 1 of each year.
3. Submit to Ecology for review and approval substantial changes or updates to the O&M Manual.
4. Keep the approved O&M Manual at the permitted facility.
5. Follow the instructions and procedures of this manual.

#### **b. O&M Manual Components**

In addition to the requirements of WAC 173-240-150, the O&M Manual must be consistent with the guidance in Table G1-3 in the *Criteria for Sewage Works Design* (Orange Book) 2008. The O&M Manual must include:

1. Emergency procedures for plant shutdown and cleanup in the event of a wastewater system upset or failure.
2. A review of system components which if failed could pollute surface water or could impact human health. Provide a procedure for a routine schedule of checking the function of these components.

3. Wastewater system maintenance procedures that contribute to the generation of process wastewater.
4. Any directions to maintenance staff when cleaning, or maintaining other equipment or performing other tasks which are necessary to protect the operation of the wastewater system (for example, defining maximum allowable discharge rate for draining a tank, blocking all floor drains before beginning the overhaul of a stationary engine).
5. Wastewater sampling protocols and procedures for compliance with the sampling and reporting requirements in the wastewater discharge permit.
6. Minimum staffing adequate to operate and maintain the treatment processes and carry out compliance monitoring required by the permit.
7. Treatment plant process control monitoring schedule.
8. Processes for monitoring and controlling chemical usage in the reverse osmosis system and cooling tower system.
9. Process for diverting RO reject water, cooling tower blowdown, and filter backwash to Outfall 001A, including procedures for determining the need to divert the named streams.

#### **S4.B. Bypass Procedures**

A bypass is the intentional diversion of waste streams from any portion of a treatment facility. This permit prohibits all bypasses except when the bypass is for essential maintenance, as authorized in Special Condition S4.B.1, or is approved by Ecology as an anticipated bypass following the procedures in Special Condition S4.B.2.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.  
This permit allows bypasses for essential maintenance of the treatment system when necessary to ensure efficient operation of the system. The Permittee may bypass the treatment system for essential maintenance only if doing so does not cause violations of effluent limits. The Permittee is not required to notify Ecology when bypassing for essential maintenance. However the Permittee must comply with the monitoring requirements specified in Special Condition S2.B.
2. Anticipated bypasses for non-essential maintenance  
Ecology may approve an anticipated bypass under the conditions listed below. This permit prohibits any anticipated bypass that is not approved through the following process.
  - a. If a bypass is for non-essential maintenance, the Permittee must notify Ecology, if possible, at least ten (10) days before the planned date of bypass. The notice must contain:
    - A description of the bypass and the reason the bypass is necessary.
    - An analysis of all known alternatives which would eliminate, reduce, or mitigate the potential impacts from the proposed bypass.
    - A cost-effectiveness analysis of alternatives.

- The minimum and maximum duration of bypass under each alternative.
  - A recommendation as to the preferred alternative for conducting the bypass.
  - The projected date of bypass initiation.
  - A statement of compliance with SEPA.
  - A request for modification of water quality standards as provided for in WAC 173-201A-410, if an exceedance of any water quality standard is anticipated.
  - Details of the steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.
- b. For probable construction bypasses, the Permittee must notify Ecology of the need to bypass as early in the planning process as possible. The Permittee must consider the analysis required above during the project planning and design process. The project-specific engineering report as well as the plans and specifications must include details of probable construction bypasses to the extent practical. In cases where the Permittee determines the probable need to bypass early, the Permittee must continue to analyze conditions up to and including the construction period in an effort to minimize or eliminate the bypass.
- c. Ecology will determine if the Permittee has met the conditions of Special Condition S4.B.2 a and b and consider the following prior to issuing a determination letter, an administrative order, or a permit modification as appropriate for an anticipated bypass:
- If the Permittee planned and scheduled the bypass to minimize adverse effects on the public and the environment.
  - If the bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
  - If feasible alternatives to the bypass exist, such as:
    - The use of auxiliary treatment facilities.
    - Retention of untreated wastes.
    - Stopping production.
    - Maintenance during normal periods of equipment downtime, but not if the Permittee should have installed adequate backup equipment in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance.
    - Transport of untreated wastes to another treatment facility.

## **S5. Solid Wastes**

### **S5.A. Solid Waste Handling**

The Permittee must handle and dispose of all solid waste material in such a manner as to prevent its entry into state ground or surface water.

### **S5.B. Leachate**

The Permittee must not allow leachate from its solid waste material to enter state waters without providing all known, available, and reasonable methods of treatment, nor allow such leachate to cause violations of the State Surface Water Quality Standards, Chapter 173-201A WAC, or the State Ground Water Quality Standards, Chapter 173-200 WAC. The Permittee must apply for a permit or permit modification as may be required for such discharges to state ground or surface waters.

### **S5.C. Solid Waste Control Plan**

#### **a. Submittal Requirements**

The Permittee must:

1. Submit a solid waste control plan to Ecology by November 1, 2021.
2. Submit to Ecology any proposed revision or modification of the solid waste control plan for review and approval at least 30 days prior to implementation.
3. Comply with the plan and any modifications.
4. Submit an update of the solid waste control plan by November 1, 2023.

#### **b. Solid Waste Control Plan Content**

The solid waste control plan must:

1. Follow Ecology's guidance for preparing a solid waste control plan (<https://fortress.wa.gov/ecy/publications/documents/0710024.pdf>) and address all solid wastes generated by the permittee.
2. Include at a minimum a description, source, generation rate, and disposal methods of these solid wastes.
3. Not conflict with local or state solid waste regulations.

## **S6. Prohibited Discharges**

The Permittee must comply with these General and Specific Discharge Prohibitions for Outfalls 001A and 001B.

### **S6.A. General Prohibitions**

The Permittee must not introduce into the receiving treatment plant pollutants which cause pass-through or interference.

### **S6.B. Specific Prohibitions**

In addition, the Permittee must not introduce the following into the collection system or the receiving treatment plant:

1. Pollutants which create a fire or explosion hazard in the collection system or at the receiving treatment plant, including, but not limited to, waste streams with a closed cup flashpoint of less than 60 degrees C (140 degrees F) using the test methods specified in 40 CFR 261.21.
2. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the collection system or at the receiving treatment plant resulting in interference.
3. Any pollutant (including oxygen-demanding pollutants (BOD<sub>5</sub>, etc.)), released in a discharge at a flow rate and/or pollutant concentration that will cause interference with the receiving treatment plant.
4. Heat in amounts which will inhibit biological activity in the receiving treatment plant resulting in interference, but in no case heat in such quantities that the temperature at the receiving treatment plant exceeds 40 degrees C (104 degrees F) unless the approval authority, upon request of the receiving treatment plant, approves alternative temperature limits.
5. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through.
6. Pollutants which result in the presence of toxic gases, vapors, or fumes within the collection system or the receiving treatment plant in a quantity that may cause acute worker health and safety problems.
7. Any trucked or hauled pollutants, except at discharge points designated by the collection system and/or receiving treatment plant.
8. Pollutants that will cause corrosive structural damage to the collection system or the receiving treatment plant.

**S6.C. Prohibited Unless Approved**

Any of the following discharges are prohibited unless approved by Ecology under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or a need to augment sewage flows due to septic conditions):

1. Noncontact cooling water in significant volumes.
2. Storm water and other direct inflow sources.
3. Wastewaters significantly affecting system hydraulic loading, which do not require treatment or would not be afforded a significant degree of treatment by the system.
4. The discharge of dangerous wastes as defined in Chapter 173-303 WAC (unless specifically authorized in this permit).

**S7. Dilution Prohibited**

The Permittee must not dilute the process wastewater discharge to the receiving treatment plant with non-process area stormwater or increase the use of potable water, process water, or, in any way, attempt to dilute an effluent as a partial or complete substitute for adequate treatment to achieve compliance with the limits for Outfalls 001A and 001B contained in this permit.

## **S8. Application for Permit Renewal or Modification for Facility Changes**

The Permittee must submit an application for renewal of this permit by November 1, 2023.

The Permittee must also submit a new application or addendum at least one hundred eighty (180) days prior to commencement of discharges, resulting from the activities listed below, which may result in permit violations. These activities include any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility.

## **S9. Non-Routine and Unanticipated Wastewater**

1. Beginning on the effective date of this permit, the Permittee is authorized to discharge non-routine wastewater or unanticipated wastewater and therefore not listed on the permit application, on a case-by-case basis if approved by Ecology and the receiving collection system operator and treatment plant, if applicable. Prior to any such discharge, the Permittee must contact Ecology and **at a minimum** provide the following information:
  - a. The proposed discharge location.
  - b. The nature of the activity that will generate the discharge.
  - c. Any alternatives to the discharge, such as reuse, storage, or recycling of the water.
  - d. The total volume of water it expects to discharge.
  - e. The results of the chemical analysis of the water.
  - f. The date of proposed discharge.
  - g. The expected rate of discharge discharged, in gallons per minute.
  - h. Confirmation that the receiving collection system and treatment plant accept the proposed discharge, if applicable.
2. The Permittee must analyze the water for all constituents limited for the discharge and report them as required by subpart 1.e above. The analysis must also include any parameter deemed necessary by Ecology. All discharges must comply with the effluent limits as established in Special Condition S1 of this permit, water quality standards, and any other limits imposed by Ecology.
3. The Permittee must limit the discharge rate, as referenced in subpart 1.g above, so it will not cause erosion of ditches or structural damage to culverts and their entrances or exits.
4. The discharge cannot proceed until Ecology has reviewed the information provided and has authorized the discharge by letter to the Permittee or by an Administrative Order.

Once approved and if the proposed discharge is to a municipal storm drain, the Permittee must obtain prior approval from the municipality and notify it when it plans to discharge.



## **S10. Spill Control Plan**

### **S10.A. Spill Control Plan Submittals and Requirements**

The Permittee must:

1. Submit to Ecology an update to the existing spill control plan by November 1, 2020.
2. Review the plan at least annually and update the spill plan as needed.
3. Send changes to the plan to Ecology.
4. Follow the plan and any supplements throughout the term of the permit.

### **S10.B. Spill Control Plan Components**

The spill control plan must include the following:

1. A list of all oil and petroleum products and other materials used and/or stored on-site, which when spilled, or otherwise released into the environment, designate as Dangerous Waste (DW) or Extremely Hazardous Waste (EHW) by the procedures set forth in WAC 173-303-070. Include other materials used and/or stored on-site which may become pollutants or cause pollution upon reaching state's waters.
2. A description of preventive measures and facilities (including an overall facility plot showing drainage patterns) which prevent, contain, or treat spills of these materials.
3. A description of the reporting system the Permittee will use to alert responsible managers and legal authorities in the event of a spill.
4. A description of operator training to implement the plan.

The Permittee may submit plans and manuals required by 40 CFR Part 112, contingency plans required by Chapter 173-303 WAC, or other plans required by other agencies, which meet the intent of this section. Approval of the Spill Control Plan with respect to this requirement does not constitute approval of the plans and manuals with respect to the underlying requirement.

## **S11. Slug Discharge Control Plan**

### **S11.A. Slug Discharge Control Plan Submittal and Requirements**

The Permittee must:

3. Prepare and submit to Ecology, by November 1, 2020, a plan to minimize the potential of slug discharges from the facility covered by this permit. The plan and any subsequent revisions become effective 30 days following submission.
4. Review its slug discharge plan and update it as needed.
5. Submit all revisions or updates of this plan to Ecology for review and approval.
6. Keep the current approved plan on the plant site and make it readily available to facility personnel.
7. Follow the approved plan and any approved supplements throughout the term of the permit.

8. Submit an update of the slug discharge control plan, or a certification that it is current by November 1, 2023.

### **S11.B. Slug Discharge Control Plan Components**

The slug discharge control plan must include the following information and procedures relating to the prevention of unauthorized slug discharges from Outfalls 001A and 001B to the collection system and the receiving treatment plant; it must include:

1. A description of a reporting system the Permittee will use to immediately notify facility management, the receiving treatment plant operator, the collection system operator, and appropriate state, federal, and local authorities of any slug discharges, and provisions to provide a written follow-up report within five days.
2. A description of operator training, equipment, and facilities (including overall facility plan) for preventing, containing, or treating slug discharges.
3. Procedures to prevent adverse impact to the collection system and the receiving treatment plant from accidental spills including:
  - a. Inspection and maintenance of storage areas
  - b. Handling and transfer of materials
  - c. Loading and unloading operations
  - d. Control of plant site run-off
  - e. Worker training
  - f. Building of containment structures or equipment
  - g. Measures for containing toxic organic pollutants (including solvents)
  - h. Measures and equipment for emergency response
4. A list of all raw materials, products, chemicals, and hazardous materials used, processed, or stored at the facility; the normal quantity maintained on the premises for each listed material; and a map showing where they are located.
5. A description of process wastewater discharge practices for batch and continuous processes under normal and non-routine circumstances.
6. A brief description of any unauthorized discharges which occurred during the 36-month period preceding the effective date of this permit and subsequent measures taken by the Permittee to prevent or to reduce the possibility of further unauthorized discharges.
7. An implementation schedule including additional operator training and procurement and installation of equipment or facilities required to properly implement the plan.

### **S12. Receiving Water Study**

The Permittee must collect receiving water information necessary to determine if the effluent has a reasonable potential to cause a violation of the water quality standards. If reasonable potential exists, Ecology will use the study information to calculate effluent limits.

The Permittee must:

1. Submit a sampling and quality assurance plan for Ecology review and approval by November 1, 2020. Prepare all quality assurance plans in accordance with the guidelines given in *Guidelines for Preparing Quality Assurance Project Plans for Environmental Studies*, Ecology Publication 04-03-030. This document is available at: <https://fortress.wa.gov/ecy/publications/documents/0403030.pdf>
2. Conduct all sampling and analysis in accordance with the approved quality assurance project plan.
  - a. Locate the receiving water sampling locations outside the zone of influence of the effluent.
  - b. Use sampling station accuracy requirements of  $\pm 20$  meters.
  - c. Time the sampling as close as possible to the critical period.
  - d. Follow the clean sampling techniques (Method 1669: *Sampling Ambient Water for Trace Metals at EPA Water Quality Criteria Levels*, EPA Publication No. 821-R-95-034, April 1995).
  - e. Collect at least ten receiving water samples and analyze the samples for dissolved oxygen (DO), turbidity, total suspended solids (TSS), hardness, temperature, pH, ammonia, conductivity, iron, and chloride.
  - f. Conduct all chemical analysis using the methods and the detection levels identified in Appendix A.
3. Submit sediment, chemical, and biological data to Ecology's Environmental Information Management System (EIM). Data must be submitted to EIM according to the instructions on the EIM website.

The data submittal portion of the EIM website (<https://ecology.wa.gov/Research-Data/Data-resources/Environmental-Information-Management-database/EIM-submit-data>) provides information and help on formats and requirements for submitting tabular data. Specific questions about data submittal may be directed to the EIM Data Coordinator.
4. Submit the final report, summarizing the results of the study to Ecology within 1 year of Ecology's approval of the sampling and quality assurance plan. The final report must document when the data was successfully loaded into EIM.

Any subsequent sampling and analysis must also meet these requirements. The Permittee may conduct a cooperative receiving water study with other NPDES Permittees discharging in the same vicinity.

### **S13. Dangerous Wastes – Permit by Rule Requirements**

The Permittee is authorized to treat dangerous wastes, generated on -site, at the wastewater treatment units under the permit by rule provisions of WAC 173-303-802(5). This authorization is limited to the onsite waste streams identified on the permit application and application amendments as approved by Ecology.

#### **S14. Stormwater Management Plan (SWMP)**

1. All stormwater runoff generated from process areas must be routed to Outfall 001A or Outfall 001B. Any stormwater runoff from process areas discharged directly from the facility site must be reported to Ecology within 24 hours and a plan for corrective action must be submitted to Ecology within 30 days of the event.
2. The Permittee must develop and implement a stormwater management plan (SWMP) for stormwater runoff from process areas. If a stormwater pollution prevention plan (SWPPP) has been developed that includes stormwater runoff from process areas, the SWPPP can be used to meet this requirement. The Permittee must ensure the SWPPP includes all of the required information for the SWMP. The SWMP or SWPPP must be submitted to Ecology for review and approval no later than November 1, 2020.

At a minimum, the SWMP must include the following information:

- a. A site map that identifies:
  - i. The scale or the relative distances between significant structures and drainage systems
  - ii. Significant features
  - iii. Stormwater drainage and discharge structures
  - iv. Stormwater drainage areas for each stormwater discharge point off-site (if applicable)
  - v. Paved areas and buildings
  - vi. Areas of pollutant contact (actual or potential) associated with specific industrial activities
  - vii. Surface water locations (including wetlands and drainage ditches)
  - viii. Areas of existing and potential soil erosion (in a significant amount)
  - ix. Vehicle maintenance areas
  - x. Lands and waters adjacent to the site that may be helpful in identifying discharge points or drainage routes
- b. Best Management Practices (BMPs): The SWMP must describe all BMPs used to prevent stormwater runoff from leaving the site and discharging directly to any surface waters.
- c. Preventive Maintenance: The SWMP shall include BMPs to inspect and maintain the stormwater drainage system and other controls that could fail and result in the discharge of untreated stormwater to surface water.
- d. Spill Prevention and Emergency Cleanup (SPEC): The SWMP must include a SPEC that includes BMPs to prevent spills that can contaminate stormwater. The SWMP may reference applicable sections of already existing plans.
- e. Employee Training: The SWMP shall include BMPs to provide SWMP training for employees who have duties in areas of industrial activities subject to this permit.

3. The stormwater BMPs must:
  - a. Provide all known, available, and reasonable methods of prevention, control, and treatment (AKART) for stormwater pollution.
  - b. Ensure the discharge does not cause or contribute to a violation of the Water Quality Standards.
  - c. Comply with applicable federal technology-based treatment requirements under 40 CFR 125.3.
  - d. Be consistent with the Stormwater Management Manual for Western Washington (August 2012 edition) or provide an equivalent level of pollution prevention approved by Ecology.
  
4. The Permittee must conduct at least one stormwater inspection per year during the wet season (October 1 – April 30).
 

The Permittee must conduct the wet season inspection during a rainfall event and must include observations of the presence of any floating materials, suspended solids, oil and grease, discolorations, turbidity, odor, etc., in stormwater runoff throughout the site that could contribute to discharge off-site. The results of the inspection for that year must be submitted to Ecology by September 1<sup>st</sup>.
  
5. The SWMP must be modified whenever there is a change in design, construction, operation, or maintenance at the facility that significantly changes the nature of pollutants in wastewater or stormwater, significantly increases the quantity of pollutants discharged, or causes the SWMP BMPs or work practices to be less effective in controlling pollutants. The Permittee must provide for implementation of any modifications to the SWMP in a timely manner.

### **S.15 Compliance Schedule**

The Permittee must meet the final effluent limits for Outfall 002, as established in Special Condition S1, by November 1, 2021. The following compliance schedule establishes milestones for meeting this requirement.

<b>Task</b>	<b>Special Condition Requirement</b>	<b>Due Date</b>
1. Perform effluent characterization analysis and report results.	S2 (sampling) S3 (reporting)	October 31, 2020 (sampling) January 15, 2021 (reporting)
2. Complete a receiving water study and submit a report.	S12	November 1, 2020 (plan) Submit report within 1 year of plan approval.

<b>Task</b>	<b>Special Condition Requirement</b>	<b>Due Date</b>
<p>3. Modify the discharge or install additional treatment if the final effluent limits cannot be met.</p> <p>The Permittee must submit plans and specifications if a modification to the existing treatment system or installation of an additional treatment system is necessary.</p>	<p>S1 (final discharge limits)</p> <p>G5 (plans and specifications submittal)</p>	<p>November 1, 2021</p> <p>At least 180 days prior to the commencement of construction</p>

## General Conditions

### G1. Signatory Requirements

1. All applications submitted to Ecology must be signed and certified.
  - a. In the case of corporations, by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
    - A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation, or
    - The manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long-term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
  - b. In the case of a partnership, by a general partner.
  - c. In the case of sole proprietorship, by the proprietor.
  - d. In the case of a municipal, state, or other public facility, by either a principal executive officer or ranking elected official.

Applications for permits for domestic wastewater facilities that are either owned or operated by, or under contract to, a public entity shall be submitted by the public entity.

2. All reports required by this permit and other information requested by Ecology must be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by a person described above and submitted to Ecology.
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
3. Changes to authorization. If an authorization under paragraph G1.2, above, is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph G1.2, above, must be submitted to Ecology prior to or together with any reports, information, or applications to be signed by an authorized representative.

4. Certification. Any person signing a document under this section must make the following certification:

“I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

## **G2. Right of Inspection and Entry**

The Permittee must allow an authorized representative of Ecology, upon the presentation of credentials and such other documents as may be required by law:

1. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
2. To have access to and copy, at reasonable times and at reasonable cost, any records required to be kept under the terms and conditions of this permit.
3. To inspect, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
4. To sample or monitor, at reasonable times, any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

## **G3. Permit Actions**

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the permittee) or upon Ecology’s initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in 40 CFR 122.62, 122.64 or WAC 173-220-150 according to the procedures of 40 CFR 124.5.

1. The following are causes for terminating this permit during its term, or for denying a permit renewal application:
  - a. Violation of any permit term or condition.
  - b. Obtaining a permit by misrepresentation or failure to disclose all relevant facts.
  - c. A material change in quantity or type of waste disposal.
  - d. A determination that the permitted activity endangers human health or the environment, or contributes to water quality standards violations and can only be regulated to acceptable levels by permit modification or termination.
  - e. A change in any condition that requires either a temporary or permanent reduction, or elimination of any discharge or sludge use or disposal practice controlled by the permit.
  - f. Nonpayment of fees assessed pursuant to RCW 90.48.465.
  - g. Failure or refusal of the Permittee to allow entry as required in RCW 90.48.090.



2. The following are causes for modification but not revocation and reissuance except when the Permittee requests or agrees:
  - a. A material change in the condition of the waters of the state.
  - b. New information not available at the time of permit issuance that would have justified the application of different permit conditions.
  - c. Material and substantial alterations or additions to the permitted facility or activities which occurred after this permit issuance.
  - d. Promulgation of new or amended standards or regulations having a direct bearing upon permit conditions, or requiring permit revision.
  - e. The Permittee has requested a modification based on other rationale meeting the criteria of 40 CFR Part 122.62.
  - f. Ecology has determined that good cause exists for modification of a compliance schedule, and the modification will not violate statutory deadlines.
  - g. Incorporation of an approved local pretreatment program into a municipality's permit.
3. The following are causes for modification or alternatively revocation and reissuance:
  - a. When cause exists for termination for reasons listed in 1.a through 1.g of this section, and Ecology determines that modification or revocation and reissuance is appropriate.
  - b. When Ecology has received notification of a proposed transfer of the permit. A permit may also be modified to reflect a transfer after the effective date of an automatic transfer (General Condition G7) but will not be revoked and reissued after the effective date of the transfer except upon the request of the new Permittee.

#### **G4. Reporting Planned Changes**

The Permittee must, as soon as possible, but no later than one hundred eighty (180) days prior to the proposed changes, give notice to Ecology of planned physical alterations or additions to the permitted facility, production increases, or process modification which will result in:

1. The permitted facility being determined to be a new source pursuant to 40 CFR 122.29(b).
2. A significant change in the nature or an increase in quantity of pollutants discharged.
3. A significant change in the Permittee's sludge use or disposal practices. Following such notice, and the submittal of a new application or supplement to the existing application, along with required engineering plans and reports, this permit may be modified, or revoked and reissued pursuant to 40 CFR 122.62(a) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of permit limits or not specifically authorized by this permit constitutes a violation.

#### **G5. Plan Review Required**

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications must be submitted to Ecology for approval in accordance with chapter 173-240 WAC.

Engineering reports, plans, and specifications must be submitted at least one hundred eighty (180) days prior to the planned start of construction unless a shorter time is approved by Ecology. Facilities must be constructed and operated in accordance with the approved plans.

## **G6. Compliance with Other Laws and Statutes**

Nothing in this permit excuses the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

## **G7. Transfer of This Permit**

In the event of any change in control or ownership of facilities from which the authorized discharge emanate, the Permittee must notify the succeeding owner or controller of the existence of this permit by letter, a copy of which must be forwarded to Ecology.

### **1. Transfers by Modification**

Except as provided in paragraph (2) below, this permit may be transferred by the Permittee to a new owner or operator only if this permit has been modified or revoked and reissued under 40 CFR 122.62(b)(2), or a minor modification made under 40 CFR 122.63(d), to identify the new Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

### **2. Automatic Transfers**

This permit may be automatically transferred to a new Permittee if:

- a. The Permittee notifies Ecology at least thirty (30) days in advance of the proposed transfer date.
- b. The notice includes a written agreement between the existing and new Permittees containing a specific date transfer of permit responsibility, coverage, and liability between them.
- c. Ecology does not notify the existing Permittee and the proposed new Permittee of its intent to modify or revoke and reissue this permit. A modification under this subparagraph may also be minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the written agreement.

## **G8. Reduced Production for Compliance**

The Permittee, in order to maintain compliance with its permit, must control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

## **G9. Removed Substances**

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters must not be resuspended or reintroduced to the final effluent stream for discharge to state waters.

### **G10. Duty to Provide Information**

The Permittee must submit to Ecology, within a reasonable time, all information which Ecology may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee must also submit to Ecology upon request, copies of records required to be kept by this permit.

### **G11. Other Requirements of 40 CFR**

All other requirements of 40 CFR 122.41 and 122.42 are incorporated in this permit by reference.

### **G12. Additional Monitoring**

Ecology may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.

### **G13. Payment of Fees**

The Permittee must submit payment of fees associated with this permit as assessed by Ecology.

### **G14. Penalties for Violating Permit Conditions**

Any person who is found guilty of willfully violating the terms and conditions of this permit is deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to ten thousand dollars (\$10,000) and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.

Any person who violates the terms and conditions of a waste discharge permit may incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to ten thousand dollars (\$10,000) for every such violation. Each and every such violation is a separate and distinct offense, and in case of a continuing violation, every day's continuance is deemed to be a separate and distinct violation.

### **G15. Upset**

Definition – “Upset” means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limits because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limits if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset must demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

1. An upset occurred and that the Permittee can identify the cause(s) of the upset.
2. The permitted facility was being properly operated at the time of the upset.

3. The Permittee submitted notice of the upset as required in Special Condition S3.F.
4. The Permittee complied with any remedial measures required under S3.F of this permit.

In any enforcement action the Permittee seeking to establish the occurrence of an upset has the burden of proof.

### **G16. Property Rights**

This permit does not convey any property rights of any sort, or any exclusive privilege.

### **G17. Duty to Comply**

The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

### **G18. Toxic Pollutants**

The Permittee must comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

### **G19. Penalties for Tampering**

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two (2) years per violation, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this condition, punishment shall be a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than four (4) years, or by both.

### **G20. Reporting Requirements Applicable to Existing Manufacturing, Commercial, Mining, and Silvicultural Dischargers**

The Permittee belonging to the categories of existing manufacturing, commercial, mining, or silviculture must notify Ecology as soon as they know or have reason to believe:

1. That any activity has occurred or will occur which would result in the discharge from Outfall 002, on a routine or frequent basis, of any toxic pollutant which is not limited in this permit, if that discharge will exceed the highest of the following "notification levels:"
  - a. One hundred micrograms per liter (100 µg/L).
  - b. Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony.
  - c. Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21(g)(7).

- d. The level established by the Director in accordance with 40 CFR 122.44(f).
2. That any activity has occurred or will occur which would result in any discharge to surface waters, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in this permit, if that discharge will exceed the highest of the following “notification levels:”
    - a. Five hundred micrograms per liter (500µg/L).
    - b. One milligram per liter (1 mg/L) for antimony.
    - c. Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with 40 CFR 122.21(g)(7).
    - d. The level established by the Director in accordance with 40 CFR 122.44(f).

## **G21. Compliance Schedules**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit must be submitted no later than fourteen (14) days following each schedule date.

## Appendix A

### List of Pollutants with Analytical Methods, Detection Limits and Quantitation Levels

The Permittee must use the specified analytical methods, detection limits (DLs) and quantitation levels (QLs) in the following table for permit and application required monitoring unless:

- Another permit condition specifies other methods, detection levels, or quantitation levels.
- The method used produces measurable results in the sample and EPA has listed it as an EPA-approved method in 40 CFR Part 136.

If the Permittee uses an alternative method, not specified in the permit and as allowed above, it must report the test method, DL, and QL on the discharge monitoring report or in the required report.

If the Permittee is unable to obtain the required DL and QL in its effluent due to matrix effects, the Permittee must submit a matrix-specific detection limit (MDL) and a quantitation limit (QL) to Ecology with appropriate laboratory documentation.

When the permit requires the Permittee to measure the base neutral compounds in the list of priority pollutants, it must measure all of the base neutral pollutants listed in the table below. The list includes EPA required base neutral priority pollutants and several additional polynuclear aromatic hydrocarbons (PAHs). The Water Quality Program added several PAHs to the list of base neutrals below from Ecology's Persistent Bioaccumulative Toxics (PBT) List. It only added those PBT parameters of interest to Appendix A that did not increase the overall cost of analysis unreasonably.

Ecology added this Appendix to the permit in order to reduce the number of analytical "non-detects" in permit-required monitoring and to measure effluent concentrations near or below criteria values where possible at a reasonable cost.

The lists below include conventional pollutants (as defined in CWA section 502(6) and 40 CFR Part 122.), toxic or priority pollutants as defined in CWA section 307(a)(1) and listed in 40 CFR Part 122 Appendix D, 40 CFR Part 401.15 and 40 CFR Part 423 Appendix A), and nonconventionals. 40 CFR Part 122 Appendix D (Table V) also identifies toxic pollutants and hazardous substances which are required to be reported by dischargers if expected to be present. This permit Appendix A list does not include those parameters.

***Conventional Pollutants***

<b>Pollutant</b>	<b>CAS Number (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
Biochemical Oxygen Demand		SM5210-B		2 mg/L
Biochemical Oxygen Demand, Soluble		SM5210-B <sup>3</sup>		2 mg/L
Fecal Coliform		SM 9221E,9222	N/A	Specified in method - sample aliquot dependent
Oil and Grease (HEM) (Hexane Extractable Material)		1664 A or B	1,400	5,000
pH		SM4500-H <sup>+</sup> B	N/A	N/A
Total Suspended Solids		SM2540-D		5 mg/L

***Nonconventional Pollutants***

<b>Pollutant</b>	<b>CAS Number (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
Alkalinity, Total		SM2320-B		5 mg/L as CaCO <sub>3</sub>
Aluminum, Total	7429-90-5	200.8	2.0	10
Ammonia, Total (as N)		SM4500-NH <sub>3</sub> -B and C/D/E/G/H		20
Barium Total	7440-39-3	200.8	0.5	2.0
BTEX (benzene + toluene + ethylbenzene + m,o,p xylenes)		EPA SW 846 8021/8260	1	2
Boron, Total	7440-42-8	200.8	2.0	10.0
Chemical Oxygen Demand		SM5220-D		10 mg/L
Chloride		SM4500-Cl B/C/D/E and SM4110 B		Sample and limit dependent
Chlorine, Total Residual		SM4500 Cl G		50.0

<b>Pollutant</b>	<b>CAS Number (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
Cobalt, Total	7440-48-4	200.8	0.05	0.25
Color		SM2120 B/C/E		10 color units
Dissolved oxygen		SM4500-OC/OG		0.2 mg/L
E.coli		SM 9221B, 9221F, 9223B	N/A	Specified in method - sample aliquot dependent
Enterococci		SM 9230B, 9230C, 9230D	N/A	Specified in method - sample aliquot dependent
Flow		Calibrated device		
Fluoride	16984-48-8	SM4500-F E	25	100
Hardness, Total		SM2340B		200 as CaCO <sub>3</sub>
Iron, Total	7439-89-6	200.7	12.5	50
Magnesium, Total	7439-95-4	200.7	10	50
Manganese, Total	7439-96-5	200.8	0.1	0.5
Molybdenum, Total	7439-98-7	200.8	0.1	0.5
Nitrate + Nitrite Nitrogen (as N)		SM4500-NO <sub>3</sub> - E/F/H		100
Nitrogen, Total Kjeldahl (as N)		SM4500-N <sub>org</sub> B/C and SM4500NH <sub>3</sub> - B/C/D/EF/G/H		300
NWTPH Dx <sup>4</sup>		Ecology NWTPH Dx	250	250
NWTPH Gx <sup>5</sup>		Ecology NWTPH Gx	250	250
Phosphorus, Total (as P)		SM 4500 PB followed by SM4500-PE/PF	3	10
Salinity		SM2520-B		3 practical salinity units or scale (PSU or PSS)



<b>Pollutant</b>	<b>CAS Number (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
Settleable Solids		SM2540 -F		Sample and limit dependent
Soluble Reactive Phosphorus (as P)		SM4500-P E/F/G	3	10
Sulfate (as mg/L SO <sub>4</sub> )		SM4110-B		0.2 mg/L
Sulfide (as mg/L S)		SM4500-S <sup>2</sup> F/D/E/G		0.2 mg/L
Sulfite (as mg/L SO <sub>3</sub> )		SM4500-SO3B		2 mg/L
Temperature (max. 7-day avg.)		Analog recorder or Use micro-recording devices known as thermistors		0.2° C
Tin, Total	7440-31-5	200.8	0.3	1.5
Titanium, Total	7440-32-6	200.8	0.5	2.5
Total Coliform		SM 9221B, 9222B, 9223B	N/A	Specified in method - sample aliquot dependent
Total Organic Carbon		SM5310-B/C/D		1 mg/L
Total dissolved solids		SM2540 C		20 mg/L

***Priority Pollutants (PP) – Metals, Cyanide, & Total Phenols***

<b>Pollutant</b>	<b>PP #</b>	<b>CAS Number (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
Antimony, Total	114	7440-36-0	200.8	0.3	1.0
Arsenic, Total	115	7440-38-2	200.8	0.1	0.5
Beryllium, Total	117	7440-41-7	200.8	0.1	0.5
Cadmium, Total	118	7440-43-9	200.8	0.05	0.25
Chromium (hex) dissolved	119	18540-29-9	SM3500-Cr C	0.3	1.2
Chromium, Total	119	7440-47-3	200.8	0.2	1.0

<b>Pollutant</b>	<b>PP #</b>	<b>CAS Number (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
Copper, Total	120	7440-50-8	200.8	0.4	2.0
Lead, Total	122	7439-92-1	200.8	0.1	0.5
Mercury, Total	123	7439-97-6	1631E	0.0002	0.0005
Nickel, Total	124	7440-02-0	200.8	0.1	0.5
Selenium, Total	125	7782-49-2	200.8	1.0	1.0
Silver, Total	126	7440-22-4	200.8	0.04	0.2
Thallium, Total	127	7440-28-0	200.8	0.09	0.36
Zinc, Total	128	7440-66-6	200.8	0.5	2.5
Cyanide, Total	121	57-12-5	335.4	5	10
Cyanide, Weak Acid Dissociable	121		SM4500-CN I	5	10
Cyanide, Free Amenable to Chlorination (Available Cyanide)	121		SM4500-CN G	5	10
Phenols, Total	65		EPA 420.1		50

*PP – Acid Compounds*

<b>Pollutant</b>	<b>PP #</b>	<b>CAS Number (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
2-Chlorophenol	24	95-57-8	625.1	3.3	9.9
2,4-Dichlorophenol	31	120-83-2	625.1	2.7	8.1
2,4-Dimethylphenol	34	105-67-9	625.1	2.7	8.1
4,6-dinitro-o-cresol (2-methyl-4,6,- dinitrophenol)	60	534-52-1	625.1/1625B	24	72
2,4 dinitrophenol	59	51-28-5	625.1	42	126
2-Nitrophenol	57	88-75-5	625.1	3.6	10.8
4-Nitrophenol	58	100-02-7	625.1	2.4	7.2
Parachlorometa cresol (4-chloro-3- methylphenol)	22	59-50-7	625.1	3.0	9.0

Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> µg/L unless specified	Quantitation Level (QL) <sup>2</sup> µg/L unless specified
Pentachlorophenol	64	87-86-5	625.1	3.6	10.8
Phenol	65	108-95-2	625.1	1.5	4.5
2,4,6-Trichlorophenol	21	88-06-2	625.1	2.7	8.1

*PP – Volatile Compounds*

Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> µg/L unless specified	Quantitation Level (QL) <sup>2</sup> µg/L unless specified
Acrolein	2	107-02-8	624	5	10
Acrylonitrile	3	107-13-1	624	1.0	2.0
Benzene	4	71-43-2	624.1	4.4	13.2
Bromoform	47	75-25-2	624.1	4.7	14.1
Carbon tetrachloride	6	56-23-5	624.1/601 or SM6230B	2.8	8.4
Chlorobenzene	7	108-90-7	624.1	6.0	18.0
Chloroethane	16	75-00-3	624/601	1.0	2.0
2-Chloroethylvinyl Ether	19	110-75-8	624	1.0	2.0
Chloroform	23	67-66-3	624.1 or SM6210B	1.6	4.8
Dibromochloromethane (chlordibromomethane)	51	124-48-1	624.1	3.1	9.3
1,2-Dichlorobenzene	25	95-50-1	624	1.9	7.6
1,3-Dichlorobenzene	26	541-73-1	624	1.9	7.6
1,4-Dichlorobenzene	27	106-46-7	624	4.4	17.6
Dichlorobromomethane	48	75-27-4	624.1	2.2	6.6
1,1-Dichloroethane	13	75-34-3	624.1	4.7	14.1
1,2-Dichloroethane	10	107-06-2	624.1	2.8	8.4
1,1-Dichloroethylene	29	75-35-4	624.1	2.8	8.4
1,2-Dichloropropane	32	78-87-5	624.1	6.0	18.0

Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> µg/L unless specified	Quantitation Level (QL) <sup>2</sup> µg/L unless specified
1,3-dichloropropene (mixed isomers) (1,2-dichloropropylene) <sup>6</sup>	33	542-75-6	624.1	5.0	15.0
Ethylbenzene	38	100-41-4	624.1	7.2	21.6
Methyl bromide (Bromomethane)	46	74-83-9	624/601	5.0	10.0
Methyl chloride (Chloromethane)	45	74-87-3	624	1.0	2.0
Methylene chloride	44	75-09-2	624.1	2.8	8.4
1,1,2,2-Tetrachloroethane	15	79-34-5	624.1	6.9	20.7
Tetrachloroethylene	85	127-18-4	624.1	4.1	12.3
Toluene	86	108-88-3	624.1	6.0	18.0
1,2-Trans-Dichloroethylene (Ethylene dichloride)	30	156-60-5	624.1	1.6	4.8
1,1,1-Trichloroethane	11	71-55-6	624.1	3.8	11.4
1,1,2-Trichloroethane	14	79-00-5	624.1	5.0	15.0
Trichloroethylene	87	79-01-6	624.1	1.9	5.7
Vinyl chloride	88	75-01-4	624/SM6200B	1.0	2.0

***PP – Base/Neutral Compounds***  
 Compounds in bold are Ecology PBTs

Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> µg/L unless specified	Quantitation Level (QL) <sup>2</sup> µg/L unless specified
Acenaphthene	1	83-32-9	625.1	1.9	5.7
Acenaphthylene	77	208-96-8	625.1	3.5	10.5
Anthracene	78	120-12-7	625.1	1.9	5.7
Benzidine	5	92-87-5	625.1	44	132
Benzyl butyl phthalate	67	85-68-7	625.1	2.5	7.5
Benzo(a)anthracene	72	56-55-3	625.1	7.8	23.4

Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> µg/L unless specified	Quantitation Level (QL) <sup>2</sup> µg/L unless specified
Benzo(b)fluoranthene (3,4-benzofluoranthene) <sup>7</sup>	74	205-99-2	610/625.1	4.8	14.4
<b>Benzo(j)fluoranthene</b> <sup>7</sup>		<b>205-82-3</b>	625	0.5	1.0
Benzo(k)fluoranthene (11,12-benzofluoranthene) <sup>7</sup>	75	207-08-9	610/625.1	2.5	7.5
<b>Benzo(r,s,t)pentaphene</b>		<b>189-55-9</b>	625	1.3	5.0
Benzo(a)pyrene	73	50-32-8	610/625.1	2.5	7.5
Benzo(ghi)Perylene	79	191-24-2	610/625.1	4.1	12.3
Bis(2-chloroethoxy)methane	43	111-91-1	625.1	5.3	15.9
Bis(2-chloroethyl)ether	18	111-44-4	611/625.1	5.7	17.1
Bis(2-chloro-1-methylethyl)Ether (Bis(2-chloroisopropyl)ether) <sup>10</sup>	42	108-60-1	625.1	5.7	17.1
Bis(2-ethylhexyl)phthalate	66	117-81-7	625.1	2.5	7.5
4-Bromophenyl phenyl ether	41	101-55-3	625.1	1.9	5.7
2-Chloronaphthalene	20	91-58-7	625.1	1.9	5.7
4-Chlorophenyl phenyl ether	40	7005-72-3	625.1	4.2	12.6
Chrysene	76	218-01-9	610/625.1	2.5	7.5
<b>Dibenzo (a,h)acridine</b>		<b>226-36-8</b>	610M/625M	2.5	10.0
<b>Dibenzo (a,j)acridine</b>		<b>224-42-0</b>	610M/625M	2.5	10.0
Dibenzo(a-h)anthracene (1,2,5,6-dibenzanthracene)	82	53-70-3	625.1	2.5	7.5
<b>Dibenzo(a,e)pyrene</b>		192-65-4	610M/625M	2.5	10.0
<b>Dibenzo(a,h)pyrene</b>		189-64-0	625M	2.5	10.0
3,3-Dichlorobenzidine	28	91-94-1	605/625.1	16.5	49.5
Diethyl phthalate	70	84-66-2	625.1	1.9	5.7
Dimethyl phthalate	71	131-11-3	625.1	1.6	4.8
Di-n-butyl phthalate	68	84-74-2	625.1	2.5	7.5

Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> µg/L unless specified	Quantitation Level (QL) <sup>2</sup> µg/L unless specified
2,4-dinitrotoluene	35	121-14-2	609/625.1	5.7	17.1
2,6-dinitrotoluene	36	606-20-2	609/625.1	1.9	5.7
Di-n-octyl phthalate	69	117-84-0	625.1	2.5	7.5
1,2-Diphenylhydrazine ( <i>as Azobenzene</i> )	37	122-66-7	1625B	5.0	20
Fluoranthene	39	206-44-0	625.1	2.2	6.6
Fluorene	80	86-73-7	625.1	1.9	5.7
Hexachlorobenzene	9	118-74-1	612/625.1	1.9	5.7
Hexachlorobutadiene	52	87-68-3	625.1	0.9	2.7
Hexachlorocyclopentadiene	53	77-47-4	1625B/625	2.0	4.0
Hexachloroethane	12	67-72-1	625.1	1.6	4.8
Indeno(1,2,3- <i>cd</i> )Pyrene	83	193-39-5	610/625.1	3.7	11.1
Isophorone	54	78-59-1	625.1	2.2	6.6
<b>3-Methyl cholanthrene</b>		<b>56-49-5</b>	625	2.0	8.0
Naphthalene	55	91-20-3	625.1	1.6	4.8
Nitrobenzene	56	98-95-3	625.1	1.9	5.7
N-Nitrosodimethylamine	61	62-75-9	607/625	2.0	4.0
N-Nitrosodi-n-propylamine	63	621-64-7	607/625	0.5	1.0
N-Nitrosodiphenylamine	62	86-30-6	625	1.0	2.0
<b>Perylene</b>		<b>198-55-0</b>	625	1.9	7.6
Phenanthrene	81	85-01-8	625.1	5.4	16.2
Pyrene	84	129-00-0	625.1	1.9	5.7
1,2,4-Trichlorobenzene	8	120-82-1	625.1	1.9	5.7

*PP – Dioxin*

Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> µg/L unless specified	Quantitation Level (QL) <sup>2</sup> µg/L unless specified
2,3,7,8-Tetra-Chlorodibenzo-P-Dioxin (2,3,7,8 TCDD)	129	1746-01-6	1613B	1.3 pg/L	5 pg/L

*PP – Pesticides/PCBs*

Pollutant	PP #	CAS Number (if available)	Recommended Analytical Protocol	Detection (DL) <sup>1</sup> µg/L unless specified	Quantitation Level (QL) <sup>2</sup> µg/L unless specified
Aldrin	89	309-00-2	608.3	4.0 ng/L	12 ng/L
alpha-BHC	102	319-84-6	608.3	3.0 ng/L	9.0 ng/L
beta-BHC	103	319-85-7	608.3	6.0 ng/L	18 ng/L
gamma-BHC (Lindane)	104	58-89-9	608.3	4.0 ng/L	12 ng/L
delta-BHC	105	319-86-8	608.3	9.0 ng/L	27 ng/L
Chlordane <sup>8</sup>	91	57-74-9	608.3	14 ng/L	42 ng/L
4,4' -DDT	92	50-29-3	608.3	12 ng/L	36 ng/L
4,4' -DDE	93	72-55-9	608.3	4.0 ng/L	12 ng/L
4,4' DDD	94	72-54-8	608.3	11ng/L	33 ng/L
Dieldrin	90	60-57-1	608.3	2.0 ng/L	6.0 ng/L
alpha-Endosulfan	95	959-98-8	608.3	14 ng/L	42 ng/L
beta-Endosulfan	96	33213-65-9	608.3	4.0 ng/L	12 ng/L
Endosulfan Sulfate	97	1031-07-8	608.3	66 ng/L	198 ng/L
Endrin	98	72-20-8	608.3	6.0 ng/L	18 ng/L
Endrin Aldehyde	99	7421-93-4	608.3	23 ng/L	70 ng/L
Heptachlor	100	76-44-8	608.3	3.0 ng/L	9.0 ng/L
Heptachlor Epoxide	101	1024-57-3	608.3	83 ng/L	249 ng/L
PCB-1242 <sup>9</sup>	106	53469-21-9	608.3	0.065	0.195
PCB-1254	107	11097-69-1	608.3	0.065	0.195

<b>Pollutant</b>	<b>PP #</b>	<b>CAS Number (if available)</b>	<b>Recommended Analytical Protocol</b>	<b>Detection (DL)<sup>1</sup> µg/L unless specified</b>	<b>Quantitation Level (QL)<sup>2</sup> µg/L unless specified</b>
PCB-1221	108	11104-28-2	608.3	0.065	0.195
PCB-1232	109	11141-16-5	608.3	0.065	0.195
PCB-1248	110	12672-29-6	608.3	0.065	0.195
PCB-1260	111	11096-82-5	608.3	0.065	0.195
PCB-1016 <sup>9</sup>	112	12674-11-2	608.3	0.065	0.195
Toxaphene	113	8001-35-2	608.3	240 ng/L	720 ng/L



1. Detection level (DL) or detection limit means the minimum concentration of an analyte (substance) that can be measured and reported with a 99% confidence that the analyte concentration is greater than zero as determined by the procedure given in 40 CFR part 136, Appendix B.
2. Quantitation Level (QL) also known as Minimum Level of Quantitation (ML) – The lowest level at which the entire analytical system must give a recognizable signal and acceptable calibration point for the analyte. It is equivalent to the concentration of the lowest calibration standard, assuming that the lab has used all method-specified sample weights, volumes, and cleanup procedures. The QL is calculated by multiplying the MDL by 3.18 and rounding the result to the number nearest to  $(1, 2, \text{ or } 5) \times 10^n$ , where n is an integer. (64 FR 30417).

ALSO GIVEN AS:

The smallest detectable concentration of analyte greater than the Detection Limit (DL) where the accuracy (precision & bias) achieves the objectives of the intended purpose. (Report of the Federal Advisory Committee on Detection and Quantitation Approaches and Uses in Clean Water Act Programs Submitted to the US Environmental Protection Agency December 2007).

3. Soluble Biochemical Oxygen Demand method note: First, filter the sample through a Millipore Nylon filter (or equivalent) - pore size of 0.45-0.50 um (prep all filters by filtering 250 ml of laboratory grade deionized water through the filter and discard). Then, analyze sample as per method 5210-B.
4. NWTPH Dx - Northwest Total Petroleum Hydrocarbons Diesel Extended Range – see <https://fortress.wa.gov/ecy/publications/documents/97602.pdf>
5. NWTPH Gx - Northwest Total Petroleum Hydrocarbons Gasoline Extended Range – see <https://fortress.wa.gov/ecy/publications/documents/97602.pdf>
6. 1, 3-dichloroproylene (mixed isomers) - You may report this parameter as two separate parameters: cis-1, 3-dichloropropene (10061-01-5) and trans-1, 3-dichloropropene (10061-02-6).
7. Total Benzofluoranthenes - Because Benzo(b)fluoranthene, Benzo(j)fluoranthene and Benzo(k)fluoranthene co-elute you may report these three isomers as total benzofluoranthenes.
8. Chlordane – You may report alpha-chlordane (5103-71-9) and gamma-chlordane (5103-74-2) in place of chlordane (57-74-9). If you report alpha and gamma-chlordane, the DL/PQLs that apply are 14/42 ng/L.
9. PCB 1016 & PCB 1242 – You may report these two PCB compounds as one parameter called PCB 1016/1242.
10. Bis(2-Chloro-1-Methylethyl) Ether – This compound was previously listed as Bis(2-Chloroisopropyl) Ether (39638-32-9)