

Issuance Date: December 15, 2020  
Effective Date: January 1, 2021  
Expiration Date: December 31, 2025

## **AIR OPERATING PERMIT 0000078**


In compliance with the provisions of  
The State of Washington  
Clean Air Act Chapter 70.94 Revised Code of Washington


**WestRock Longview, LLC**  
**P.O. Box 639**  
**Longview, Washington 98632**

is authorized to operate in accordance with the terms and conditions  
of this permit.

Issued by:

State of Washington  
Department of Ecology  
P.O. Box 47600  
Olympia, Washington 98504-7600

  
\_\_\_\_\_  
Shingo Yamazaki, P.E.  
Environmental Engineer  
Solid Waste Management Program

  
\_\_\_\_\_  
James DeMay, P.E.  
Industrial Section Manager  
Solid Waste Management Program

## Table of Contents

INTRODUCTION AND LEGAL AUTHORITY .....	4
EMISSION UNIT SPECIFIC REQUIREMENTS [WAC 173-401-600] .....	5
A1. RECOVERY FURNACE 19 (RF19).....	6
A2. RECOVERY FURNACE 22 (RF22).....	17
B1. SMELT DISSOLVER TANK 19 (SDT19) .....	34
B2. SMELT DISSOLVER TANK 22 (SDT22) .....	42
C1. LIME KILN 3 (LK3) .....	52
C2. LIME KILN 4 (LK4) .....	61
C3. LIME KILN 5 (LK5) .....	70
D1. LOW VOLUME HIGH CONCENTRATION (LVHC) SYSTEM .....	85
D2. PULPING PROCESS CONDENSATES .....	91
D3. HIGH VOLUME LOW CONCENTRATION (HVLC) SYSTEM .....	96
E1. NEUTRAL SULFITE SEMI-CHEMICAL PLANT (NSSC).....	102
F1. DIGESTERS, MULTI-EFFECT EVAPORATORS, BROWNSTOCK WASHERS, AND CONDENSATE STRIPPER SYSTEMS.....	106
G1. POWER BOILER 20 (PB20).....	109
H1. PAPER MACHINES .....	138
I1. BOX PLANT PRODUCTION LINES .....	139
J1. RECIPROCATING INTERNAL COMBUSTION ENGINES (RICE) - EMERGENCY.....	142
J2. RECIPROCATING INTERNAL COMBUSTION ENGINES (RICE) – NEW SOURCE PERFORMANCE STANDARDS .....	144
J3. RECIPROCATING INTERNAL COMBUSTION ENGINES (RICE) – NON- EMERGENCY .....	147
K1. MILLWIDE EMISSION LIMITS.....	148
L1. GREENHOUSE GAS (GHG) REPORTING .....	150
M1. COMPLIANCE ASSURANCE MONITORING (CAM).....	151
FACILITY-WIDE GENERAL REQUIREMENTS [WAC 173-401-600] .....	154
MONITORING, RECORDKEEPING & REPORTING .....	158
STANDARD TERMS & CONDITIONS .....	165
MISCELLANEOUS REQUIREMENTS .....	167
PERMIT SHIELD.....	169
Appendix A – Monitoring and Calculation Specifications.....	175

ApA.1: Operating Limit Calculations.....	175
ApA.2: Monitoring Terminology and General Source Test Requirements.....	175
ApA.4: PB Mass Rate Limit Calculations .....	179
ApA.6: Exhaust Stack Flow Correlations.....	181
Appendix B – Emission Control Compliance Demonstration Plan.....	183
Appendix C – Applicable Permits and Orders.....	185

## INTRODUCTION AND LEGAL AUTHORITY

This Air Operating Permit is authorized under the Operating Permit Regulation, Chapter 173-401 Washington Administrative Code (WAC). The provisions of this permit describe the emissions limitations, operating requirements, monitoring and recording requirements, and reporting frequencies for the permitted source.

WestRock Longview, LLC (WestRock Longview) requires a Title V Air Operating Permit because it emits, or has the potential to emit, 100 tons per year or more of one or more air pollutants (WAC 173-401-300(1)).

During the drafting of this permit, Ecology has attempted to incorporate requirements using the exact language of the law, regulation, or order. In some cases, this has not been possible. Where there is a difference in language, this difference is presented in this permit only for clarification of the underlying requirement. The legal requirement remains the underlying applicable requirement cited in the “Applicable Requirements” column of the tables and the citations contained in brackets at the end of each requirement. Any conflict between the permit and an underlying requirement will be resolved by referring to the cited applicable requirement. Unless otherwise stated, the effective date of referenced regulations or statutes is that of the provision in effect on the date of permit issuance. Compliance with underlying requirements shall be demonstrated using the methods specified in this permit.

The Title V Air Operating Permit consists of all parts of this assembled document including all footnotes and Appendices, but does not include the accompanying Statement of Basis or the Title V permit application materials submitted by the facility.

The definitions of terms contained in WAC 173-401-200 and as defined in all referenced regulations, apply to this permit unless otherwise defined in the permit.

Any federal test method referenced, unless specifically stated otherwise within the body of the permit, is that which is contained in 40 CFR Part 60, Appendix A. Any state test method referenced, unless specifically stated otherwise within the body of the permit, is that which is contained in the “Ecology Source Test Manual” as of July 12, 1990.

## **EMISSION UNIT SPECIFIC REQUIREMENTS [WAC 173-401-600]**

WestRock Longview requires a Title V Air Operating Permit because it emits or has the potential to emit, 100 tons per year (tpy) or more of one or more air pollutants (WAC 173-401-300(1)). The emission units identified in Conditions A through J are subject to the emission unit specific requirements set forth in Conditions A through J. Monitoring is required only when the emission unit is operating. These units are also subject to the facility-wide applicable requirements and the mill wide emission limits in Condition K, as applicable. The associated monitoring, recordkeeping, and reporting requirements for these limits are in the Facility-Wide section of this permit or in Condition K. Unless specified otherwise, the basis of authority for the type and frequency of monitoring imposed in Conditions A through K is WAC 173-401-615.

The reference test method (RM) or compliance determination algorithm is identified under the column titled, "Monitoring and Reporting." The identified reference test method or compliance determination algorithm is the compliance determination method which is intended to be the default or absolute determinant of compliance. It may or may not also be the method by which ongoing compliance is indicated.

Insignificant emission units (IEUs) are subject to the applicable requirements contained in the Facility-Wide section, however they are not subject to testing, monitoring, recordkeeping, reporting requirements unless the generally applicable requirements in the State Implementation Plan (SIP) impose them. [WAC 173-401-530(2)(c)]

Appendix A contains the emission estimate algorithms. These algorithms set forth the manner by which emissions are calculated for those requirements for which the RM itself does not directly result in an emission estimate. Unless otherwise required by the applicable requirement, minor modifications to the test method may be used with the advanced approval of Ecology. In addition, the Permittee may use an equivalent alternative method with written approval from Ecology. Failure to obtain prior written approval for any test changes may invalidate the use of the test result(s) for Title V compliance purposes.

The permitted facility includes emission units that are subject to EPA's New Source Performance Standards (NSPS) including 40 CFR Part 60, Subparts A, D, Db, BB, and IIII. Emission units subject to NSPS requirements cross-reference the specific applicable NSPS standards.

The permitted facility includes emission units that are subject to EPA's National Emission Standards for Hazardous Air Pollutants (NESHAP) including 40 CFR Part 61 Subpart E and 40 CFR Part 63, Subparts A, S, KK, MM, ZZZZ, and DDDDD. Emission units subject to NESHAP requirements cross-reference the specific applicable NESHAP standards.

**A1. RECOVERY FURNACE 19 (RF19)**

The emission unit shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 of Subpart MM.

RF19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A1.1a	PM & PM <sub>10</sub>	0.040 gr/dscf @ 8% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i></p> <p>Sample M/Q using RM 5 (see Appendix ApA.2).</p> <p>During source tests for PM and PM<sub>10</sub> on all recovery furnaces, primary voltage, primary current, opacity, and spark rate for the electrostatic precipitator shall be recorded for each field once during each source test. In addition, secondary voltage and secondary current data shall also be collected once during each source test when available. All precipitator data shall be maintained on file with corresponding test data. Precipitator data shall be submitted to Ecology when the PM and PM<sub>10</sub> source test results exceed the permit limit. The department may modify or waive this requirement.</p> <p><i>Reporting:</i></p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i></p> <p>The Permittee shall comply with the general CAM requirements in Condition M. The Permittee shall comply with requirements in Condition A1.4. The Permittee shall implement corrective action if the average of ten consecutive 6-minute averages result in a measurement greater than 20 percent opacity.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.15</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

RF19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A1.1b	PM	0.10 gr/dscf @ 8% O <sub>2</sub> , 1-hr average	Same as for previous limit. CAM demonstration same as previous limits.	WAC 173-405-040(1)(a) 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
A1.1c	PM & PM <sub>10</sub>	292 tons per year, 12 month rolling total	Calculate per Appendix ApA.3. Report monthly. CAM demonstration same as previous limits.	PSD 01-03, Amendment 3, Condition 1.15 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
A1.2	HAP metals (PM as surrogate)	0.044 gr/dscf @ 8% O <sub>2</sub>	<p><i>Performance Testing:</i></p> <p>Sample every 5 years using EPA RM 5. First periodic performance test must be conducted by October 13, 2020 and within 5 years thereafter following the previous performance test. The sampling time and sample volume for each run shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used as the cleanup solvent instead of acetone in the sample recovery procedure.</p> <p><i>Representative Conditions:</i></p> <p>Performance tests shall be conducted based on representative performance during the period being tested. The owner/operator must record the process information that is necessary to document operating conditions during the test and include such record and explanation to support that such conditions represent normal operation. Upon request, the owner/operator shall make</p>	<p>40 CFR 63.862(a)(1)(i)(A) for standard</p> <p>40 CFR 63.863(c)(1) for 5-year periodic performance test compliance date</p> <p>40 CFR 63.865 for performance testing requirements</p> <p>40 CFR 63.9(e) and 40 CFR 63.7(b) for</p>

RF19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>available such records as may be necessary to determine the operating conditions during the performance test.</p> <p><i>60-day notification:</i></p> <p>The Permittee must notify Ecology in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is initially scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) All results of performance tests;</li> <li>2) The process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation;</li> <li>3) Documentation of supporting calculations for compliance determinations made under 40 CFR 63.865(a) through (d);</li> <li>4) For each failure to meet the emission limit, the number of failures, the date, start time, and duration of each event;</li> <li>5) For any failure to meet the emission limit, record an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions.</li> </ol> <p><i>On-going compliance:</i></p> <p>On-going compliance demonstrated through Condition A1.4.</p> <p><i>Reporting:</i></p> <p>Report failures to meet the applicable standard in the <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR</p>	<p>performance test notification</p> <p>40 CFR 63.866 for recordkeeping</p> <p>40 CFR 63.867(c)(4) for excess emission reporting and (d) for electronic reporting</p>



RF19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>63.867(c)(4), delivered or postmarked by the 30th day following the end of each calendar half.</p> <p>Within 60 days after the date of completing each performance test, submit the results of the performance test electronically via EPA's Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with 40 CFR 63.867(d).</p> <p>Submit source test results in the monthly air report, due after results received by the Permittee.</p>	
A1.3a	Opacity	Opacity greater than 30% for 2% or more of operating time during a semiannual period	<p><i>Monitoring:</i></p> <p>Monitoring continuously using a COMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS 1. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system operating requirements.</p> <p><i>Exceedances:</i></p> <p>An exceedance has occurred when the average of ten consecutive 6-minute averages result in a measurement of greater than 20 percent opacity. The Permittee must implement corrective action following an exceedance.</p> <p><i>Violation Determination:</i></p> <p>A violation occurs when opacity is greater than 30 percent for 2 percent or more of operating time during a semi-annual period while spent pulping liquor is fed.</p> <p><i>Reporting:</i></p> <p>Report daily maximum six-minute average opacity, daily maximum hourly average opacity, and exceedances monthly. Semi-annually report percent of operating time during a semi-annual period that opacity exceeded 30 percent.</p>	Order 3462-AQ07, Modification 1, Appendix A

RF19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A1.3b	Opacity	35% average for more than 6 consecutive minutes in any 60-minute period.	<p>EPA Reference Method 9 is the reference test method.</p> <p>Monitor continuously using a COMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, Performance Specification 1. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system operating requirements.</p> <p>Report daily maximum six-minute average opacity, daily average opacity, and exceedances monthly.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M. CAM reporting required on at a minimum semiannual basis.</p>	<p>WAC 173-405-040(6)</p> <p>WAC 173-401-615 for monitoring</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
A1.4	HAP Metals (Opacity as surrogate) Operating Limit	Opacity greater than 35% for 2% or more of operating time during a semiannual period.	<p><i>Monitoring:</i></p> <p>Monitor opacity using a COMS which is installed, calibrated, maintained, and operated in accordance with Performance Specification 1 (PS-1) in Appendix B to 40 CFR Part 60 and the provisions in §63.6(h) and 63.8 and §63.864(d)(3) and (4).</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Monitoring Exceedances:</i></p> <p>The Permittee is required to implement corrective action if the average of ten consecutive 6-minute averages result in a measurement greater than 20 percent opacity.</p> <p><i>Violation Determination:</i></p> <p>A violation of the underlying particulate matter standard in Condition A1.2 occurs when opacity is greater than 35 percent for 2 percent or more of operating time during a semiannual period while spent pulping liquor is fed.</p>	<p>40 CFR 63.864 for monitoring requirements</p> <p>40 CFR 63.864(k) for ongoing compliance and violation determination</p> <p>40 CFR 63.866 for recordkeeping requirements</p> <p>40 CFR 63.867(c) for excess emission reporting requirements</p>

RF19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) Black liquor solids firing rates in units of Mg/d or ton/d;</li> <li>2) Any occurrence when corrective action is required and when a violation is noted;</li> <li>3) For each failure to meet the opacity operating limit, the number of failures, the date, start time, and duration of each event;</li> <li>4) For each failure to meet the operating limit, an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions;</li> <li>5) Record actions taken to minimize emissions in accordance with §63.860(d) and any corrective actions taken to return the affected unit to its normal or usual manner of operation.</li> </ol> <p><i>Reporting:</i></p> <p>Report exceedances monthly to Ecology.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance</i> or <i>Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c), delivered or postmarked by the 30<sup>th</sup> day following the end of each calendar half.</p>	
A1.5a	SO <sub>2</sub>	149 lb/hr, 3-hr average	<p>Monitor continuously using a Continuous Emission Monitoring System (CEMS) that conforms to 40 CFR Part 60, Appendix F and Appendix B, Performance Specification 2 (PS-2).</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system operating requirements.</p> <p>Report 3-hr average concentrations, monthly average concentration, maximum monthly 3-hr average concentration, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.16

<b>RF19</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
A1.5b	SO <sub>2</sub>	500 ppm @ 8% O <sub>2</sub> , 1-hr average	Same as for previous limit. Report maximum monthly 1-hr average concentration in ppm corrected to 8% O <sub>2</sub> monthly.	WAC 173-405-040(9)(a)
A1.5c	SO <sub>2</sub>	301 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.16
A1.6a	TRS (as H <sub>2</sub> S)	10.0 ppm <sub>v</sub> @ 8% O <sub>2</sub> , 24-hr average	Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, Performance Specification 5 (PS-5). See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system operating requirements. Report daily maximum concentrations, 24-hr average concentrations, monthly average concentrations, maximum monthly 24-hr concentrations, and exceedances monthly.	PSD 01-03, Amendment 3, Condition 1.19
A1.6b	TRS (as H <sub>2</sub> S)	59 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.19
A1.7a	CO	600 lb/hr, 8-hr average	Sample A/M using RM 10 (see Appendix ApA.2). Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.17
A1.7b	CO	2,628 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.17

RF19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A1.8a	NO <sub>x</sub>	95 ppm <sub>dv</sub> @ 8% O <sub>2</sub> , 24-hr average	Sample A/M using RM 7 (see Appendix ApA.2).  Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.18
A1.8b	NO <sub>x</sub>	753 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.18
A1.9	O <sub>2</sub>	No limit – required for O <sub>2</sub> correction	Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, Performance Specification 3 (PS 3).  See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.	Order 3462-AQ07, Modification 1, Appendix A
A1.10	Operating Limit	2,000 tons of black liquor solids (TBLS)/day, monthly average	Report average daily (black liquor solids) BLS production in tons in monthly report (See Appendix ApA.1).	PSD 01-03, Amendment 3, Condition 1.14
A1.11	HAPs	N/A	The Permittee must maintain proper operation of the electrostatic precipitator's automatic voltage control (AVC).  The Permittee must maintain records demonstrating compliance with the requirement to maintain proper operation of an electrostatic precipitator AVC.	40 CFR 63.864(e)(1) for AVC requirement  40 CFR 63.866(c)(8) for recordkeeping

<b>RF19</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
A1.12	VOC (as carbon)	1,020 tpy, 12 month rolling total	<p>Sample triennially using RM 25A (see Appendix ApA.2). Calculate per Appendix ApA.3.</p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p>Report 12-month total monthly.</p>	PSD 01-03, Amendment 3, Condition 1.20
A1.13	Annual Heat Input	Fossil fuel annual heat input <10% potential annual heat input from all fuels.	<p>The annual heat input from fossil fuels shall be less than 10 percent of the potential annual heat input from all fuels. Compliance shall be determined by procedures in 40 CFR 60.45b. Fuel oil with a sulfur content greater than 0.5 percent may not be burned except during emergency conditions, such as a malfunction in the natural gas supply line serving the area of the mill. During such conditions oil with a sulfur content greater than 0.5 percent shall only be burned during startups, shutdowns, or to burnout a high bed. When oil is burned under non-emergency conditions then the Permittee shall demonstrate low sulfur oil content firing by keeping a record of the times, volumes, sulfur content, and fuel receipts from the fuel supplier, which certify that the oil meets the fuel sulfur limit. Tall oil with sulfur content not to exceed 0.5 percent sulfur by weight may be substituted for fuel oil.</p>	Order 3462-AQ07, Modification 1, Condition 3

RF19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A1.14	Exhaust Gas Flow Equation Update	N/A	<p>At least annually, the Permittee shall update equations for calculation of exhaust gas flow.</p> <ol style="list-style-type: none"> <li>1) The equations shall correlate exhaust stack flows to process rate from the emissions unit. The correlation shall be based on linear regression analysis.</li> <li>2) By January 31 or each year, the Permittee shall submit the updated equations, the data on which they are based, and the regression analyses to Ecology for approval.</li> <li>3) The Permittee may submit proposed updates more frequently at its option. An update for an emissions unit shall have occurred only when new data are submitted.</li> <li>4) For emissions units operated 6,000 hour or more since the last update, each update shall include at least 12 hours of new data, and drop an equal amount of the oldest data. For emission unity operated less than 6,000 hour since the last update, the minimum hours of new data (and dropped oldest data) shall be:   <math display="block">(\text{Hours of operation since last update}) \times 12 \div 6,545, \text{ rounded to the nearest whole number.}</math> </li> </ol> <p>The updated equations shall take effect upon approval from Ecology.</p>	PSD 01-03, Amendment 3, Condition 2

**The following state-only requirement is not federally enforceable under the federal Clean Air Act.**

<b>RF19</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
A1.15	TRS	17.5 ppm <sub>dv</sub> @ 8% O <sub>2</sub> , daily average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-5.</p> <p>Report exceedances monthly.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p>	WAC 173-405-040(1)(b)



## **A2. RECOVERY FURNACE 22 (RF22)**

The emission unit shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 of Subpart MM.

The emission unit shall comply with the requirements of 40 CFR Part 60, Subpart BB. The source shall also comply with the General Requirements of 40 CFR Part 60, including:

- 40 CFR 60.7(b) & (f) concerning recordkeeping,
- 40 CFR 60.7(c), (d), & (e) concerning reporting,
- 40 CFR 60.11(d) concerning operation and maintenance,
- 40 CFR 60.12 concerning concealment,
- 40 CFR 60.13 concerning monitoring,
- 40 CFR 60.19 concerning notification and reporting.

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A2.1a	PM & PM <sub>10</sub>	0.027gr/dscf @ 8% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i></p> <p>Sample M/Q using RM 5 (see Appendix ApA.2).</p> <p>During source tests for PM and PM<sub>10</sub> on all recovery furnaces, primary voltage, primary current, opacity, and spark rate for the electrostatic precipitator shall be recorded for each field once during each source test. In addition, secondary voltage and secondary current data shall also be collected once during each source test when available. All precipitator data shall be maintained on file with corresponding test data. Precipitator data shall be submitted to Ecology when the PM and PM<sub>10</sub> source test results exceed the permit limit. The department may modify or waive this requirement.</p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i></p> <p>The Permittee shall comply with the general CAM requirements in Condition M. The Permittee must comply with the monitoring and corrective action requirements in Condition A2.5. The Permittee shall implement corrective action if the average of ten consecutive 6-minute averages result in a measurement greater than 20 percent opacity.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.22</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

<b>RF22</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
A2.1b	PM	0.10 gr/dscf @ 8% O <sub>2</sub> , 1-hr average	Same as for previous limit. CAM demonstration same as previous limits.	WAC 173-405-040(1)(a) 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A2.1c	PM	0.044 gr/dscf @ 8% O <sub>2</sub>	<p><i>Performance Testing:</i></p> <p>Sample M/Q using EPA RM 5 in accordance with 40 CFR 60.8 except as provided below.</p> <p>The sampling time and sample volume for each run shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used as the cleanup solvent instead of acetone in the sample recovery procedure. The particulate concentration shall be corrected to the appropriate oxygen concentration according to 40 CFR 60.284(c)(3).</p> <p>Emission rate to be calculated using the procedures in 40 CFR 60.285(c).</p> <p><i>30-day Notification:</i></p> <p>The Permittee shall provide Ecology at least 30 days prior notice of any performance test.</p> <p><i>Reporting:</i></p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i></p> <p>The Permittee shall comply with the general CAM requirements in Condition M. The Permittee shall comply with requirements in Condition A2.5.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>40 CFR 60.282(a)(1)(i) for standards</p> <p>40 CFR 60.285(b)(1) for test method and procedures</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A2.1d	PM & PM <sub>10</sub>	256 tons per year, 12 month rolling total	<p>Calculate per Appendix ApA.3. Report monthly.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M. The Permittee comply with the monitoring and corrective action requirements in Condition A2.5. The Permittee shall implement corrective action if the average of ten consecutive 6-minute averages result in a measurement greater than 20 percent opacity.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.22</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
A2.2	HAP Metals (PM as surrogate)	0.044 gr/dscf @ 8% O <sub>2</sub>	<p><i>Performance Testing:</i></p> <p>Sample every 5 years using EPA RM 5. First periodic performance test must be conducted by October 13, 2020 and within 5 years thereafter following the previous performance test. The sampling time and sample volume for each run shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used as the cleanup solvent instead of acetone in the sample recovery procedure.</p> <p><i>Representative Conditions:</i></p> <p>Performance tests shall be conducted based on representative performance during the period being tested. The owner/operator must record the process information that is necessary to document operating conditions during the test and include such record and explanation to support that such conditions represent normal operation. Upon request, the owner/operator shall make available such records as may be necessary to determine the conditions of performance test.</p> <p><i>60-day notification:</i></p>	<p>40 CFR 63.862(a)(1)(i)(A) for standard</p> <p>40 CFR 63.863(c)(1) for 5-year periodic performance test compliance date</p> <p>40 CFR 63.865 for performance testing requirements</p> <p>40 CFR 63.9(e) and 40 CFR 63.7(b) for performance test notification</p> <p>40 CFR 63.866 for recordkeeping</p> <p>40 CFR 63.867(c)(4) for excess emission reporting</p>

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>The Permittee must notify Ecology in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is initially scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) All results of performance tests;</li> <li>2) The process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation;</li> <li>3) Documentation of supporting calculations for compliance determinations made under 40 CFR 63.865(a) through (d);</li> <li>4) For each failure to meet the emission limit, the number of failures, the date, start time, and duration of each event;</li> <li>5) For any failure to meet the emission limit, record an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions.</li> </ol> <p><i>On-going compliance:</i></p> <p>On-going compliance demonstrated through Condition A2.5.</p> <p><i>Reporting:</i></p> <p>Report failures to meet the applicable standard in the <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c)(4), delivered or postmarked by the 30th day following the end of each calendar half..</p> <p>Within 60 days after the date of completing each performance test, submit the results of the performance test electronically via EPA's</p>	<p>and (d) for electronic reporting</p>

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with 40 CFR 63.867(d).</p> <p>Submit source test results in the monthly air report, due after results received by the Permittee.</p>	
A2.3a	Opacity	Opacity greater than 20% for 2% or more of operating time during a semiannual period	<p><i>Monitoring:</i></p> <p>Monitoring continuously using a COMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS 1.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p><i>Exceedances:</i></p> <p>An exceedance has occurred when the average of ten consecutive 6-minute averages result in a measurement of greater than 20 percent opacity. The Permittee must implement corrective action following an exceedance.</p> <p><i>Violation Determination:</i></p> <p>A violation occurs when opacity is greater than 20 percent for 2 percent or more of operating time during a semi-annual period while spent pulping liquor is fed.</p> <p><i>Reporting:</i></p> <p>Report daily maximum six-minute average opacity, daily maximum hourly average opacity, and exceedances monthly. Semi-annually report percent of operating time during a semi-annual period that opacity exceeded 20 percent.</p>	Order 3462-AQ07, Modification 1, Appendix A

<b>RF22</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
A2.3b	Opacity	35% average for more than 6 consecutive minutes in any 60-minute period.	<p>EPA Method 9 is the reference test method.</p> <p>Monitor continuously using a COMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, Performance Specification 1.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report daily maximum six-minute average opacity, daily average opacity, and exceedances monthly.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M. CAM reporting required on at a minimum semiannual basis.</p>	<p>WAC 173-405-040(6)</p> <p>WAC 173-401-615 for monitoring</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>



RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A2.4	PM (Opacity as surrogate)	35% opacity (six minute average) for six percent of total possible contiguous periods of excess emission in quarter	<p><i>Monitoring:</i></p> <p>Monitor continuously using a COMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-1. Span of the system shall be set at 70 percent opacity.</p> <p>See Facility-wide General Requirement, Condition 27 for CMS data recovery requirements.</p> <p><i>Violation Determination:</i></p> <p>The percent of the total number of possible contiguous periods of excess emissions in a quarter (excluding periods of startup, shutdown, or malfunction and periods when the facility is not operating) during which excess emissions occur exceeding six percent of average opacities is indicative of a violation of §60.11(d).</p> <p><i>Reporting:</i></p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 60.7(c) and 40 CFR 60.284(d), postmarked by the 30th day following the end of each six-month period (or on a more frequent basis in accordance with the criteria in 40 CFR 60.7(c)).</p> <p>Excess emissions are 6-minute average opacities which exceed 35%.</p>	<p>40 CFR 60.282(a)(1)(ii) for opacity limit</p> <p>40 CFR 60.284(a)(1) for monitoring</p> <p>40 CFR 60.284(e) for determining compliance with §60.11</p> <p>40 CFR 60.284(d) for semiannual reporting of excess emissions</p>
A2.5	HAP Metals (Opacity as surrogate) Operating Limit	Opacity greater than 35% for 2% or more of operating time during a	<p><i>Monitoring:</i></p> <p>Monitoring opacity using a COMS which is installed, calibrated, maintained, and operated in accordance with PS-1 in Appendix B to 40 CFR Part 60 and the provisions in §63.6(h) and 63.8 and §63.864(d)(3) and (4).</p>	<p>40 CFR 63.864 for monitoring requirements</p> <p>40 CFR 63.864(k) for ongoing compliance and violation determination</p>

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
		semiannual period.	<p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Monitoring Exceedances:</i></p> <p>The Permittee is required to implement corrective action if the average of ten consecutive 6-minute averages result in a measurement greater than 20 percent opacity.</p> <p><i>Violation Determination:</i></p> <p>A violation of the underlying particulate matter standard in A2.2 occurs when opacity is greater than 35 percent for 2 percent or more of operating time during a semiannual period while spent pulping liquor is fed.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) Black liquor solids firing rates in units of Mg/d or ton/d;</li> <li>2) Any occurrence when corrective action is required and when a violation is noted;</li> <li>3) For each failure to meet the opacity operating limit, the number of failures, the date, start time, and duration of each event;</li> <li>4) For each failure to meet the operating limit, an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions;</li> <li>5) Record actions taken to minimize emissions in accordance with §63.860(d) and any corrective actions taken to return the affected unit to its normal or usual manner of operation.</li> </ol> <p><i>Reporting:</i></p> <p>Report exceedances monthly to Ecology.</p>	<p>40 CFR 63.866 for recordkeeping requirements</p> <p>40 CFR 63.867(c) for excess emission reporting requirements</p>

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c), delivered or postmarked by the 30th day following the end of each calendar half.	
A2.6a	SO <sub>2</sub>	295 lb/hr, 3-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-2.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report 3-hr average concentrations, monthly average concentration, maximum monthly 3-hr average concentration, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.23
A2.6b	SO <sub>2</sub>	500 ppm @ 8% O <sub>2</sub> , 1-hr average	<p>Same as for previous limit.</p> <p>Report maximum monthly 1-hr average concentration in ppm corrected to 8% O<sub>2</sub> monthly.</p>	WAC 173-405-040(9)(a)
A2.6c	SO <sub>2</sub>	1,291 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.23
A2.7a	TRS (as H <sub>2</sub> S)	3.0 ppm <sub>dv</sub> @ 8% O <sub>2</sub> , 12-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-5.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report daily maximum concentrations, 12-hr average concentrations, monthly average concentrations, maximum monthly 12-hr concentrations, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.26

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A2.7b	TRS (as H <sub>2</sub> S)	5 ppmdv @ 8% O <sub>2</sub> (12-hr average) for more than one percent of the total possible contiguous periods of excess emissions in a quarter	<p>Same as above.</p> <p>CEMS span to be set to 30 ppm TRS.</p> <p>See Facility-wide General Requirement, Condition 27 for CMS data recovery requirements.</p> <p>Calculate and record on a daily basis 12-hour average TRS and oxygen (pursuant to Condition A2.10) concentration for two consecutive periods of each operating day. Each 12-hour average shall be determined as the arithmetic mean of the appropriate 12 contiguous 1-hour average TRS concentrations provided by the CEMS using the following equation:</p> $C_{corr} = C_{meas} \times (21 - X) / (21 - Y)$ <p>where:</p> <p><i>C<sub>corr</sub></i> = the concentration corrected for oxygen.</p> <p><i>C<sub>meas</sub></i> = the concentration uncorrected for oxygen.</p> <p><i>X</i> = the volumetric oxygen concentration in percentage to be corrected to (8 percent for recovery furnaces and 10 percent for lime kilns, incinerators, or other devices).</p> <p><i>Y</i> = the measured 12-hour average volumetric oxygen concentration.</p> <p>Periods of excess emissions reported under paragraph (d) of 40 CFR 60.284 are not indicative of a violation of §60.11(d) provided that the percent of the total number of possible contiguous periods of excess emissions in a quarter (excluding periods of startup, shutdown, or malfunction and periods when the facility is not operating) during which excess emissions occur does not exceed one percent for TRS emissions.</p> <p><i>Reporting:</i></p>	<p>40 CFR 60.284 for monitoring requirements</p> <p>40 CFR 60.284(e) for determining compliance with §60.11</p> <p>40 CFR 60.284(d) for semiannual reporting of excess emissions</p>

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 60.7(c) and 40 CFR 60.284(d), postmarked by the 30th day following the end of each six-month period (or on a more frequent basis in accordance with the criteria in 40 CFR 60.7(c)).</p> <p>Excess emissions are 12-hr averages of TRS concentrations above 5 ppm by volume corrected to 8% O<sub>2</sub>.</p>	
A2.7c	TRS (as H <sub>2</sub> S)	17 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.26
A2.8a	CO	300 ppmv @ 8% O <sub>2</sub> , 8-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-4.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system operating requirements.</p> <p>Report 8-hr average concentrations, monthly average concentration, maximum monthly 8-hr average concentration, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.24
A2.8b	CO	1,380 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.24

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A2.9a	NO <sub>x</sub>	95 ppm <sub>dv</sub> @ 8% O <sub>2</sub> , 24-hr average	<p>Monitor continuously using a CEMS in accordance with 40 CFR Part 60, Appendix F and Appendix B, PS-2.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system operating requirements.</p> <p>Report 24-hr average concentrations, monthly average concentration, maximum monthly 24-hr average concentration, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.25
A2.9b	NO <sub>x</sub>	735 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.25
A2.10	O <sub>2</sub>	No limit – required for O <sub>2</sub> correction	<p>Monitor and record the percent oxygen by volume on a dry basis, using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-3.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Calculate and record on a daily basis 12-hour average oxygen concentrations for the two consecutive periods of each operating day.</p>	<p>Order 3462-AQ07, Modification 1, Appendix A</p> <p>40 CFR 60.284(a)(2) for monitoring requirement</p> <p>40 CFR 60.284(c)(2) for recording requirement</p>
A2.11	Operating Limit	1,950 TBLS/day, monthly average	Report average daily BLS production in tons in monthly report (See Appendix ApA.1).	PSD 01-03, Amendment 3, Condition 1.21

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A2.12	HAPs	N/A	<p>The Permittee must maintain proper operation of the electrostatic precipitator's automatic voltage control (AVC).</p> <p>The Permittee must maintain records demonstrating compliance with the requirement to maintain proper operation of an electrostatic precipitator AVC.</p>	<p>40 CFR 63.864(e)(1) for AVC requirement</p> <p>40 CFR 63.866(c)(8) for recordkeeping</p>
A2.13	Annual Heat Input	Fossil fuel annual heat input <10% potential annual heat input from all fuels.	<p>The annual heat input from fossil fuels shall be less than 10 percent of the potential annual heat input from all fuels. Compliance shall be determined by procedures in 40 CFR 60.45b. Fuel oil with a sulfur content greater than 0.5 percent may not be burned except during emergency conditions, such as a malfunction in the natural gas supply line serving the area of the mill. During such conditions oil with a sulfur content greater than 0.5 percent shall only be burned during startups, shutdowns, or to burnout a high bed. When oil is burned under non-emergency conditions then the Permittee shall demonstrate low sulfur oil content firing by keeping a record of the times, volumes, sulfur content, and fuel receipts from the fuel supplier which certify that the oil meets the fuel sulfur limit. Tall oil with sulfur content not to exceed 0.5 percent sulfur by weight may be substituted for fuel oil.</p>	Order 3462-AQ07, Modification 1, Condition 3

RF22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
A2.14	Exhaust Gas Flow Equation Update	N/A	<p>At least annually, the Permittee shall update equations for calculation of exhaust gas flow.</p> <ol style="list-style-type: none"> <li>1) The equations shall correlate exhaust stack flows to process rate from the emissions unit. The correlation shall be based on linear regression analysis.</li> <li>2) By January 31 or each year, the Permittee shall submit the updated equations, the data on which they are based, and the regression analyses to Ecology for approval.</li> <li>3) The Permittee may submit proposed updates more frequently at its option. An update for an emissions unit shall have occurred only when new data are submitted.</li> <li>4) For emissions units operated 6,000 hour or more since the last update, each update shall include at least 12 hours of new data, and drop an equal amount of the oldest data. For emission unity operated less than 6,000 hour since the last update, the minimum hours of new data (and dropped oldest data) shall be:   <math display="block">(\text{Hours of operation since last update}) \times 12 \div 6,545, \text{ rounded to the nearest whole number.}</math> </li> </ol> <p>The updated equations shall take effect upon approval from Ecology.</p>	PSD 01-03, Amendment 3, Condition 2



**The following state-only requirement is not federally enforceable under the federal Clean Air Act.**

<b>RF22</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
A2.15	TRS	5.0 ppm <sub>dv</sub> @ 8% O <sub>2</sub> , daily average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-5.</p> <p>Report exceedances monthly.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p>	WAC 173-405-040(1)(c)

**B1. SMELT DISSOLVER TANK 19 (SDT19)**

The emission unit shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 of Subpart MM.

Opacity limits apply to each stack individually. All other limits apply to the total emissions from the combined stacks.

SDT19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
B1.1a	PM & PM <sub>10</sub>	0.12 lb/TBLS, 1-hr average	<p><i>Performance Testing:</i> Sample M/Q using RM 5 (see Appendix ApA.2).</p> <p><i>Reporting:</i> Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i> The Permittee shall comply with the general CAM requirements in Condition M. The Permittee shall implement corrective action when any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" in Appendix B is not met.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.40</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
B1.1b	PM	0.30 lb/TBLS, 1-hr average	Same as for previous limit.	<p>WAC 173-405-040(2)</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

SDT19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
B1.1c	PM & PM <sub>10</sub>	44 tons per year, 12 month rolling total	Calculate per Appendix ApA.3. Report monthly. CAM demonstration same as previous limits.	PSD 01-03, Amendment 3, Condition 1.40 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
B1.2	HAP Metals (PM as surrogate)	0.20 lb/TBLS (0.10 kg/Mg of black liquor solids fired)	<p><i>Performance Testing:</i></p> <p>Sample every 5 years using EPA RM 5. First periodic performance test must be conducted by October 13, 2020 and within 5 years thereafter following the previous performance test. The sampling time and sample volume for each run shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used as the cleanup solvent instead of acetone in the sample recovery procedure.</p> <p><i>Representative Conditions:</i></p> <p>Performance tests shall be conducted based on representative performance during the period being tested. The owner/operator must record the process information that is necessary to document operating conditions during the test and include such record and explanation to support that such conditions represent normal operation. Upon request, the owner/operator shall make available such records as may be necessary to determine the conditions of the performance test.</p> <p><i>60-day notification:</i></p> <p>The Permittee must notify Ecology in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is initially scheduled to begin.</p>	<p>40 CFR 63.862(a)(1)(i)(B) for standard</p> <p>40 CFR 63.865 for performance testing requirements</p> <p>40 CFR 63.9(e) and 40 CFR 63.7(b) for performance test notification</p> <p>40 CFR 63.866 for recordkeeping</p> <p>40 CFR 63.867(c)(4) for reporting excess emissions and (d) for electronic reporting</p>

SDT19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) All results of performance tests;</li> <li>2) The process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation;</li> <li>3) Documentation of supporting calculations for compliance determinations made under 40 CFR 63.865(a) through (d);</li> <li>4) For each failure to meet the emission limit, the number of failures, the date, start time, and duration of each event;</li> <li>5) For any failure to meet the emission limit, record an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions.</li> </ol> <p><i>On-going compliance:</i></p> <p>On-going compliance demonstrated through Condition B1.4.</p> <p><i>Reporting:</i></p> <p>Report failures to meet the applicable standard in the <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c)(4), delivered or postmarked by the 30th day following the end of each calendar half.</p> <p>Within 60 days after the date of completing each performance test, submit the results of the performance test electronically via EPA's Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with 40 CFR 63.867(d).</p>	

SDT19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			Submit source test results in the monthly air report, due after results received by the Permittee.	
B1.3a	Opacity	20 % average for more than 6 consecutive minutes in any 60 minute period (limit is applicable to each stack individually)	<p>Emission control parameter monitoring is required when exhaust gases are being emitted from the smelt dissolving tank vent during combustion in the associated recovery furnace. Maintain emission control parameters at levels specified in the "Emission Control Compliance Demonstration Plan" (see Appendix B).</p> <p>Continuously monitor parameters specified in the plan. Continuously monitor the explosion dampers.</p> <p>Check explosion dampers and spout box doors at least once per shift to assure they are closed.</p> <p>Whenever any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met, corrective action must be initiated within 24 hours. Failure to initiate corrective action within 24 hours is a violation of WAC 173-405-040(8) and may be a violation of the underlying applicable requirement. Report deviations from these operating parameters that last longer than 3 hours and corrective action in the monthly report.</p> <p>Compliance may also be determined by RM 9.</p>	<p>Order 3462-AQ07, Modification 1, Appendix A</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

SDT19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
B1.3b	Opacity	35% average for more than 6 consecutive minutes in any 60 minute period (limit applies to each stack individually)	<p>EPA Method 9 is the reference test method.</p> <p>Continuous monitoring same as above.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>WAC 173-405-040(6)</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
B1.4	HAP Metals (Scrubber Operating Limit as surrogate)	Five monitoring parameter values for either pressure drop across the scrubber or scrubbing liquid flowrate below the minimum operating limits during any semiannual reporting period	<p><i>Monitoring:</i></p> <p>The Permittee must calibrate, maintain, and operate a continuous parametric monitoring system (CPMS) that can be used to determine and record the pressure drop across the scrubber and the scrubbing liquid flow rate at least once every successive 15-minute period using the procedures in 40 CFR 63.8(c), as well as the procedures in 40 CFR 63.864(e)(10)(i) and (ii).</p> <p>The Permittee must establish operating limits for pressure drop across the scrubber and the scrubbing liquid flow rate based on performance testing in accordance with 40 CFR 63.864(j).</p> <p>Operating limits for pressure drop and scrubber flow rate have been established/specified in the “Emission Control Compliance Demonstration Plan” (Appendix B).</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Monitoring Exceedances:</i></p>	<p>40 CFR 63.864 for monitoring requirements</p> <p>40 CFR 63.864(j) for determination of operating limits</p> <p>40 CFR 63.864(k) for ongoing compliance and violation determination</p> <p>40 CFR 63.866 for recordkeeping requirements</p> <p>40 CFR 63.867(c) for excess emission reporting requirements</p>

SDT19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>The Permittee is required to implement corrective action when any 3-hr average parameter value is below the minimum operating limit established during times when spent pulping liquor is fed, with the exception of pressure drop during startup and shutdown.</p> <p><i>Violation Determination:</i></p> <p>A violation of the underlying particulate matter standard in Condition B1.2 occurs when six or more 3-hour average parameter values within any 6-month reporting period are below the minimum operating limits established, with the exception of pressure drop during startup and shutdown.</p> <p>For purposes of determining the number of monitoring exceedances, no more than one exceedance will be attributed to any given 24-hour period.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) Any occurrence when corrective action is required and when a violation is noted;</li> <li>2) Records of parameter monitoring data required under §63.864, including any period when the operating parameter levels were inconsistent with the levels established during the performance test, with a brief explanation of the cause of the monitoring exceedance, the time the monitoring exceedance occurred, the time corrective action was initiated and completed, and the corrective action taken;</li> <li>3) Records of parameter operating limits established for each affected source or process unit;</li> <li>4) For each failure to meet the operating limits, the number for failures, date, start time, and duration of each event;</li> <li>5) For each failure to meet an operating limit, maintain sufficient information to estimate the quantity of each regulated pollutant emitted over the emission limit. This information must be sufficient to</li> </ol>	

SDT19	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>provide a reliable emissions estimate if requested by the Administrator.</p> <p>6) Record actions taken to minimize emissions in accordance with §63.860(d) and any corrective actions taken to return the affected unit to its normal or usual manner of operation;</p> <p><i>Reporting:</i></p> <p>Report monitoring exceedances monthly to Ecology.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c), delivered or postmarked by the 30th day following the end of each calendar half.</p>	
B1.5a	SO <sub>2</sub>	1,000 ppm, 1-hr average	<p>Sample T/M using RM 6C.</p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p>	WAC 173-405-040(9)(b)
B1.5	SO <sub>2</sub>	16 tpy, 12-month rolling total	<p>Same as previous limit.</p> <p>Calculate per Appendix ApA.3. Report monthly.</p>	PSD 01-03, Amendment 3, Condition 1.41
B1.6	TRS (as H <sub>2</sub> S)	114 tpy, 12-month rolling total	<p>Sample T/M using RM 16 (see Appendix ApA.2).</p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p>Calculate per Appendix ApA.3. Report monthly.</p>	PSD 01-03, Amendment 3, Condition 1.44



<b>SDT19</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
B1.7	CO	66 tpy, 12-month rolling total	Sample T/M using RM 10 (see Appendix ApA.2). Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements. Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.42
B1.8	NOx	11 tpy, 12-month rolling total	Sample T/M using RM 7 (see Appendix ApA.2). Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements. Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.43
B1.9	Operating Limit	2,000 TBLS/day, monthly average	Report average daily BLS production in tons in monthly report (See Appendix ApA.1).	PSD 01-03, Amendment 3, Condition 1.39

**B2.SMELT DISSOLVER TANK 22 (SDT22)**

The emission unit shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 of Subpart MM.

This source shall comply with the requirements of 40 CFR Part 60, Subpart BB. The source shall also comply with the General Requirements of 40 CFR Part 60, including:

- 40 CFR 60.7(b) & (f) concerning recordkeeping,
- 40 CFR 60.7(c), (d), & (e) concerning reporting,
- 40 CFR 60.11(d) concerning operation and maintenance,
- 40 CFR 60.12 concerning concealment,
- 40 CFR 60.13 concerning monitoring,
- 40 CFR 60.19 concerning notification and reporting.

SDT22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
B2.1a	PM & PM <sub>10</sub>	0.12 lb/TBLS, 1-hr average	<p><i>Performance Testing:</i> Sample M/Q using RM 5 (see Appendix ApA.2).</p> <p><i>Reporting:</i> Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i> The Permittee shall comply with the general CAM requirements in Condition M. The Permittee shall implement corrective action when any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met.  CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.40</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

SDT22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
B2.1b	PM	0.30 lb/TBLS, 1-hr average	Same as for previous limit.	WAC 173-405-040(2)  40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
B2.1c	PM	0.2 lb/TBLS (dry weight), 1-hr average	<p><i>Performance Testing:</i></p> <p>Sample M/Q using RM 5 in accordance with 40 CFR 60.8 except as provided in 40 CFR 60.285.</p> <p>The sampling time and sample volume for each run shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used as the cleanup solvent instead of acetone in the sample recovery procedure. The particulate concentration shall be corrected to the appropriate oxygen concentration according to 40 CFR 60.284(c)(3).</p> <p>Emission rate to be calculated using the procedures in 40 CFR 60.285(c).</p> <p><i>30-day Notification:</i></p> <p>The Permittee shall provide Ecology at least 30 days prior notice of any performance test.</p> <p><i>Reporting:</i></p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p>	<p>40 CFR 60.282(a)(2) for standards</p> <p>40 CFR 60.285(b)(1) for test method and procedures</p> <p>40 CFR 60.284(b)(2) for continuous monitoring requirement</p> <p>40 CFR 60.284(c)(4) for recordkeeping requirements</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and</p>

SDT22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p><i>Monitoring:</i></p> <p>The Permittee must install a monitoring device for the continuous measurement of pressure loss of the gas stream through the control equipment and scrubbing liquid supply pressure in accordance with 40 CFR 60.284(b)(2).</p> <p>The Permittee must record, once per shift, measurements obtained from continuous monitoring devices required by 40 CFR 60.284(b)(2).</p> <p><i>Compliance Assurance Monitoring:</i></p> <p>The Permittee shall comply with the general CAM requirements in Condition M. The Permittee shall comply with requirements in Condition B2.4.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	reporting/recordkeeping
B2.1d	PM & PM <sub>10</sub>	44 tons per year, 12 month rolling total	<p>Calculate per Appendix ApA.3. Report monthly.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M. The Permittee shall implement corrective action when any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.46</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
B2.2	HAP Metals (PM as a surrogate)	0.20 lb/TBLS (0.10 kg/Mg of black liquor solids fired)	<p><i>Performance Testing:</i></p> <p>Sample every 5 years using EPA RM 5. First periodic performance test must be conducted by October 13, 2020 and within 5 years thereafter following the previous performance test. The sampling time and sample volume for each run shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used as the cleanup solvent instead of acetone in the sample recovery procedure.</p>	<p>40 CFR 63.862(a)(1)(i)(B) for standard</p> <p>40 CFR 63.865 for performance testing requirements</p>

SDT22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p><i>Representative Conditions:</i></p> <p>Performance tests shall be conducted based on representative performance during the period being tested. The owner/operator must record the process information that is necessary to document operating conditions during the test and include such record and explanation to support that such conditions represent normal operation. Upon request, the owner/operator shall make available such records as may be necessary to determine the conditions of the performance test.</p> <p><i>60-day notification:</i></p> <p>The Permittee must notify Ecology in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is initially scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) All results of performance tests;</li> <li>2) The process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation;</li> <li>3) Documentation of supporting calculations for compliance determinations made under 40 CFR 63.865(a) through (d);</li> <li>4) For each failure to meet the emission limit, the number of failures, the date, start time, and duration of each event;</li> <li>5) For any failure to meet the emission limit, record an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions.</li> </ol> <p><i>On-going compliance:</i></p>	<p>40 CFR 63.9(e) and 40 CFR 63.7(b) for performance test notification</p> <p>40 CFR 63.866 for recordkeeping</p> <p>40 CFR 63.867(c)(4) for excess emissions reporting and (d) for electronic reporting</p>

SDT22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>On-going compliance demonstrated through Condition B2.4.</p> <p><i>Reporting:</i></p> <p>Report failures to meet the applicable standard in the <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c)(4), delivered or postmarked by the 30th day following the end of each calendar half.</p> <p>Within 60 days after the date of completing each performance test, submit the results of the performance test electronically via EPA's Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with 40 CFR 63.867(d).</p> <p>Submit source test results in the monthly air report, due after results received by the Permittee.</p>	

SDT22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
B2.3a	Opacity	20 % average for more than 6 consecutive minutes in any 60 minute period	<p>Emission control parameter monitoring is required when exhaust gasses are being emitted from the smelt dissolving tank vent during combustion in the associated recovery furnace. Maintain emission control parameter hourly average rates at levels specified in the "Emission Control Compliance Demonstration Plan" (see Appendix B).</p> <p>Continuously monitor parameters specified in the plan. Continuously monitor the explosion dampers.</p> <p>Check explosion dampers and spout box doors at least once per shift to assure they are closed.</p> <p>Whenever any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met, corrective action must be initiated within 24 hours. Failure to initiate corrective action within 24 hours is a violation of WAC 173-405-040(8) and may be a violation of the underlying applicable requirement. Report deviations from these operating parameters that last longer than 3 hours and corrective action in the monthly report.</p> <p>Compliance may also be determined by RM 9.</p>	<p>Order 3462-AQ07, Modification 1, Appendix A</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
B2.3b	Opacity	35% average for more than 6 consecutive minutes in any 60-minute period.	<p>EPA Method 9 is the reference test method.</p> <p>Continuous monitoring same as above.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>WAC 173-405-040(6)</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

SDT22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
B2.4	HAP Metals (Scrubber Operating Limit as a surrogate)	Five monitoring parameter values for either pressure drop across the scrubber or scrubbing liquid flowrate below the minimum operating limits during any semiannual reporting period	<p><i>Monitoring:</i></p> <p>The Permittee must calibrate, maintain, and operate a CPMS that can be used to determine and record the pressure drop across the scrubber and the scrubbing liquid flow rate at least once every successive 15-minute period using the procedures in 40 CFR 63.8(c), as well as the procedures in 40 CFR 63.864(e)(10)(i) and (ii).</p> <p>The Permittee must establish operating limits for pressure drop across the scrubber and the scrubbing liquid flow rate based on performance testing in accordance with 40 CFR 63.864(j).</p> <p>Operating limits for pressure drop and scrubber flow rate have been established/specified in the “Emission Control Compliance Demonstration Plan” (Appendix B).</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Monitoring Exceedances:</i></p> <p>The Permittee is required to implement corrective action when any 3-hr average parameter value is below the minimum operating limit established during times when spent pulping liquor is fed, with the exception of pressure drop during startup and shutdown.</p> <p><i>Violation Determination:</i></p> <p>A violation of the underlying particulate matter standard in Condition B2.2 occurs when six or more 3-hour average parameter values within any 6-month reporting period are below the minimum operating limits established, with the exception of pressure drop during startup and shutdown.</p> <p>For purposes of determining the number of monitoring exceedances, no more than one exceedance will be attributed to any given 24-hour period.</p>	<p>40 CFR 63.864 for monitoring requirements</p> <p>40 CFR 63.864(j) for determination of operating limits</p> <p>40 CFR 63.864(k) for ongoing compliance and violation determination</p> <p>40 CFR 63.866 for recordkeeping requirements</p> <p>40 CFR 63.867(c) for excess emission reporting requirements</p>



SDT22	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) Any occurrence when corrective action is required and when a violation is noted;</li> <li>2) Records of parameter monitoring data required under §63.864, including any period when the operating parameter levels were inconsistent with the levels established during the performance test, with a brief explanation of the cause of the monitoring exceedance, the time the monitoring exceedance occurred, the time corrective action was initiated and completed, and the corrective action taken;</li> <li>3) Records of parameter operating limits established for each affected source or process unit;</li> <li>4) For each failure to meet the operating limits, the number for failures, date, start time, and duration of each event;</li> <li>5) For each failure to meet an operating limit, maintain sufficient information to estimate the quantity of each regulated pollutant emitted over the emission limit. This information must be sufficient to provide a reliable emissions estimate if requested by the Administrator.</li> <li>6) Record actions taken to minimize emissions in accordance with §63.860(d) and any corrective actions taken to return the affected unit to its normal or usual manner of operation;</li> </ol> <p><i>Reporting:</i></p> <p>Report monitoring exceedances monthly to Ecology.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance</i> or <i>Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c), delivered or postmarked by the 30th day following the end of each calendar half.</p>	

<b>SDT22</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
B2.5a	SO <sub>2</sub>	1,000 ppm, 1-hr avg	Sample T/M using RM 6C. Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	WAC 173-405-040(9)(b)
B2.5	SO <sub>2</sub>	31 tpy, 12-month rolling total	Same as previous limit. Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.47
B2.6a	TRS (as H <sub>2</sub> S)	0.0168 lb/TBLS, 24-hr average	Sample T/M using RM 16 (see Appendix ApA.2). Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.50
B2.6b	TRS (as H <sub>2</sub> S)	0.033 lb/TBLS	Same as for previous limit.	40 CFR 60.283(a)(4)
B2.6c	TRS (as H <sub>2</sub> S)	6 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.50
B2.7	CO	65 tpy, 12-month rolling total	Sample T/M using RM 10 (see Appendix ApA.2). Calculate per Appendix ApA.3. Report monthly. Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.48

<b>SDT22</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
B2.8	NO <sub>x</sub>	11 tpy, 12-month rolling total	Sample T/M using RM 7 (see Appendix ApA.2). Calculate per Appendix ApA.3. Report monthly.  Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.49
B2.9	Operating Limit	1,950 TBLS/day, monthly average	Report average daily BLS production in tons in monthly report (See Appendix ApA.1).	PSD 01-03, Amendment 3, Condition 1.45

**C1. LIME KILN 3 (LK3)**

The emission unit shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 of Subpart MM.

LK3	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C1.1a	PM & PM <sub>10</sub>	0.030 gr/dscf @ 10% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i> Sample M/Q using RM 5 (see Appendix ApA.2).</p> <p><i>Reporting:</i> Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i> The Permittee shall comply with the general CAM requirements in Condition M. The Permittee shall implement corrective action when any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met. CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.58</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
C1.1b	PM	0.13 gr/dscf @ 10% O <sub>2</sub> , 1-hr average	Same as previous limit.	<p>WAC 173-405-040(3)(a)</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

LK3	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C1.1c	PM & PM <sub>10</sub>	34 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly. CAM demonstration same as previous limits.	PSD 01-03, Amendment 3, Condition 1.58  40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
C1.2	HAP Metals (PM as a surrogate)	0.064 gr/dscf (0.15 g/dscm) @10% O <sub>2</sub>	<p><i>Performance Testing:</i></p> <p>Sample every 5 years using EPA RM 5. First periodic performance test must be conducted by October 13, 2020 and within 5 years thereafter following the previous performance test.</p> <p><i>Representative Conditions:</i></p> <p>Performance tests shall be conducted based on representative performance during the period being tested. The owner/operator must record the process information that is necessary to document operating conditions during the test and include such record and explanation to support that such conditions represent normal operation. Upon request, the owner/operator shall make available such records as may be necessary to determine the conditions of the performance test.</p> <p><i>60-day notification:</i></p> <p>The Permittee must notify Ecology in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is initially scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) All results of performance tests;</li> </ol>	<p>40 CFR 63.862(a)(1)(i)(C) for standard</p> <p>40 CFR 63.865 for performance testing requirements</p> <p>40 CFR 63.9(e) and 40 CFR 63.7(b) for performance test notification</p> <p>40 CFR 63.866 for recordkeeping</p> <p>40 CFR 63.867(c)(4) for excess emissions reporting and (d) for electronic reporting</p>

LK3	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>2) The process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation;</p> <p>3) Documentation of supporting calculations for compliance determinations made under 40 CFR 63.865(a) through (d);</p> <p>4) For each failure to meet the emission limit, the number of failures, the date, start time, and duration of each event;</p> <p>5) For any failure to meet the emission limit, record an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions.</p> <p><i>On-going compliance:</i></p> <p>On-going compliance demonstrated through Condition C1.4.</p> <p><i>Reporting:</i></p> <p>Report failures to meet the applicable standard in the <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c)(4), delivered or postmarked by the 30th day following the end of each calendar half.</p> <p>Within 60 days after the date of completing each performance test, submit the results of the performance test electronically via EPA’s Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with 40 CFR 63.867(d).</p> <p>Submit source test results in the monthly air report, due after results received by the Permittee.</p>	

LK3	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C1.3a	Opacity	25% average for more than 6 consecutive minutes in any 60 minute period	<p>Emission control parameter monitoring is required when exhaust gasses are being emitted as a result of combustion in the unit or the unit ID fan is being operated as part of the cool down process for unit shutdown. Maintain emission control parameter hourly average rates at levels specified in the "Emission Control Compliance Demonstration Plan" (see Appendix B).</p> <p>Continuously monitor parameters specified in the plan.</p> <p>Whenever any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met, corrective action must be initiated within 24 hours. Failure to initiate corrective action within 24 hours is a violation of WAC 173-405-040(8) and may be a violation of the underlying applicable requirement. Report deviations from these operating parameters that last longer than 3 hours and corrective action in the monthly report.</p> <p>Compliance may also be determined by RM 9.</p>	Order 3462-AQ07, Modification 1, Appendix A 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
C1.3b	Opacity	35% average for more than 6 consecutive minutes in any 60-minute period.	<p>EPA Method 9 is the reference test method.</p> <p>Continuous monitoring same as above.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	WAC 173-405-040(6) 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
C1.4	HAP Metals (Scrubber Operating	Five monitoring parameter values below for either the pressure drop	<p><i>Monitoring:</i></p> <p>The Permittee must calibrate, maintain, and operate a CPMS that can be used to determine and record the pressure drop across the scrubber and the scrubbing liquid flow rate at least once every successive 15-</p>	40 CFR 63.864 for monitoring requirements

LK3	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
	Limit as a surrogate)	across the scrubber or the scrubber liquid flow rate the minimum operating limits during any semiannual reporting period	<p>minute period using the procedures in 40 CFR 63.8(c), as well as the procedures in 40 CFR 63.864(e)(10)(i) and (ii).</p> <p>The Permittee must establish operating limits for pressure drop across the scrubber and the scrubbing liquid flow rate based on performance testing in accordance with 40 CFR 63.864(j).</p> <p>Parameter values for pressure drop and scrubber flow rate have been established/specified in the “Emission Control Compliance Demonstration Plan” (Appendix B).</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Monitoring Exceedances:</i></p> <p>The Permittee is required to implement corrective action when any 3-hr average parameter value is below the minimum operating limit established during times when lime mud is fed, with the exception of pressure drop during startup and shutdown.</p> <p><i>Violation Determination:</i></p> <p>A violation of the underlying particulate matter standard in Condition C1.2 occurs when six or more 3-hour average parameter values within any 6-month reporting period are below the minimum operating limits established, with the exception of pressure drop during startup and shutdown.</p> <p>For purposes of determining the number of monitoring exceedances, no more than one exceedance will be attributed to any given 24-hour period.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p>	<p>40 CFR 63.864(j) for determination of operating limits</p> <p>40 CFR 63.864(k) for ongoing compliance and violation determination</p> <p>40 CFR 63.866 for recordkeeping requirements</p> <p>40 CFR 63.867(c) for excess emission reporting requirements</p>



LK3	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<ol style="list-style-type: none"> <li>1) CaO production rates in units of Mg/d or ton/day;</li> <li>2) Any occurrence when corrective action is required and when a violation is noted;</li> <li>3) Records of parameter monitoring data required under §63.864, including any period when the operating parameter levels were inconsistent with the levels established during the performance test, with a brief explanation of the cause of the monitoring exceedance, the time the monitoring exceedance occurred, the time corrective action was initiated and completed, and the corrective action taken;</li> <li>4) Records of parameter operating limits established for each affected source or process unit;</li> <li>5) For each failure to meet the operating limits, the number for failures, date, start time, and duration of each event;</li> <li>6) For each failure to meet an operating limit, maintain sufficient information to estimate the quantity of each regulated pollutant emitted over the emission limit. This information must be sufficient to provide a reliable emissions estimate if requested by the Administrator.</li> <li>7) Record actions taken to minimize emissions in accordance with §63.860(d) and any corrective actions taken to return the affected unit to its normal or usual manner of operation;</li> </ol> <p><i>Reporting:</i></p> <p>Report monitoring exceedances monthly to Ecology.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c), delivered or postmarked by the 30th day following the end of each calendar half.</p>	

LK3	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C1.5a	SO <sub>2</sub>	20 ppmdv @ 10% O <sub>2</sub> , 3-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-2. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report 3-hr average values monthly.</p>	PSD 01-03, Amendment 3, Condition 1.59
C1.5b	SO <sub>2</sub>	500 ppm @ 10% O <sub>2</sub> , 1-hr average	Same as previous limit.	WAC 173-405-040(9)(a)
C1.5c	SO <sub>2</sub>	27 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.59
C1.6a	TRS (as H <sub>2</sub> S)	20 ppmdv @ 10% O <sub>2</sub> , 24-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-5.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report daily maximum concentrations, 24-hr average concentrations, monthly average concentrations, maximum monthly 24-hr concentrations, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.62

<b>LK3</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C1.6b	TRS (as H <sub>2</sub> S)	Temperature ≥1,200°F and retention time ≥ 0.5 seconds when burning NCGs	Monitor unit operation, flame safety interlocks, and interlock connections to NCG valves. Report NCG venting per Condition F1.2.	40 CFR 60.283(a)(1)(iii)
C1.6c	TRS (as H <sub>2</sub> S)	10 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.62
C1.7a	CO	133 lb/hr, 8-hr average	Sample A/M using RM 10 (see Appendix ApA.2). Calculate per Appendix ApA.3 without dividing by CaO production.  Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.60
C1.7b	CO	581 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.60
C1.8a	NO <sub>x</sub>	340 ppmdv @ 10% O <sub>2</sub> , 24-hr average	Sample A/M using RM 7 (see Appendix ApA.2).  Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.61
C1.8b	NO <sub>x</sub>	238 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.61

<b>LK3</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C1.9	O <sub>2</sub>	No limit – required for O <sub>2</sub> correction	Monitor continuously using a CEMS in accordance with 40 CFR Part 60, Appendix F and Appendix B, PS-3. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.	Order 3462-AQ07, Modification 1, Appendix A
C1.10	Operating Limit	240 tons CaO/D, monthly average	Report average daily CaO production in tons in monthly report (see Appendix ApA.1).	PSD 01-03, Amendment 3, Condition 1.57
C1.11	Stack Dimensions	N/A	Certify stack dimensions meet discharge characteristics presented in the PSD 01-03 application (certification complete). Report any changes to stack diameter or height after stack dimensions are certified.	Order 3462-AQ07, Modification 1, Appendix A

**The following state-only requirement is not federally enforceable under the federal Clean Air Act.**

<b>LK3</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C1.12a	TRS	20 ppm @ 10% O <sub>2</sub> , 24-hr average	Same as Condition C1.6a.	WAC 173-405-040(3)(c)
C1.12b	TRS	80 ppm H <sub>2</sub> S @ 10% O <sub>2</sub> for more than 2 consecutive hours	Same as Condition C1.6a. Report exceedances monthly. All TRS monitored is considered H <sub>2</sub> S for this limit.	WAC 173-405-040(3)(b)

**C2. LIME KILN 4 (LK4)**

The emission unit shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 of Subpart MM.

LK4	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C2.1a	PM & PM <sub>10</sub>	0.030 gr/dscf @ 10% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i> Sample M/Q using RM 5 (see Appendix ApA.2).</p> <p><i>Reporting:</i> Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i> The Permittee shall comply with the general CAM requirements in Condition M. The Permittee shall implement corrective action when any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met. CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.64</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
C2.1b	PM	0.13 gr/dscf @ 10% O <sub>2</sub> , 1-hr average	Same as previous limit.	<p>WAC 173-405-040(3)(a)</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

LK4	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C2.1c	PM & PM <sub>10</sub>	35.6 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly. CAM demonstration same as previous limits.	PSD 01-03, Amendment 3, Condition 1.64 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
C2.2	HAP Metals (PM as a surrogate)	0.064 gr/dscf (0.15 g/dscm) @ 10% O <sub>2</sub>	<p><i>Performance Testing:</i> Sample every 5 years using EPA RM 5. First periodic performance test must be conducted by October 13, 2020 and within 5 years thereafter following the previous performance test.</p> <p><i>Representative Conditions:</i> Performance tests shall be conducted based on representative performance during the period being tested. The owner/operator must record the process information that is necessary to document operating conditions during the test and include such record and explanation to support that such conditions represent normal operation. Upon request, the owner/operator shall make available such records as may be necessary to determine the conditions of the performance test.</p> <p><i>60-day notification:</i> The Permittee must notify Ecology in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is initially scheduled to begin.</p> <p><i>Recordkeeping:</i> The Permittee must maintain records of:</p>	<p>40 CFR 63.862(a)(1)(i)(C) for standard</p> <p>40 CFR 63.865 for performance testing requirements</p> <p>40 CFR 63.9(e) and 40 CFR 63.7(b) for performance test notification</p> <p>40 CFR 63.866 for recordkeeping</p> <p>40 CFR 63.867(c)(4) for excess emissions reporting and (d) for electronic reporting</p>

LK4	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<ol style="list-style-type: none"> <li>1) All results of performance tests;</li> <li>2) The process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation;</li> <li>3) Documentation of supporting calculations for compliance determinations made under 40 CFR 63.865(a) through (d);</li> <li>4) For each failure to meet the emission limit, the number of failures, the date, start time, and duration of each event;</li> <li>5) For any failure to meet the emission limit, record an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions.</li> </ol> <p><i>On-going compliance:</i> On-going compliance demonstrated through Condition C2.4.</p> <p><i>Reporting:</i> Report failures to meet the applicable standard in the <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c)(4), delivered or postmarked by the 30th day following the end of each calendar half.</p> <p>Within 60 days after the date of completing each performance test, submit the results of the performance test electronically via EPA's Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with 40 CFR 63.867(d).</p> <p>Submit source test results in the monthly air report, due after results received by the Permittee.</p>	

LK4	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C2.3a	Opacity	25% average for more than 6 consecutive minutes in any 60 minute period	<p>Emission control parameter monitoring is required when exhaust gasses are being emitted as a result of combustion in the unit or the unit ID fan is being operated as part of the cool down process for unit shutdown. Maintain emission control parameter hourly average rates at levels specified in the "Emission Control Compliance Demonstration Plan" (see Appendix B).</p> <p>Continuously monitor parameters specified in the plan.</p> <p>Whenever any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met, corrective action must be initiated within 24 hours. Failure to initiate corrective action within 24 hours is a violation of WAC 173-405-040(8) and may be a violation of the underlying applicable requirement. Report deviations from these operating parameters that last longer than 3 hours and corrective action in the monthly report.</p> <p>Compliance may also be determined by RM 9.</p>	<p>Order 3462-AQ07, Modification 1, Appendix A</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
C2.3b	Opacity	35% average for more than 6 consecutive minutes in any 60-minute period.	<p>EPA Method 9 is the reference test method.</p> <p>Continuous monitoring same as above.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M.</p> <p>CAM reporting required on at a minimum semiannual basis.</p>	<p>WAC 173-405-040(6)</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
C2.4	HAP Metals (Scrubber Operating Limit as a surrogate)	Five monitoring parameter values for either pressure drop across the	<p><i>Monitoring:</i></p> <p>The Permittee must calibrate, maintain, and operate a CPMS that can be used to determine and record the pressure drop across the scrubber and the scrubbing liquid flow rate at least once every successive 15-minute</p>	<p>40 CFR 63.864 for monitoring requirements</p>



LK4	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
		scrubber or the scrubbing liquid flow rate below the minimum operating limits during any semiannual reporting period	<p>period using the procedures in 40 CFR 63.8(c), as well as the procedures in 40 CFR 63.864(e)(10)(i) and (ii).</p> <p>The Permittee must establish operating limits for pressure drop across the scrubber and the scrubbing liquid flow rate based on performance testing in accordance with 40 CFR 63.864(j).</p> <p>Parameter values for pressure drop and scrubber flow rate have been established/specified in the “Emission Control Compliance Demonstration Plan” (Appendix B).</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Monitoring Exceedances:</i></p> <p>The Permittee is required to implement corrective action when any 3-hr average parameter value is below the minimum operating limit established during times when lime mud is fed, with the exception of pressure drop during startup and shutdown.</p> <p><i>Violation Determination:</i></p> <p>A violation of the underlying particulate matter standard in Condition C2.2 occurs when six or more 3-hour average parameter values within any 6-month reporting period are below the minimum operating limits established, with the exception of pressure drop during startup and shutdown.</p> <p>For purposes of determining the number of monitoring exceedances, no more than one exceedance will be attributed to any given 24-hour period.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) CaO production rates in units of Mg/d or ton/day;</li> </ol>	<p>40 CFR 63.864(j) for determination of operating limits</p> <p>40 CFR 63.864(k) for ongoing compliance and violation determination</p> <p>40 CFR 63.866 for recordkeeping requirements</p> <p>40 CFR 63.867(c) for excess emission reporting requirements</p>

LK4	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>2) Any occurrence when corrective action is required and when a violation is noted;</p> <p>3) Records of parameter monitoring data required under §63.864, including any period when the operating parameter levels were inconsistent with the levels established during the performance test, with a brief explanation of the cause of the monitoring exceedance, the time the monitoring exceedance occurred, the time corrective action was initiated and completed, and the corrective action taken;</p> <p>4) Records of parameter operating limits established for each affected source or process unit;</p> <p>5) For each failure to meet the operating limits, the number for failures, date, start time, and duration of each event;</p> <p>6) For each failure to meet an operating limit, maintain sufficient information to estimate the quantity of each regulated pollutant emitted over the emission limit. This information must be sufficient to provide a reliable emissions estimate if requested by the Administrator.</p> <p>7) Record actions taken to minimize emissions in accordance with §63.860(d) and any corrective actions taken to return the affected unit to its normal or usual manner of operation;</p> <p><i>Reporting:</i></p> <p>Report monitoring exceedances monthly to Ecology.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance</i> or <i>Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c), delivered or postmarked by the 30th day following the end of each calendar half.</p>	

<b>LK4</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C2.5a	SO <sub>2</sub>	20 ppmdv @ 10% O <sub>2</sub> , 3-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-2. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report 3-hr average values monthly.</p>	PSD 01-03, Amendment 3, Condition 1.65
C2.5b	SO <sub>2</sub>	500 ppm @ 10% O <sub>2</sub> , 1-hr average	Same as previous limit.	WAC 173-405-040(9)(a)
C2.5c	SO <sub>2</sub>	28 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.65
C2.6a	TRS (as H <sub>2</sub> S)	20 ppmdv @ 10% O <sub>2</sub> , 24-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-5.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report daily maximum concentrations, 24-hr average concentrations, monthly average concentrations, maximum monthly 24-hr concentrations, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.68

<b>LK4</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C2.6b	TRS (as H <sub>2</sub> S)	Temperature ≥1,200°F and retention time ≥ 0.5 seconds when burning NCGs	Monitor unit operation, flame safety interlocks, and interlock connections to NCG valves. Report NCG venting per condition F1.2.	40 CFR 60.283(a)(1)(iii)
C2.6c	TRS (as H <sub>2</sub> S)	11 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.68
C2.7a	CO	138 lb/hr, 8-hr average	Sample A/M using RM 10 (see Appendix ApA.2). Calculate per Appendix ApA.3 without dividing by CaO production.  Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.66
C2.7b	CO	605 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.66
C2.8a	NO <sub>x</sub>	340 ppm <sub>dv</sub> @ 10% O <sub>2</sub> , 24-hr average	Sample A/M using RM 7 (see Appendix ApA.2).  Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	PSD 01-03, Amendment 3, Condition 1.67

<b>LK4</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C2.8b	NO <sub>x</sub>	248 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.67
C2.9	O <sub>2</sub>	No limit – required for O <sub>2</sub> correction	Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B PS-3. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.	Order 3462-AQ07, Modification 1, Appendix A
C2.10	Operating Limit	250 tons CaO/D, monthly average	Report average daily CaO production in tons in monthly report (see Appendix ApA.1).	PSD 01-03, Amendment 3, Condition 1.63
C2.11	Stack Dimensions	N/A	Certify stack dimensions meet discharge characteristics presented in the PSD 01-03 application (certification complete). Report any changes to stack diameter or height after stack dimensions are certified.	Order 3462-AQ07, Modification 1, Appendix A

**The following state-only requirement is not federally enforceable under the federal Clean Air Act.**

<b>LK4</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C2.12a	TRS	20 ppm @ 10% O <sub>2</sub> , 24-hr average	Same as Condition C2.6a.	WAC 173-405-040(3)(c)
C2.12b	TRS	80 ppm H <sub>2</sub> S @ 10% O <sub>2</sub> for more than 2 consecutive hours	Same as Condition C2.6a. Report exceedances monthly. All TRS monitored is considered H <sub>2</sub> S for this limit.	WAC 173-405-040(3)(b)

**C3. LIME KILN 5 (LK5)**

The emission unit shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 of Subpart MM.

This source shall comply with the requirements of 40 CFR Part 60, Subpart BB. The source shall also comply with the General Requirements of 40 CFR Part 60, including:

- 40 CFR 60.7(b) & (f) concerning recordkeeping,
- 40 CFR 60.7(c), (d), & (e) concerning reporting,
- 40 CFR 60.11(d) concerning operation and maintenance,
- 40 CFR 60.12 concerning concealment,
- 40 CFR 60.13 concerning monitoring,
- 40 CFR 60.19 concerning notification and reporting.

Opacity limits apply to each stack individually. All other limits apply to the total emissions from the combined stacks.

<b>LK5</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C3.1a	PM & PM10 (while firing natural gas (NG))	0.035 gr/dscf @ 10% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i> Sample M/Q using RM 5 (see Appendix ApA.2).</p> <p><i>Reporting:</i> Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i> The Permittee shall comply with the general CAM requirements in Condition M. The Permittee is required to implement corrective action if the average of ten consecutive 6-minute averages result in a measurement greater than 20 percent opacity. A violation of the underlying particulate matter standard when opacity is greater than 35 percent for 3 percent or more of operating time during a semiannual period while lime mud is fed. CAM reporting required on at a minimum semiannual basis.</p>	<p>PSD 01-03, Amendment 3, Condition 1.70</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
C3.1b	PM & PM10 (while firing oil)	0.060 gr/dscf @ 10% O <sub>2</sub> , 1-hr average	Same as previous limit.	<p>PSD 01-03, Amendment 3, Condition 1.70</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

<b>LK5</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C3.1c	PM (while firing gaseous fossil fuel)	0.066 gr/dscf @ 10% O <sub>2</sub>	<p><i>Performance Testing:</i></p> <p>Sample M/Q using EPA RM 5 in accordance with 40 CFR 60.8 except as provided below. The sampling time and sample volume for each run shall be at least 60 minutes and 0.90 dscm (31.8 dscf). Water shall be used as the cleanup solvent instead of acetone in the sample recovery procedure. The particulate concentration shall be corrected to the appropriate oxygen concentration according to 40 CFR 60.284(c)(3).</p> <p>Emission rate to be calculated using the procedures in 40 CFR 60.285(c).</p> <p><i>30-day Notification:</i></p> <p>The Permittee shall provide Ecology at least 30 days prior notice of any performance test.</p> <p><i>Reporting:</i></p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p>CAM demonstration same as previous limits.</p>	<p>40 CFR 60.282(a)(3) for standard</p> <p>40 CFR 60.285(b)(1) for test method and procedures</p> <p>40 CFR 60.284(c)(4) for recordkeeping requirements</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>



LK5	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C3.1d	PM (while firing liquid fossil fuel)	0.13 gr/dscf @ 10% O <sub>2</sub>	Same as previous limit. CAM demonstration same as previous limits.	40 CFR 60.282(a)(3) for standard 40 CFR 60.285(b)(1) for test method and procedures 40 CFR 60.284(c)(4) for recordkeeping requirements 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
C3.1e	PM	0.13 gr/dscf @ 10% O <sub>2</sub> , 1-hr average	Same as previous limit. CAM demonstration same as previous limits.	WAC 173-405-040(3)(a) 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
C3.1f	PM & PM <sub>10</sub>	69 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly. CAM demonstration same as previous limits.	PSD 01-03, Amendment 3, Condition 1.70 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping

LK5	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C3.2	HAP Metals (PM as a surrogate)	0.064 gr/dscf (0.15 g/dscm) @ 10% O <sub>2</sub>	<p><i>Performance Testing:</i></p> <p>Sample every 5 years using EPA RM 5. First periodic performance test must be conducted by October 13, 2020 and within 5 years thereafter following the previous performance test.</p> <p><i>Representative Conditions:</i></p> <p>Performance tests shall be conducted based on representative performance during the period being tested. The owner/operator must record the process information that is necessary to document operating conditions during the test and include such record and explanation to support that such conditions represent normal operation. Upon request, the owner/operator shall make available such records as may be necessary to determine the conditions of the performance test.</p> <p><i>60-day notification:</i></p> <p>The Permittee must notify Ecology in writing of his or her intention to conduct a performance test at least 60 calendar days before the performance test is initially scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) All results of performance tests;</li> <li>2) The process information that is necessary to document operating conditions during the test and include in such record an explanation to support that such conditions represent normal operation;</li> <li>3) Documentation of supporting calculations for compliance determinations made under 40 CFR 63.865(a) through (d);</li> </ol>	<p>40 CFR 63.862(a)(1)(i)(C) for standard</p> <p>40 CFR 63.865 for performance testing requirements</p> <p>40 CFR 63.9(e) and 40 CFR 63.7(b) for performance test notification</p> <p>40 CFR 63.866 for recordkeeping</p> <p>40 CFR 63.867(c)(4) for excess emissions reporting and (d) for electronic reporting</p>

LK5	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>4) For each failure to meet the emission limit, the number of failures, the date, start time, and duration of each event;</p> <p>5) For any failure to meet the emission limit, record an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions.</p> <p><i>On-going compliance:</i> On-going compliance demonstrated through Condition C3.4.</p> <p><i>Reporting:</i> Report failures to meet the applicable standard in the <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c)(4), delivered or postmarked by the 30th day following the end of each calendar half.</p> <p>Within 60 days after the date of completing each performance test, submit the results of the performance test electronically via EPA's Compliance and Emissions Data Reporting Interface (CEDRI) in accordance with 40 CFR 63.867(d).</p> <p>Submit source test results in the monthly air report, due after results received by the Permittee.</p>	

<b>LK5</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C3.3a	Opacity	Opacity greater than 20% for 3% or more of operating time during a semiannual period (limit is applicable to each stack individually)	<p><i>Monitoring:</i></p> <p>Monitoring continuously using a COMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS 1.</p> <p><i>Exceedances:</i></p> <p>An exceedance has occurred when the average of ten consecutive 6-minute averages result in a measurement of greater than 20 percent opacity. The Permittee must implement corrective action following an exceedance.</p> <p><i>Violation Determination:</i></p> <p>A violation occurs when opacity is greater than 20 percent for 3 percent or more of operating time during a semi-annual period while lime mud is fed.</p> <p><i>Reporting:</i></p> <p>Report daily maximum six-minute average opacity and exceedances monthly. Semi-annually report percent of operating time during a semi-annual period that opacity exceeded 20 percent.</p>	Order 3462-AQ07, Modification 1, Appendix A

LK5	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C3.3b	Opacity	35% average for more than 6 consecutive minutes in any 60 minute period  (limit is applicable to each stack individually)	<p>EPA Method 9 is the reference test method.</p> <p>Monitor continuously using a COMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, Performance Specification 1. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system operating requirements.</p> <p>Report daily maximum six-minute average opacity, daily average opacity, and exceedances monthly.</p> <p>The Permittee shall comply with the general CAM requirements in Condition M. CAM reporting required on at a minimum semiannual basis.</p>	<p>WAC 173-405-040(6)</p> <p>WAC 173-400-615 for monitoring</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
C3.4	HAP Metals (Opacity as a surrogate)	Opacity greater than 20% for 3% or more of operating time during a semiannual period  (limit is applicable to each stack individually)	<p><i>Monitoring:</i></p> <p>Monitoring opacity using a COMS which is installed, calibrated, maintained, and operated in accordance with PS-1 in Appendix B to 40 CFR Part 60 and the provisions in §63.6(h) and 63.8 and §63.864(d)(3) and (4).</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Monitoring Exceedances:</i></p> <p>The Permittee is required to implement corrective action if the average of ten consecutive 6-minute averages result in a measurement greater than 20 percent opacity.</p> <p><i>Violation Determination:</i></p> <p>A violation of the underlying particulate matter standard in Condition C3.2 occurs when opacity is greater than 20 percent for 3 percent or</p>	<p>40 CFR 63.864 for monitoring requirements</p> <p>40 CFR 63.864(k) for ongoing compliance and violation determination</p> <p>40 CFR 63.866 for recordkeeping requirements</p> <p>40 CFR 63.867(c) for excess emission reporting requirements</p>

LK5	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>more of operating time during a semiannual period while lime mud is fed.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) CaO production rates in units of Mg/d or ton/day;</li> <li>2) Any occurrence when corrective action is required and when a violation is noted;</li> <li>3) For each failure to meet the opacity operating limit, the number of failures, the date, start time, and duration of each event;</li> <li>4) For each failure to meet the operating limit, an estimate of the quantity of each regulated pollutant emitted over the emission limit and a description of the method used to estimate the emissions;</li> <li>5) Record actions taken to minimize emissions in accordance with §63.860(d) and any corrective actions taken to return the affected unit to its normal or usual manner of operation.</li> </ol> <p><i>Reporting:</i></p> <p>Report monitoring exceedances monthly to Ecology.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance</i> or <i>Summary Report</i> in accordance with 40 CFR 63.10(e)(3)(v) and 40 CFR 63.867(c), delivered or postmarked by the 30th day following the end of each calendar half.</p>	

<b>LK5</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C3.5a	SO <sub>2</sub>	20 ppmdv @ 10% O <sub>2</sub> , 3-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B PS-2. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report 3-hr average concentrations, monthly average concentration, maximum monthly 3-hr average concentration, and exceedances monthly.</p>	<p>PSD 01-03, Amendment 3, Condition 1.71</p> <p>Order 8429, Modification 1, Condition 3.1</p>
C3.5b	SO <sub>2</sub>	500 ppm @ 10% O <sub>2</sub> , 1-hr average	Same as previous limit.	WAC 173-405-040(9)(a)
C3.5c	SO <sub>2</sub>	28 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.71
C3.6a	TRS (as H <sub>2</sub> S)	8 ppmdv @ 10% O <sub>2</sub> , 12-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-5.</p> <p>See Facility-wide General Requirement, Condition 26 for CMS data recovery requirements.</p> <p>Report daily maximum concentrations, 12-hr average concentrations, monthly average concentrations, maximum monthly 12-hr concentrations, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.74 for limit
C3.6b	TRS (as H <sub>2</sub> S)	8 ppmdv @ 10% O <sub>2</sub> , 12-hr average	<p><i>Monitoring:</i></p> <p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-5.</p>	<p>40 CFR 60.283(a)(5) for limit</p> <p>40 CFR 60.284(a)(2) for monitoring</p>

LK5	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p>CEMS span to be set to 30 ppm TRS.</p> <p>Calculate and record on a daily basis 12-hour average TRS and oxygen concentrations pursuant to Condition C3.9 for two consecutive periods of each operating day. Each 12-hour average shall be determined as the arithmetic mean of the appropriate 12 contiguous 1-hour average TRS concentrations provided by the CEMS using the following equation:</p> $C_{corr} = C_{meas} \times (21 - X) / (21 - Y)$ <p>where:</p> <p><i>C<sub>corr</sub></i> = the concentration corrected for oxygen.</p> <p><i>C<sub>meas</sub></i> = the concentration uncorrected for oxygen.</p> <p><i>X</i> = the volumetric oxygen concentration in percentage to be corrected to (8 percent for recovery furnaces and 10 percent for lime kilns, incinerators, or other devices).</p> <p><i>Y</i> = the measured 12-hour average volumetric oxygen concentration.</p> <p><i>Excess Emissions:</i></p> <p>Periods of excess emission are defined as all 12-hour average TRS concentrations above 8 ppm @ 10% O<sub>2</sub> by volume.</p> <p>Ecology will not consider periods of excess emissions under §60.284(d)(2) to be indicative of a violation under §60.11(d) provided that Ecology determines the affected facility, including air pollution control equipment, is maintained and operated in a manner which is</p>	<p>40 CFR 60.284(d)(2) for excess emission definition</p> <p>40 CFR 60.284(d) for semiannual reporting of excess emissions</p>



LK5	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>consistent with good air pollution control practice for minimizing emissions during periods of excess emissions. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p><i>Reporting:</i></p> <p>Report daily maximum concentrations, 12-hr average concentrations, monthly average concentrations, maximum monthly 12-hr concentrations, and exceedances monthly.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 60.7(c) and 40 CFR 60.284(d), postmarked by the 30th day following the end of each six-month period (or on a more frequent basis in accordance with the criteria in 40 CFR 60.7(c)). Report NCG venting per condition F1.2.</p>	
C3.6c	TRS (as H <sub>2</sub> S)	6 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.74
C3.7a	CO	64 lb/hr, 8-hr average	<p>Monitor continuously using CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-4. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Calculate per Appendix ApA.3 without dividing by CaO production.</p> <p>Report 8-hr average concentrations, maximum monthly 8-hr concentration, and exceedances monthly.</p>	PSD 01-03, Amendment 3, Condition 1.72

<b>LK5</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C3.7b	CO	282 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.72
C3.8a	NO <sub>x</sub>	275 ppmdv @ 10% O <sub>2</sub> , 24-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B PS-2. See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report 24-hr average concentrations, monthly average concentration, maximum monthly 24-hr average concentration, and exceedances monthly.</p>	<p>PSD 01-03, Amendment 3, Condition 1.73</p> <p>Order 8429, Modification 1, Condition 3.2</p>
C3.8b	NO <sub>x</sub>	262 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.73
C3.9	O <sub>2</sub>	No limit – required for O <sub>2</sub> correction	<p>Monitor and record the percent oxygen by volume on a dry basis, using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS-3.</p> <p>See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Calculate and record on a daily basis 12-hour average oxygen concentrations for the two consecutive periods of each operating day. These 12-hour averages shall correspond to the 12-hour average TRS concentrations in Condition C3.6a and shall be determined as an arithmetic mean of the appropriate 12 contiguous 1-hour average oxygen concentrations provided by the continuous monitoring system.</p>	<p>Order 3462-AQ07, Modification 1, Appendix A</p> <p>40 CFR 60.284(a)(2) for monitoring requirement</p> <p>40 CFR 60.284(c)(2) for recording requirement</p>

<b>LK5</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
C3.10	Operating Limit	325 tons CaO/D, monthly average	Report average daily CaO production in tons in monthly report (see Appendix ApA.1).	PSD 01-03, Amendment 3, Condition 1.69
C3.11	HAPs	N/A	<p>The Permittee must maintain proper operation of the electrostatic precipitator's automatic voltage control (AVC).</p> <p>The Permittee must maintain records demonstrating compliance with the requirement to maintain proper operation of an electrostatic precipitator AVC.</p>	<p>40 CFR 63.864(e)(1) for AVC requirement</p> <p>40 CFR 63.866(c)(8) for recordkeeping</p>

The following state-only requirement is not federally enforceable under the federal Clean Air Act.

LK5	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
C3.12a	TRS	20 ppm @ 10% O <sub>2</sub> , 24-hr average	Same as Condition C3.6a.	WAC 173-405-040(3)(c)
C3.12b	TRS	80 ppm H <sub>2</sub> S @ 10% O <sub>2</sub> for more than 2 consecutive hours	Same as Condition C3.6a. Report exceedances monthly. All TRS monitored is considered H <sub>2</sub> S for this limit.	WAC 173-405-040(3)(b)

### D1. LOW VOLUME HIGH CONCENTRATION (LVHC) SYSTEM

The LVHC systems include: #1 Kamyr digester; #2 Kamyr digester; #8 Evaporator System; #9 Evaporator System; #10 Evaporator System; Turpentine System; Steam Stripper System; Spill Tank, and NSSC LVHC System.

The applicable emission systems shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 to Subpart S.

<b>LVHC</b>	<b>Parameter</b>	<b>Limit, Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
D1.1	HAPs: Collection and Treatment	LVHC non-condensable gas source group emissions shall be enclosed and vented into a closed-vent system and routed to Lime Kiln 3, Lime Kiln 4, and/or Lime Kiln 5.	40 CFR 63.443(c)
D1.2	HAPs: Collection and Treatment	Introduce LVHC gases with the primary fuel or into flame zone of Lime Kiln 3, Lime Kiln 4, and/or Lime Kiln 5.	40 CFR 63.443(d)

LVHC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D1.3	HAPs: Enclosures	<p>Each enclosure shall maintain negative pressure at each enclosure or hood opening as demonstrated by the procedures in 40 CFR 63.457(e). Each enclosure or hood opening closed during the initial performance test shall be maintained in the closed position at all times except when necessary to open for sampling, inspection, maintenance, or repairs.</p> <p><i>Monthly Inspections:</i></p> <p>For each enclosure opening, a visual inspection of the closure mechanism shall be performed at least once every 30 days to ensure the opening is maintained in the closed position and sealed.</p> <p>For this condition, 30 days shall be interpreted to mean: at least once per calendar month with no two consecutive inspections occurring within 14 days.</p> <p><i>Annual Inspections:</i></p> <p>Demonstrate annually that each enclosure opening is maintained at negative pressure as specified in 40 CFR 63.457(e).</p> <p>For locations where safe access is not readily available, the Permittee shall submit a list to Ecology with a brief explanation of safety concerns. Upon Ecology approval:</p> <ul style="list-style-type: none"> <li>(1) Measurements for detectable leaks at locations specified on the list shall not be required annually, and</li> <li>(2) Measurements for detectable leaks at locations specified on the list shall be required once per five-year interval.</li> </ul>	<p>40 CFR 63.450(a) and (b)</p> <p>40 CFR 63.453(k)(1) and Order 3463-AQ07 for monthly inspections</p> <p>40 CFR 63.453(k)(4) and Order 3463-AQ07 for annual inspections</p>

LVHC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D1.4	HAPs: Closed-vent system	<p>Each component of the closed-vent system used to control LVHC non-condensable gas source group emission that is operated at positive pressure and located prior to a control device shall be designed for and operated with no detectable leaks as indicated by an instrument reading of less than 500 ppmv above background, as measured by 40 CFR Part 60, Appendix A, Method 21.</p> <p><i>Monthly Inspections:</i></p> <p>Each closed vent system (reasonably accessible ductwork, piping, enclosures, and connections to covers in the collection system for the LVHC non-condensable gas source group) shall be visually inspected for visible defects every 30 day or as requested by Ecology.</p> <p>For this condition, 30 days shall be interpreted to mean: at least once per calendar month with no two consecutive inspections occurring within 14 days.</p> <p><i>Annual Inspections:</i></p> <p>Measure annually components of closed-vent systems under positive pressure for detectable leaks as specified in 40 CFR 63.457(d).</p> <p>For locations where safe access is not readily available, the Permittee shall submit a list to Ecology with a brief explanation of safety concerns. Upon Ecology approval:</p> <ol style="list-style-type: none"> <li>(1) Measurements for detectable leaks at locations specified on the list shall not be required annually, and</li> <li>(2) Measurements for detectable leaks at locations specified on the list shall be required once per five-year interval.</li> </ol>	<p>40 CFR 63.450(c)</p> <p>40 CFR 63.453(k)(2) and Order 3463-AQ07 for monthly inspections</p> <p>40 CFR 63.453(k)(3) and Order 3463-AQ07 for annual inspections</p>

LVHC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D1.5	HAPs: Collection and Treatment	<p>Each bypass line in the closed-vent system that could divert vent streams containing HAPs to the atmosphere without meeting the emission limitations in 40 CFR 63.443 shall comply with either of the following requirements:</p> <p>(1) On each bypass line, the owner or operator shall install, calibrate, maintain, and operate according to the manufacturer's specifications a flow indicator that is capable of taking periodic readings as frequently as specified in §63.454(e). The flow indicator shall be installed in the bypass line in such a way as to indicate flow in the bypass line; or</p> <p>(2) For bypass line valves that are not computer controlled, the owner or operator shall maintain the bypass line valve in the closed position with a car seal or a seal placed on the valve or closure mechanism in such a way that valve or closure mechanism cannot be opened without breaking the seal.</p>	40 CFR 63.450(d)
D1.6	HAPs: Inspection and Monitoring	<p>Install, calibrate, certify, operate, and maintain according to the manufacturer's specifications, a continuous monitoring system (CMS) as specified in 40 CFR 63.453(b) through (l) except as allowed in 40 CFR 63.453(m). The CMS shall include a continuous recorder.</p>	40 CFR 63.453(b) through (m)



LVHC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D1.7	HAPs: Inspection and Monitoring	<p>If an inspection of the LVHC non-condensable gas collection system identifies visible defects, or if an instrument reading of 500 ppmv or greater above background is measured by 40 CFR Part 60, Appendix A, Method 21 in accordance with the procedures in 40 CFR 63.457(d), or if enclosure openings are not maintained at negative pressure, take the following corrective actions as soon as practicable.</p> <p>Make first effort repair to correct the closed-vent system as soon as practicable but no later than 5 calendar days after the problem is identified.</p> <p>Complete the repair or corrective action no later than 15 days after the problem is identified. Delay of repair or corrective action is allowed if the repair or corrective action is technically infeasible without a process unit shutdown or if the Permittee determines that the emissions resulting from immediate repair would be greater than the emission likely to result from delay of repair. Repair of such equipment shall be completed by the end of the next process shutdown.</p>	40 CFR 63.453(k)(6) and 40 CFR 63.457(d)

LVHC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D1.8	HAPs: Recordkeeping	<p>For each applicable enclosure opening, closed vent system, and closed collection system, prepare and maintain a site-specific inspection plan, including a drawing or schematic of the components of applicable affected equipment and shall record the following information for each inspection:</p> <ol style="list-style-type: none"> <li>(1) Date of inspection;</li> <li>(2) Equipment type and identification;</li> <li>(3) Results of negative pressure tests for enclosures;</li> <li>(4) Results of leak detection tests;</li> <li>(5) The nature of the defect or leak and the method of detection;</li> <li>(6) The date the defect or leak was detected and the date of each attempt to repair the defect or leak;</li> <li>(7) Repair methods applied in each attempt to repair the defect or leak;</li> <li>(8) Reason for the delay if the defect or leak is not repaired within 15 days;</li> <li>(9) Expected date of successful repair of the defect or leak if the repair is not completed within 15 days;</li> <li>(10) Date of successful repair of the defect or leak;</li> <li>(11) Position and duration of opening of bypass line valves and the condition of any valve seals; and</li> <li>(12) Duration of the use of manual or computer-controlled bypass valves.</li> </ol>	40 CFR 63.454(b)
D1.9	HAPs: Excess Emissions	<p>Records shall be maintained for all periods of excess emissions.</p> <p>Periods of excess emissions from the LVHC non-condensable gas source group are not violations of 63.443(c) and (d) provided that the time of excess emissions divided by the total process operating time in a semi-annual reporting period does not exceed one (1) percent from the computer-controlled bypass valves in the LVHC system.</p>	40 CFR 63.443(e)(1)

## D2. PULPING PROCESS CONDENSATES

Pulping process condensates to be collected include: #1 Kamyr Digester System Foul Condensates; #2 Kamyr Digester System Foul Condensates; #8 Evaporator Surface Condenser, Vacuum System & Vapor Condensates off a Primary Feed Effect; #9 Evaporator Surface Condenser, Vacuum System & Vapor Condensates off a Primary Feed Effect; #10 Evaporator Surface Condenser, Vacuum System & Vapor Condensates off a Primary Feed Effect; Turpentine System; Decanter Underflow Foul Condensates.

The applicable systems shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 to Subpart S.

Condensates	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D2.1	HAPs: Collection and Treatment	Collect kraft pulping condensate streams such that one of the following collection requirements is satisfied: <ol style="list-style-type: none"> <li>(1) Kraft pulping condensates are collected from all named condensate streams;</li> <li>(2) Kraft pulping condensates are collected from each HVLC collection system, from each LVHC collection system, and from other named condensate streams that in total contain at least 65 percent of the total HAP mass from the kraft pulping condensate from each digester system, each turpentine recovery system, vapors from the weak black liquor feed stages of each evaporator system, and the evaporator vacuum system for each weak black liquor feed stage; or</li> <li>(3) Kraft pulping condensates collected from named condensate streams contains at least 11.1 pounds of total HAP per oven-dry ton of unscreened brownstock feeding the bleach plant and 7.2 pounds of total HAP per oven-dry ton of unscreened brownstock not intended for bleaching.</li> </ol>	40 CFR 63.446(c)
D2.2	HAPs: Collection and Treatment	Transfer collected kraft pulping condensates through a closed collection system. The closed collection system shall meet the requirements of 40 CFR 63.960, 63.961, and 63.962, except for the closed vent systems and control devices shall be designed and operated in accordance with 40 CFR 63.443(d) and 63.450.	40 CFR 63.446(d)(1)

Condensates	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D2.3	HAPs: Collection and Treatment	<p>The Permittee is permitted to install and operate condensate collection tanks (CCT) to collect kraft pulping condensates. The CCT shall be equipped so that the fixed roof and all openings are operated with no detectable leaks, as indicated by an instrument reading of less than 500 ppm<sub>dv</sub> above background as measured by 40 CFR Part 60, Appendix A, Method 21 in accordance with the procedures in 40 CFR 63.457(d). Each opening will be maintained in a closed, sealed position at all times that the tank contains condensate, except when necessary to use the openings for sampling, removal, or for equipment inspection, maintenance or repair.</p> <p>The CCT shall be equipped with a water seal device on the overflow line.</p> <p>The CCT shall be vented to a closed vent system meeting the requirements in 40 CFR 63.450. CCT vent gases shall be incinerated in lime kiln and/or power boiler.</p>	<p>40 CFR 63.446(d)(2) for CCT</p> <p>40 CFR 63.962(b)(2)(i)(A) for water seal</p> <p>40 CFR 63.446(d)(2)(i) for venting to closed collection</p>
D2.4	HAPs: Collection and Treatment	<p>Kraft pulping condensates collected in the CCT shall be transferred in a closed collection system to the UNOX reactor.</p> <p>Kraft pulping condensates shall be treated to demonstrate 6.6 lb/ODTP destruction of total HAPs (with methanol as a surrogate).</p> <p>Discharge the pulping process condensate below the liquid surface of a biological treatment system and treat the pulping process condensates to meet the requirements specified in paragraph (e)(3), (4), or (5) of 40 CFR 63.446, and total HAP shall be measured as specified in §63.457(g).</p>	<p>40 CFR 63.446(e)(2), (3), (4), (5)</p>
D2.5	HAPs: Collection and Treatment	<p>The Permittee shall not be considered in violation of the collection and treatment requirements if the time of excess emissions divided by the total process operating time in a semi-annual reporting period does not exceed 10%.</p>	<p>40 CFR 63.446(g)</p>

Condensates	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D2.6	HAPs: Condensate Collection System Inspections	<p><i>Monthly Inspections</i></p> <p>The condensate collection system shall be visually inspected every 30 days. Follow the inspection requirements found in 40 CFR 63.964(a)(1)(i)(A), 63.964(a)(1)(v), and 63.964(b)(1) and (2) including:</p> <ul style="list-style-type: none"> <li>(1) The unburied portion of the collection system piping shall be visually inspection to verify that there are no defects.</li> <li>(2) The inspection shall include verification that appropriate liquid level in the water seals in the CCT are being maintained and identify any other defects that could reduce water seal control effectiveness.</li> </ul> <p>For this condition, 30 days shall be interpreted to mean: at least once per calendar month with no two consecutive inspections occurring within 14 days.</p> <p><i>Annual Inspections</i></p> <p>CCT shall be inspection for detectable leaks annually using the procedures in 40 CFR 63.457(d).</p> <p><i>Inspection Corrective Actions</i></p> <p>Follow the repair requirements found in 40 CFR 63.964(a)(1)(i)(A), 63.964(a)(1)(v), and 63.964(b)(1) and (2) including:</p> <ul style="list-style-type: none"> <li>(1) The first effort to repair a defect shall be no later than 5 calendar days after detection.</li> <li>(2) Repair shall be completed as soon as practicable but no later than 15 calendar days after detection unless the repair of the defect requires emptying or temporary removal from service of the collection system.</li> <li>(3) If repair of the defect requires emptying or temporary removal of the condensate collection system from service, the defect will be repaired the next time the process equipment generating the condensate stops operation. The repair of the defect will be completed before the process resumes operation.</li> </ul>	<p>Order 3463-AQ07, 40 CFR 63.453(l), 40 CFR 63.964(a)(1)(iii), and 40 CFR 63.964(a)(1)(i)(A) for monthly inspection</p> <p>40 CFR 63.453(l)(2) for annual inspections</p> <p>40 CFR 63.453(l)(3) and 63.964(b)(1) and (2) for corrective actions</p>

Condensates	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D2.7	HAPs: Inspection Recordkeeping	<p>For the condensate closed collection system, the Permittee must prepare and maintain a site-specific inspection plan including a drawing or schematic of the components of applicable affected equipment and shall record the following information for each inspection:</p> <ol style="list-style-type: none"> <li>(1) Date of inspection;</li> <li>(2) The equipment type and identification;</li> <li>(3) Results of leak detection tests;</li> <li>(4) The nature of the defect or leak and the method of detection (i.e., visual inspection or instrument detection);</li> <li>(5) The date the defect or leak was detected and the date of each attempt to repair the defect or leak;</li> <li>(6) Repair methods applied in each attempt to repair the defect or leak;</li> <li>(7) The reason for the delay if the defect or leak is not repaired within 15 days after discovery;</li> <li>(8) The expected date of successful repair of the defect or leak if the repair is not completed within 15 days; and</li> <li>(9) The date of successful repair of the defect or leak.</li> </ol>	40 CFR 63.453(l)(1)(i) and 40 CFR 63.454(b)

Condensates	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D2.8	HAPs: Monitoring	<p>The control device shall be operating in a manner consistent with the procedures/values established under 40 CFR Part 63, Subpart S except as provided in 40 CFR 63.453(p), 40 CFR 63.443(e), or 40 CFR 63.446(g).</p> <p>Daily monitoring requirements to demonstrate compliance with the provisions of 40 CFR 63.453(m) and (n) to the liquid stream UNOX DCD operated by the Permittee.</p> <p>Sample DCD inlet and outlet streams daily and analyzed for methanol. The following method of calculation is to be used for the daily methanol samples:</p> <p>Treatment in lbs HAPs / Kraft ODTP =</p> $\frac{\text{Collected lbs/D HAPs} - \text{lbs/D HAPs at DCD sampler} - \text{lbs/D HAPs in RAS}}{\text{Kraft ODTP/D}}$ <p>Report daily and 30-day rolling average results in lb/TODP. 30-day rolling average results must meet applicable limits in Section D2.1 and D2.4.</p>	40 CFR 63.446(e)(4) and 63.453(h)
D2.9	HAPs: Performance Testing	<p>Conduct a HAP removal test as specified in §63.457(l) within 45 days after the beginning of each quarter and meet the applicable emission limit in §63.446(e)(2). The test conducted in the first quarter (annually) shall be performed for total HAP as specified in §63.457(g) and meet the mass removal emission limit specified in §63.446(e)(2). The remaining quarterly tests shall be performed in the same manner, except that the permittee may use the applicable methanol procedure in §63.457(l)(2) and the value of r determined during the first quarter test instead of measuring the additional HAP to determine a new value of r.</p> <p>Report results of the performance before the close of business on the 60<sup>th</sup> day following the completion of the performance test, unless approved otherwise in writing by Ecology.</p>	40 CFR 63.457(g) for testing requirement 40 CFR 63.457(l) for calculation 40 CFR 63.455(h) for reporting

### D3. HIGH VOLUME LOW CONCENTRATION (HVLC) SYSTEM

Applies to the following systems: Pulp washing, knotter system, screen system.

The Permittee submitted information to satisfy Clean Condensate Alternative (CCA) criteria in 40 CFR 63.447 which allows use of the CCA to meet HVLC collection and treatment requirements. Ecology issued Order 2737-AQ05 which mandates enforceable conditions to assure applicable HAPs collection requirements are met using CCA.

The applicable systems shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 to Subpart S.

HVLC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D3.1	HAPs: Collection and Treatment	The HVLC system shall be enclosed and vented to Lime Kiln 3, Lime Kiln 4, and/or Power Boiler 20 except for each knotter system that does not exceed 0.1 pounds of HAPs per ODP ton, and each screen system that does not exceed 0.2 pounds HAPs per ODP ton.	40 CFR 63.443(a)(1)(ii)(A) 40 CFR 63.443(a)(1)(ii)(B) 40 CFR 63.443(c)
D3.2	HAPs: Collection and Treatment	Introduce HVLC gases with the primary fuel or into flame zone of Lime Kiln 3, Lime Kiln 4, and/or Power Boiler 20.	40 CFR 63.443(d)(4)



HVLC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D3.3	HAPs: Enclosures	<p>The HVLC system shall maintain negative pressure at each enclosure or hood opening as demonstrated by the procedures specified in 40 CFR 63.457(e). Each enclosure or hood opening closed during the initial performance test specified in 40 CFR 63.457(a) shall be maintained in the same closed and sealed position as during the performance test at all times except when necessary to use the opening for sampling, inspection, maintenance, or repairs.</p> <p><i>Monthly Inspections:</i></p> <p>For each enclosure opening, a visual inspection of the closure mechanism shall be performed at least once every 30 days to ensure the opening is maintained in the closed position and sealed.</p> <p>For this condition, 30 days shall be interpreted to mean: at least once per calendar month with no two consecutive inspections occurring within 14 days.</p> <p><i>Annual Inspections:</i></p> <p>Demonstrate annually that each enclosure opening is maintained at negative pressure as specified in 40 CFR Part 63.457(e).</p>	<p>40 CFR 63.450(a) and (b)</p> <p>40 CFR 63.453(k)(1) for monthly inspections</p> <p>40 CFR 63.453(k)(4) for annual inspections</p>

HVLC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D3.4	HAPs: Closed-vent system	<p>Each component of the closed-vent system used to control HVLC non-condensable gas source group emission that is operated at positive pressure and located prior to a control device shall be designed for and operated with no detectable leaks as indicated by an instrument reading of less than 500 ppmv above background, as measured by 40 CFR Part 60, Appendix A, Method 21.</p> <p><i>Monthly Inspections:</i></p> <p>Each closed vent system (reasonably accessible ductwork, piping, enclosures, and connections to covers in the collection system for the HVLC system) shall be visually inspected for visible evidence of defects every 30 days or as requested by Ecology.</p> <p>For this condition, 30 days shall be interpreted to mean: at least once per calendar month with no two consecutive inspections occurring within 14 days.</p> <p><i>Annual Inspections:</i></p> <p>Measure annually components of closed-vent systems under positive pressure for detectable leaks as specified in 40 CFR 63.457(d).</p>	<p>40 CFR 63.450(a) and (c)</p> <p>40 CFR 63.453(k)(2) for monthly inspections</p> <p>40 CFR 63.453(k)(3) for annual inspections</p>
D3.5	HAPs: Collection and Treatment	<p>Each bypass line in the closed-vent system that could divert vent streams containing HAP to the atmosphere without meeting the emission limitations in §§63.443 shall comply with either of the following requirements:</p> <p>(1) On each bypass line, the Permittee shall install, calibrate, maintain, and operate according to the manufacturer's specifications a flow indicator that is capable of taking periodic readings as frequently as specified in 40 CFR 63.454(e). The flow indicator shall be installed in the bypass line in such a way as to indicate flow in the bypass line (note: monitoring bypass valve position is a satisfactory flow indicator); or</p> <p>(2) For bypass line valves that are not computer controlled, the Permittee shall maintain the bypass line valve in the closed position with a car seal or a seal placed on the valve or closure mechanism in such a way that valve or closure mechanism cannot be opened without breaking the seal</p>	40 CFR 63.450(d)

HVLC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D3.6	HAPs: Monthly Inspections	<p>The valve or closure mechanism specified in § 63.450(d)(2) shall be inspected at least once every 30 days to ensure that the valve is maintained in the closed position and the emission point gas stream is not diverted through the bypass line.</p> <p>For this condition, 30 days shall be interpreted to mean: at least once per calendar month with no two consecutive inspections occurring within 14 days.</p>	<p>40 CFR 63.453(k)(5)</p> <p>Order 3463-AQ07</p>
D3.7	HAPs: Inspection Corrective Action	<p>If an inspection of the HVLC system identifies visible defects, or if an instrument reading of 500 ppmv or greater above background is measured by 40 CFR 60, Appendix A, Method 21 in accordance with the procedures in 40 CFR 63.457(d), or if enclosure openings are not maintained at negative pressure, take the following corrective action as soon as practicable.</p> <p>Make a first effort to repair or correct the closed-vent system as soon as practicable, but no later than 5 calendar days after the problem is identified.</p> <p>Complete the repair or corrective action no later than 15 days after the problem is identified. Delay of repair or corrective action is allowed if the repair or corrective action is technically infeasible without a process unit shutdown or if the Permittee determines that the emissions resulting from immediate repair would be greater than the emission likely to result from delay of repair. Repair of such equipment shall be completed by the end of the next process shutdown.</p>	<p>40 CFR 63.453(k)(6)</p> <p>40 CFR 63.457(d)</p>

HVLC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D3.8	HAPs: Recordkeeping	<p>For each applicable enclosure opening, closed vent system, and closed collection system, prepare and maintain a site-specific inspection plan, including a drawing or schematic of the components of applicable affected equipment and shall record the following information for each inspection:</p> <ol style="list-style-type: none"> <li>(1) Date of inspection;</li> <li>(2) Equipment type and identification;</li> <li>(3) Results of negative pressure tests for enclosures;</li> <li>(4) Results of leak detection tests;</li> <li>(5) The nature of the defect or leak and the method of detection;</li> <li>(6) The date the defect or leak was detected and the date of each attempt to repair the defect or leak;</li> <li>(7) Repair methods applied in each attempt to repair the defect or leak;</li> <li>(8) Reason for the delay if the defect or leak is not repaired within 15 days;</li> <li>(9) Expected date of successful repair of the defect or leak if the repair is not completed within 15 days;</li> <li>(10) Date of successful repair of the defect or leak;</li> <li>(11) Position and duration of opening of bypass line valves and the condition of any valve seals; and</li> <li>(12) Duration of the use of manual or computer-controlled bypass valves.</li> </ol>	40 CFR 63.454(a) and (b)
D3.9	HAPs: Recordkeeping	Records shall be maintained for all periods of excess emissions. Periods of excess emissions from the HVLC system are not violations of 40 CFR 63.443(c) and (d) provided that the time of excess emissions divided by the total process operating time in a semiannual reporting period does not exceed four (4) percent.	40 CFR 63.443(e)(2)

HVLC	Parameter	Limit, Monitoring, Reporting, Recordkeeping	Applicable Requirements
D3.10	HAPs: CCA Collection and Treatment	<p>Collect condensates from the following sources (CCA units) and route them via hard piping to the Dedicated Control Device (DCD) for treatment:</p> <p>#9 Evaporator – “clean” side of the surface condenser, #10 Evaporator – “clean” side of the surface condenser, #10 Evaporator – “clean” side of the 7<sup>th</sup> effect.</p> <p>For these sources, follow the inspection, repair, and reporting requirements in 40 CFR 63.443(l).</p> <p>Washer lines No. 5, 6 and 7 for which these additional collection requirements were established have been permanently retired from service.</p>	<p>40 CFR 63.447 Order 2737-AQ05, Table 1</p>
D3.11	HAPs: CCA Collection and Treatment	<p>Collect an additional 1.0 lb/ODTP of HAPs as measured at the inlet to the DCD. Compliance shall be demonstrated by collection <math>\geq 8.2</math> lb/ODTP of HAPs based on a 30-day rolling average (this includes the <math>\geq 7.2</math> lb/ODTP amount required to meet the 40 CFR 63.446(c) collection requirements).</p> <p>Washer lines No. 5, 6 and 7 for which these additional collection requirements were established have been permanently retired from service.</p>	<p>40 CFR 63.447 Order 2737-AQ05, Table 1</p>
D3.12	HAPs: CCA Collection and Treatment	<p>Destroy an additional 1.0 lb/ODTP of HAPs as measured at the outlet of the DCD. Compliance shall be demonstrated by destroying <math>\geq 7.6</math> lb/ODTP of HAPs based on a 30-day rolling average (this includes the <math>\geq 6.6</math> lb/ODTP amount required to meet the 40 CFR 63.446(e) treatment requirements).</p> <p>Washer lines No. 5, 6 and 7 for which these additional collection requirements were established have been permanently retired from service.</p>	<p>40 CFR 63.447 Order 2737-AQ05, Table 1</p>

**E1. NEUTRAL SULFITE SEMI-CHEMICAL PLANT (NSSC)**

NSSC	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
E1.1	VOC (as carbon)	26.4 tpy	<p>Calculate and report per table footnote below.</p> <p>The VOC emission factors for Hi Density Storage #1, Hi Density Storage #2, Lo Density Storage, Side Hill Screen, and Wash Water Chest shall be updated every fifth year following issuance of Order 3462-AQ07.</p> <p>At least one source test shall be conducted at each emission point to supplement the existing data prior to emission factor recalculation (due to safety considerations, the Hi Density Storage #2 emission factor may be calculated based on the VOC concentration in the Hi Density Storage #1 vent). Data collection for calculation of the VOC emission factors shall conform with EPA RM 25A. See table footnote below for additional information.</p> <p><i>Reporting:</i></p> <p>The following information for the NSSC shall be included for the previous year in each January monthly report:</p> <ul style="list-style-type: none"> <li>- Hours of NSSC operation during the calendar year;</li> <li>- NSSC pulp produced during the calendar year as ODTP; and</li> <li>- VOC emitted in tons/year during the calendar year.</li> </ul>	Order 3462-AQ07, Modification 1, Appendix A
E1.2	N/A	N/A	Gases from the new chip bin (presteaming bin), refined stock blow tank, and chemi-washer filtrate vent of the NSSC pulping process shall be collected and burned as NCGs.	Order 3462-AQ07, Modification 1, Appendix A

NSSC	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
E1.3	N/A	N/A	Prior to charging any material from the kraft process into the NSSC system, the Permittee shall submit information to Ecology and the EPA Office of Air Quality Planning and Standards (OAQPS) for a determination of New Source Performance Standards (NSPS) for Kraft Pulping Mills (40 CFR Part 60, Subpart BB) applicability. The Permittee shall provide any additional information request to make the determination in a timely manner. Prior to charging material from the kraft process into the NSSC system during the decision making period, the Permittee shall install and operate controls equivalent to those required by 40 CFR Part 60, Subpart BB. After receiving the OAQPS decision, Ecology shall, if necessary, issue an Order to the Permittee concerning compliance with the NSPS rules.	Order 3462-AQ07, Modification 1, Appendix A
E1.4	N/A	N/A	The operation and maintenance manual for the NSSC shall contain a section specifying best management practices necessary to meet toxics and VOC emission rates included in the NOC application. Copies of the manual shall be kept on file at the facility and be available for inspection. Failure to follow the best management practices specified in the manual to meet the toxics and VOC emission rates shall be considered proof of excess emission due to the equipment not being properly operated and maintained in accordance with RCW 70.94.152(7).	Order 3462-AQ07, Modification 1, Appendix A

*Footnote:*

Compliance with NSSC VOC annual limit shall be calculated as follows:

$$\text{Tons per year (TPY) of VOC} = (\text{TPY of VOC from Hi Density Storage \#1}) + (\text{TPY of VOC from Hi Density Storage \#2}) + (\text{TPY of VOC from Lo Density Storage}) + (\text{TPY of VOC from Side Hill Screen}) + (\text{TPY of VOC from Wash Water Chest})$$

Tons per year of VOC from the individual emission points shall be calculated as follows during the first five years after the issuance of Order 3462-AQ07.

VOC from Hi Density Storage #1, Hi Density Storage #2, and Lo Density Storage shall be calculated as follows:

$$\frac{\text{ton VOC}}{\text{yr}} = \frac{\text{hrs NSSC operation}}{\text{yr}} \times \frac{\text{lb C}}{\text{hr}} \times \frac{\text{ton VOC}}{2000 \text{ lb VOC}}$$

Where  $\frac{\text{lb C}}{\text{hr}}$  is:  $0.035 \frac{\text{lb C}}{\text{hr}}$  for Hi Density Storage #1

$0.090 \frac{\text{lb C}}{\text{hr}}$  for Hi Density Storage #2

$0.004 \frac{\text{lb C}}{\text{hr}}$  for Lo Density Storage

VOC from the Side Hill Screen and the Wash Water Chest shall be calculated as follows:

$$\frac{\text{ton VOC}}{\text{yr}} = \frac{\text{ODTP (NSSC)}}{\text{yr}} \times \frac{\text{lb C}}{\text{ODTP}} \times \frac{\text{ton VOC}}{2000 \text{ lb VOC}}$$

Where lb C/ODTP is:  $0.099 \frac{\text{lb C}}{\text{ODTP}}$  for Side Hill Screen

$0.039 \frac{\text{lb C}}{\text{ODTP}}$  for the Wash Water Chest

The VOC emission factors:

$\frac{\text{lb C}}{\text{hr}}$  for Hi Density Storage #1

$\frac{\text{lb C}}{\text{hr}}$  for Hi Density Storage #1

$\frac{\text{lb C}}{\text{hr}}$  for Lo Density Storage

$\frac{\text{lb C}}{\text{ODTP}}$  for the Side Hill Screen

$\frac{\text{lb C}}{\text{ODTP}}$  for the Wash Water Chest



Shall be updated every fifth year. At least one source test shall be conducted at each emission point to supplement the existing data prior to emission factor recalculation (due to safety considerations, the Hi Density Storage #2 emission factor may be calculated based on the VOC concentration in the Hi Density Storage #1 vent). Data collection for calculation of the VOC emission factors shall conform with RM 25A as defined in the footnotes for Table 1 of the order. The method for recalculation shall be as follows:

Updated Emission Factor =  $(0.6 \times EA) + (0.4 \times AF)$

Where: EA is the emission factor used for emission calculations, and

AF is the emission factor for data collected during the five year period.

The updated VOC emission factor shall be submitted to Ecology prior to the end of the fifth year after permit issuance, and every five years thereafter. Calculation with the updated VOC emission factors shall commence at the end of the fifth year after permit issuance and every five years thereafter.

**F1. DIGESTERS, MULTI-EFFECT EVAPORATORS, BROWNSTOCK WASHERS, AND CONDENSATE STRIPPER SYSTEMS**

The Kamyr Digester No.1; Kamyr Digester No. 2; and Multiple-effects Evaporator Set 10 are NSPS applicable units (40 CFR Part 60, Subpart BB). These sources shall comply with the general requirements of 40 CFR Part 60, including:

- 40 CFR 60.7(b) & (f) concerning recordkeeping,
- 40 CFR 60.7(c), (d), & (e) concerning reporting,
- 40 CFR 60.11(d) concerning operation and maintenance,
- 40 CFR 60.12 concerning concealment,
- 40 CFR 60.13 concerning monitoring,
- 40 CFR 60.19 concerning notification and reporting.

	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
F1.1	TRS – NSPS units (Kamyr Digester No.1; Kamyr Digester No. 2; and Multiple-effects Evaporator Set 10)	5 ppmv @ 10 % O <sub>2</sub> , unless combusted in a lime kiln or equivalent	Monitoring required by conditions C1.6b, C2.6b, and G1.5 shall be used to demonstrate compliance with this requirement.  Excess emissions and monitoring systems performance reports meeting the requirements of 40 CFR 60.284(d) and (e) shall be submitted semi-annually. Report shall be postmarked by the 30 <sup>th</sup> day following the end of each six-month period.	40 CFR 60.283(a)(1) for emission limit

	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
F1.2	TRS	N/A	<p>All noncondensable gases from the digesters, evaporators, and condensate stripper system shall be continuously treated to reduce the emission of TRS equal to the reduction achieved by thermal oxidation in a lime kiln and/or power boiler.</p> <p>The noncondensable gases shall be burned in one of, or a combination of the following units: LK3, LK4, LK5 and/or PB20.</p> <p>To provide continuous treatment:</p> <ul style="list-style-type: none"> <li>- The NCG collection and treatment system shall be properly operated and maintained at all times,</li> <li>- Venting shall be minimized, and</li> <li>- Venting necessary for safe/proper system operation and maintenance shall not exceed 10 hours per month.</li> </ul> <p>Report venting duration and cause in the monthly air report.</p>	<p>WAC 173-405-040(4)</p> <p>Order 3462-AQ07, Modification 1 and Order 8429, Modification 1, Condition 11</p>

**The following state-only requirement is not federally enforceable under the federal Clean Air Act.**

	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
F1.3	TRS	Noncondensibles from digesters, multiple-effect evaporators and condensate stripper system shall be treated to reduce TRS emissions equal to reduction achieved by thermal oxidation in a lime kiln; install a backup treatment system.	Monitoring required by Condition F1.1 shall be used to demonstrate compliance with this requirement.	WAC 173-405-040(4)

	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
F1.4	Methanol	300 ppm, 12 month rolling average	Collect representative sample monthly (from the final stage brownstock washer shower water) and analyze using NCASI 94.02. Report monthly test results and 12-month rolling average in monthly report.	Order No. 9213, Condition 1

**G1. POWER BOILER 20 (PB20)**

This source shall comply with the requirements of 40 CFR Part 60, Subpart D for NO<sub>x</sub> and SO<sub>2</sub> and Subpart Db for PM and opacity. The source shall also comply with the General Requirements of 40 CFR Part 60, including:

- 40 CFR 60.7(b) & (f) concerning recordkeeping,
- 40 CFR 60.7(c), (d), & (e) concerning reporting,
- 40 CFR 60.11(d) concerning operation and maintenance,
- 40 CFR 60.12 concerning concealment,
- 40 CFR 60.13 concerning monitoring,
- 40 CFR 60.19 concerning notification and reporting.

The emission unit shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 10 of Subpart DDDDD.

Opacity limits apply to each stack individually. All other limits apply to the total emissions from the combined stacks.

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.1a	PM & PM <sub>10</sub> - filterable	0.025 gr/dscf @ 7% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i> Sample M/Q using RM 5 (see Appendix A).</p> <p><i>Reporting:</i> Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i> See Conditions G1.12, G1.13, and G1.14 for compliance assurance monitoring requirements. The Permittee shall comply with the general CAM requirements in Condition M. CAM reporting required on at a minimum semiannual basis.</p>	<p>Order 8429, Modification 1, Condition 5.1</p> <p>40 CFR 70.6(a)(3) for streamlining of source test frequency requirement with PSD 01-03</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.1b	PM & PM <sub>10</sub> - filterable	0.030 gr/dscf @ 7% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i> Sample M/Q using RM 5 (see Appendix ApA.2).</p> <p><i>Reporting:</i> Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p><i>Compliance Assurance Monitoring:</i> See Condition G1.1a for CAM requirements.</p>	<p>Order 3466-AQ07, Condition 1</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
G1.1c	PM & PM <sub>10</sub>	0.048 gr/dscf @ 7% O <sub>2</sub> , 1-hr average	Same as previous limit.	<p>PSD 01-03, Amendment 3, Condition 1.86</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
G1.1d	PM	0.2 gr/dscf @ 7% O <sub>2</sub> , 1-hr average	<p>Same as Condition G1.1a.</p> <p>CAM demonstration same as previous limits.</p>	<p>WAC 173-405-040(5)(a)</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.1e	PM	0.085 lb/MMBtu, when firing natural gas, oil, or a mixture of these fuels with solid fuels when combusting greater than 30% wood on an annual basis	Compliance with the limit may be demonstrated using the methods described in 40 CFR Part 60, Subpart Db, or alternative monitoring of PM and/or opacity proposed per 40 CFR 60.13(i).	40 CFR 60.43b(h)(4) for emission limit
G1.1f	PM – total	0.089 gr/dscf @ 7% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i></p> <p>Sample Q/A using RM 5/RM 202 (see Appendix A). See Condition G2.1c for reporting requirement. See Condition 15 of Order 8429 for additional calculation and reporting requirements.</p> <p><i>Reporting:</i></p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p>See Condition G1.1a for CAM requirements.</p>	<p>Order 8429, Modification 1, Condition 5.2</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.1g	PM <sub>10</sub> - total	0.083 gr/dscf @ 7% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i></p> <p>Sample Q/A using RM 5/RM 202 (see Appendix A). See Condition G1.1c for reporting requirement. See Condition 15 of Order 8429 for additional calculation and reporting requirements.</p> <p><i>Reporting:</i></p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p>See Condition G1.1a for CAM requirements.</p>	<p>Order 8429, Modification 1, Condition 5.3</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>
G1.1h	PM <sub>2.5</sub> - total	0.081 gr/dscf @ 7% O <sub>2</sub> , 1-hr average	<p><i>Performance Testing:</i></p> <p>Sample Q/A using RM 5/RM 202 (see Appendix A). See Condition G2.1c for reporting requirement. See Condition 15 of Order 8429 for additional calculation and reporting requirements.</p> <p><i>Reporting:</i></p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p> <p>See Condition G1.1a for CAM requirements.</p>	<p>Order 8429, Modification 1, Condition 5.4</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>



<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.1i	PM & PM <sub>10</sub> - filterable	234 tpy, 12-month rolling total	Calculate per Appendix ApA.4. Report monthly. See Condition G1.1a for CAM requirements.	Order 3466-AQ-07, Condition 1  40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping
G1.1j	PM & PM <sub>10</sub>	365 tpy, 12-month rolling total	Same as previous limit. CAM demonstration same as previous limits.	PSD 01-03, Amendment 3, Condition 1.86  40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.2	HAP Metals (PM as a surrogate)	4.4 E-01 lb of PM/MMBtu of heat input  (Boiler MACT Emission Limit - hybrid suspension grate boiler designed to fire wet biomass/bio-based solid)	<p><i>Performance Testing:</i></p> <p>Reference Test Method is EPA RM 5.</p> <p>Performance tests are to be conducted in accordance with the requirements in 40 CFR 63.7520.</p> <p>Conduct tests annually, no more than 13 months after the previous performance test. If performance tests for at least 2 consecutive years show that emissions are at or below 75 percent of the emission limit and there are no changes in the operation of the boiler, performance tests may be performed every third year.</p> <p>Operating limit (see conditions below) must be confirmed or reestablished during performance tests.</p> <p>Develop a site-specific test plan in accordance with 40 CFR 63.7520(a). Upon Ecology request, the Permittee shall submit the site-specific test plan for approval.</p> <p><i>60-day Notification:</i></p> <p>Notification of Intent to conduct a performance test must be provided to the Administrator 60 days before the performance test is scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must keep records of all performance tests.</p> <p><i>Reporting:</i></p> <p>Semi-annual compliance reporting in accordance with 40 CFR 63.7550.</p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p>	<p>40 CFR 63.7500(a)(1) and Table 2 (Item 13b) for emission limit</p> <p>40 CFR 63.7515(a) and (b) for testing frequency</p> <p>40 CFR 63.7520 and Table 5 (Item 1) for performance testing requirements</p> <p>40 CFR 63.7540(a)(1), Table 4 (Item 1 and 4), and Table 7 (Items 1a, 1b, and footnote a) for operating limit confirmation/reestablishment</p> <p>40 CFR 63.7520(a) for site-specific test plan requirement</p> <p>40 CFR 63.7545(d) for performance test notification</p> <p>40 CFR 63.7555(a)(2) for recordkeeping</p> <p>40 CFR 63.7515(f) and 63.7550 for reporting</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.3a	Opacity	20% average for more than 6 consecutive minutes in any 60 minute period	<p>Emission control parameter monitoring is required when exhaust gasses are being emitted as a result of combustion in the unit or the unit ID fan is being operated as part of the cool down process for unit shutdown. Maintain emission control parameter hourly average rates at levels specified in the "Emission Control Compliance Demonstration Plan" (see Appendix B).</p> <p>Continuously monitor parameters specified in the plan.</p> <p>Whenever any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met, corrective action must be initiated within 24 hours. Failure to initiate corrective action within 24 hours is a violation of WAC 173-405-040(8) and may be a violation of the underlying applicable requirement. Report deviations from these operating parameters that last longer than 3 hours and corrective action in the monthly report.</p> <p>Compliance may also be determined by RM 9.</p> <p>Limit is applicable to each stack individually.</p>	<p>Order 3462-AQ07, Modification 1, Appendix A</p> <p>40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.3b	Opacity	20% average for more than 6 consecutive minutes in any 60 minute period, except for emissions due to soot blowing or grate cleaning for up to 15 minutes in 8 consecutive hours	EPA Method 9 is the reference test method. Continuous monitoring same as above. Limit is applicable to each stack individually.	WAC 173-405-040(6) for limit 40 CFR 64.2 and 64.6 through 64.9 for respective PM CAM monitoring and reporting/recordkeeping

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.3c	Opacity	20 % (6-minute average), except for one 6-minute period per hour of not more than 27% opacity.  (Limit is not applicable when only natural gas is fired in PB 20).  (PM surrogate)	Emission control parameter monitoring is required when exhaust gasses are being emitted as a result of combustion in the unit or the unit ID fan is being operated as part of the cool down process for unit shutdown. Maintain emission control parameter hourly average rates at levels specified in the "Emission Control Compliance Demonstration Plan" (see Appendix B).  Continuously monitor parameters specified in the plan.  Whenever any 3-hr average of a level specified in the "Emission Control Compliance Demonstration Plan" is not met, corrective action must be initiated within 24 hours. Report deviations from these operating parameters that last longer than 3 hours and corrective action in the monthly report.  The PM and opacity standards shall apply at all times except startup, shutdown, or malfunction.  Limit is applicable to each stack individually.	40 CFR 60.43b(f) for emission limit  40 CFR 60.43b(g) for SSM  EPA approved alternative opacity monitoring via letter dated February 24, 2012
G1.4a	SO <sub>2</sub>	100 ppmdv @ 7% O <sub>2</sub> , 3-hr average	Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS 2 (see Appendix ApA.2).  See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.  Report 3-hr average concentrations, monthly average concentrations, maximum monthly 3-hr average concentration, and exceedances monthly.	PSD 01-03, Amendment 3, Condition 1.87
G1.4b	SO <sub>2</sub>	1,000 ppm @ 7% O <sub>2</sub> , 1-hr average	Same as previous limit.	WAC 173-405-040(9)(b)

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.4c	SO <sub>2</sub>	0.80 lb/MMBtu, 3-hr average	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B PS 2 (see Appendix ApA.2).</p> <p>Report 3-hr average concentrations, monthly average concentrations, maximum monthly 3-hr average concentration, and exceedances monthly.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 60.7(c) and 40 CFR 60.45(g), postmarked by the 30th day following the end of each six-month period (or on a more frequent basis in accordance with the criteria in 40 CFR 60.7(c)).</p>	<p>40 CFR 60.43(a)(1) for emission limit</p> <p>40 CFR 60.45(a) for monitoring</p>
G1.4d	SO <sub>2</sub>	946 tpy, 12-month rolling total	Calculate per Appendix ApA.4. Report monthly.	PSD 01-03, Amendment 3, Condition 1.87
G1.5	TRS	Temperature ≥1,200°F and retention time ≥ 0.5 seconds when burning NCGs	Monitoring not required.	40 CFR 60.283(a)(1)(iii) for standard

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.6a	CO	900 lb/hr, 8-hr average	<p><i>Performance Testing:</i></p> <p>Sample A/M using RM 10 (see Appendix ApA.4). Calculate per Appendix ApA.4 without dividing by fuel applied.</p> <p><i>Reporting:</i></p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p>	PSD 01-03, Amendment 3, Condition 1.88

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.6b	CO	3,500 ppm by volume on a dry basis; corrected to 3% O <sub>2</sub> (3-run average)  Boiler MACT Emission Limit	<p><i>Performance Testing:</i></p> <p>Reference Test Method is EPA RM 10. Use a measurement span value 2 times the concentration of the applicable emission limit.</p> <p>Performance tests are to be conducted in accordance with the requirements in 40 CFR 63.7520.</p> <p>Conduct tests annually, no more than 13 months after the previous performance test. If performance tests for at least 2 consecutive years show that emissions are at or below 75 percent of the emission limit and there are no changes in the operation of the boiler, performance tests may be performed every third year.</p> <p>Develop site-specific test plan in accordance with 40 CFR 63.7520(a). Upon Ecology request, the Permittee shall submit the site-specific test plan for approval.</p> <p><i>60-day Notification:</i></p> <p>Notification of Intent to conduct a performance test must be provided to the Administrator 60 days before the performance test is scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must keep records of all performance tests.</p> <p><i>Reporting:</i></p> <p>Semi-annual compliance reporting in accordance with 40 CFR 63.7550.</p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p>	<p>40 CFR 63.7500(a)(1) and Table 2 (Item 13a) for emission limit</p> <p>40 CFR 63.7515(a) and (b) for testing frequency</p> <p>40 CFR 63.7545(d) for performance test notification</p> <p>40 CFR 63.7520 and Table 5 (Item 5) for performance testing requirements</p> <p>40 CFR 63.7520(a) for site-specific test plan requirement</p> <p>40 CFR 63.7555 for recordkeeping</p> <p>40 CFR 63.7515(f) and 63.7550 for reporting</p>



<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.6c	CO (oxygen as a surrogate)	Operate an oxygen trim system with the oxygen level set no lower than the lowest hourly average oxygen concentration measured during the most recent CO performance test as the operating limit for oxygen (Boiler MACT Operating Limit)	Semi-annual compliance reporting in accordance with 40 CFR 63.7550.	40 CFR 63.7525(a)(7) 40 CFR 63.7540 for monitoring requirements 40 CFR 63.7500(a)(2) for operating limit 40 CFR 63.7550 and Table 9 for reporting
G1.6d	CO	3,942 tpy, 12-month rolling total	Calculate per Appendix ApA.3. Report monthly.	PSD 01-03, Amendment 3, Condition 1.88

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.7a	NO <sub>x</sub> (when firing only NG)	0.20 lb/MMBtu fuel application rate, 3-hr average  (as NO <sub>2</sub> )	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS 2 (see Appendix ApA.2). See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report 3-hr average concentrations, monthly average concentration, maximum monthly 3-hr average concentration, and excursions monthly.</p>	PSD 01-03, Amendment 3, Condition 1.89
G1.7b	NO <sub>x</sub> (when firing only NG)	0.20 lb/MMBtu fuel application rate, 3-hr average  (as NO <sub>2</sub> )	<p>Same as for previous limit.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 60.7(c) and 40 CFR 60.45(g), postmarked by the 30th day following the end of each six-month period (or on a more frequent basis as determined necessary by Ecology).</p>	<p>40 CFR 60.44(a)(1) for emission limit</p> <p>40 CFR 60.45(a) for monitoring</p>
G1.7c	NO <sub>x</sub> (when firing other fuel)	0.30 lb/MMBtu fuel application rate, 3-hr average  (as NO <sub>2</sub> )	<p>Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B PS 2 (see Appendix ApA.2). See Facility-wide General Requirement, Condition 26 for continuous emission monitoring system-operating requirements.</p> <p>Report 3-hr average concentrations, monthly average concentration, maximum monthly 3-hr average concentration, and excursions monthly.</p>	PSD 01-03, Amendment 3, Condition 1.89
G1.7d	NO <sub>x</sub> (when firing other fuel)	0.30 lb/MMBtu fuel application rate, 3-hr average  (as NO <sub>2</sub> )	<p>Same as previous limit.</p> <p>The Permittee must submit a <i>Semi-Annual Excess Emissions and Continuous Monitoring Systems Performance or Summary Report</i> in accordance with 40 CFR 60.7(c) and 40 CFR 60.45(g), postmarked by the 30th day following the end of each six-month period (or on a more frequent basis as determined necessary by Ecology).</p>	<p>40 CFR 60.44(a)(2) for emission limit</p> <p>40 CFR 60.45(a) for monitoring</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.7e	NO <sub>x</sub>	0.150 lb/MMBtu – 30-day average (as NO <sub>2</sub> )	Monitor continuously using CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B, PS 2 (see Appendix A). Report 24-hr average concentration, 30-day rolling average concentrations, maximum monthly 30-day average concentration, and exceedances monthly. This limit will become effective per the timeline specified in Condition 5, Order 8429.	Order 8429, Modification 1, Condition 5.5
G1.7f	NO <sub>x</sub>	1183 tpy, 12-month rolling total (as NO <sub>2</sub> )	Calculate per Appendix ApA.4. Report monthly.	PSD 01-03, Amendment 3, Condition 1.89
G1.8	NH <sub>3</sub>	25 ppmv @ 7% O <sub>2</sub> , 24-hr average	Sample A/M (see Appendix A) using Bay Area Air Quality Management District (BAAQMD) Source Test Procedure ST-1B or alternative method approved by Ecology. Each source test result shall represent a 24-hr average for comparison to the limit. The initial source test shall be conducted when the unit is operating at ≥95% of the maximum hourly rate. Subsequent source tests shall be conducted when the unit is operating at ≥95% of the maximum hourly rate the unit operated since the prior source test. Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.	Order 8429, Modification 1, Condition 5.6
G1.9	O <sub>2</sub>	No limit – required for O <sub>2</sub> correction	Monitor continuously using a CEMS that conforms to 40 CFR Part 60, Appendix F and Appendix B PS 3.	40 CFR 60.45(a) and Order 3462-AQ07, Modification 1, Appendix A

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.10	Operating Limit	900 MMBtu/hr fuel application rate	Report average hourly fuel application rate in MMBtu/hr in monthly report (see Appendix ApA.1).	PSD 01-03, Amendment 3, Condition 1.85
G1.11	Stack Dimensions	N/A	<p>The modified or replaced exhaust stacks shall be designed in such a way that modeled exhaust gas dispersion is equal to or better than that indicated for the originally-proposed design in the modeling reported in the application for this PSD permit. Plans for the stack design must be approved in writing by Ecology prior to initiation of construction of the stack. Construction of the modified or replacement stacks shall be consistent with design (approved construction completed).</p> <p>Certify stack dimensions meet discharge characteristics presented in the PSD application (certification completed). Report any changes to stack diameter or height after stack dimensions are certified.</p>	<p>PSD 01-03, Amendment 3, Condition 5</p> <p>Order 3462-AQ07, Modification 1, Appendix A</p>
G1.12	HAP Metals and Mercury (WESP Operating Limit)	Maintain the 30-day rolling average total secondary electric power input of the electrostatic precipitator at or above the operating limits established during the performance test demonstrating	<p><i>Monitoring:</i></p> <p>The Permittee shall install sensors to measure (secondary) voltage and current to the precipitator collection plates.</p> <p>Develop a site-specific monitoring plan in accordance with 40 CFR 63.7505(d). Upon Ecology request, the Permittee shall submit the site-specific monitoring plan for approval.</p> <p>Performance evaluations of the electric power monitoring system must be conducted in accordance with the monitoring plan at the time of each performance test but no less frequently than annually.</p> <p>Continuous compliance demonstrated in accordance with 40 CFR 63.7540 and Table 8 (Item 7) in the subpart.</p>	<p>40 CFR 63.7525(h)</p> <p>40 CFR 63.7500(a)(2) and Table 4 (Item 4b) for operating limit</p> <p>40 CFR 63.7540 and Table 8 (Item 7) for monitoring requirements</p> <p>40 CFR 63.7505(d) for site-specific monitoring plan</p> <p>40 CFR Part 63, Subpart DDDDD, Table 7 (Item</p>

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
		compliance with the PM or Mercury emission limit	<p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Establishing Operating Limit:</i></p> <p>Secondary power operating limit to be established according to Table 7 (Item 1b) in the subpart. Operating limit must be confirmed or reestablished during performance tests. Minimum total secondary electric power input must be set at the higher of the minimum values established during the performance tests for HAP metals and mercury.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee shall keep records of all monitoring data and calculated averages for secondary power.</p> <p><i>Reporting:</i></p> <p>Report deviations monthly.</p> <p>Semi-annual compliance reporting in accordance with 40 CFR 63.7550.</p>	<p>1b) for establishing operating limit</p> <p>40 CFR 63.7555 for recordkeeping</p> <p>40 CFR 63.7550 and Table 9 for reporting</p> <p>WAC 173-401-615(3)(b) for monthly reporting of deviations</p>

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.13	HAP Metals and Mercury (Scrubber Operating Limit)	Maintain the 30-day rolling average pressure drop at or above the lowest one-hour average pressure drop measured during the performance test demonstrating compliance with the PM or Mercury emission limit	<p><i>Monitoring:</i></p> <p>Continuously monitor the scrubber pressure drop using a pressure monitoring system according to 40 CFR 63.7525(f).</p> <p>Demonstrate continuous compliance in accordance with 40 CFR 63.7540 and Table 8 (Item 4) of the subpart.</p> <p>Develop a site-specific monitoring plan in accordance with 40 CFR 63.7505(d). Upon Ecology request, the Permittee shall submit the site-specific monitoring plan for approval.</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Establishing Operating Limit:</i></p> <p>Pressure drop to be established according to Table 7 (Item 1a) in the subpart. Operating limit must be confirmed or reestablished during performance tests. Minimum pressure drop must be set at the higher of the minimum values established during the performance tests for HAP metals and mercury.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee shall keep records of all monitoring data and calculated averages for scrubber pressure drop.</p> <p><i>Reporting:</i></p> <p>Report deviations monthly.</p> <p>Semi-annual compliance reporting in accordance with 40 CFR 63.7550.</p>	<p>40 CFR 63.7525(f)</p> <p>40 CFR 63.7540 and Table 8 (Item 4) for monitoring requirements</p> <p>40 CFR 63.7500(a)(2) and Table 4 (Item 1) for operating limit</p> <p>40 CFR 63.7505(d) for site-specific monitoring plan</p> <p>40 CFR Part 63, Subpart DDDDD, Table 7 (Item 1) for establishing operating limit</p> <p>40 CFR 63.7555 for recordkeeping</p> <p>40 CFR 63.7550 and Table 9 for reporting</p> <p>WAC 173-401-615(3)(b) for monthly reporting of deviations</p>

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.14	HAP Metals and Mercury (Scrubber Operating Limit)	Maintain the 30-day rolling average liquid flow rate at or above the lowest one-hour average liquid flow rate measured during the performance test demonstrating compliance with the PM or mercury emission limit	<p><i>Monitoring:</i></p> <p>Continuously monitor the scrubber liquid flow rate using a flow monitoring system according to 40 CFR 63.7525(e).</p> <p>Demonstrate continuous compliance in accordance with 40 CFR 63.7540 and Table 8 (Item 4) of the subpart.</p> <p>Develop a site-specific monitoring plan in accordance with 40 CFR 63.7505(d). Upon Ecology request, the Permittee shall submit the site-specific monitoring plan for approval.</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p><i>Establishing Operating Limit:</i></p> <p>Scrubber liquid flow rate to be established according to Table 7 (Item 1) in the subpart. Operating limit must be confirmed or reestablished during performance tests. Minimum liquid flow rate must be set at the higher of the minimum values established during the performance tests for HAP metals and mercury.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee shall keep records of all monitoring data and calculated averages for scrubber flow rate.</p> <p><i>Reporting:</i></p> <p>Report deviations monthly.</p> <p>Semi-annual compliance reporting in accordance with 40 CFR 63.7550.</p>	<p>40 CFR 63.7525(e)</p> <p>40 CFR 63.7540 and Table 8 (Item 4) for monitoring requirements</p> <p>40 CFR 63.7500(a)(2) and Table 4 (Item 1) for operating limit</p> <p>40 CFR 63.7505(d) for site-specific monitoring plan</p> <p>40 CFR Part 63, Subpart DDDDD, Table 7 (Item 1) for establishing operating limit</p> <p>40 CFR 63.7555 for recordkeeping</p> <p>40 CFR 63.7550 and Table 9 for reporting</p> <p>WAC 173-401-615(3)(b) for monthly reporting of deviations</p>

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.15	HCl	2.2 E-02 lb per MMBtu of heat input  (Boiler MACT Emission Limit)	<p><i>Performance Testing:</i></p> <p>Reference Test Method is EPA RM 26 or 26A.</p> <p>Performance tests are to be conducted in accordance with the requirements in 40 CFR 63.7520.</p> <p>Conduct tests annually, no more than 13 months after the previous performance test. If performance tests for at least 2 consecutive years show that emissions are at or below 75 percent of the emission limit and there are no changes in the operation of the boiler, performance tests may be performed every third year.</p> <p>Operating limit for fuel input (Condition G1.17) must be confirmed or reestablished during performance tests.</p> <p>Develop site-specific test and fuel monitoring plans in accordance with 40 CFR 63.7520(a) and 40 CFR 63.7521(b). Upon Ecology request, the Permittee shall submit the test and monitoring plan for approval.</p> <p><i>60-day Notification:</i></p> <p>Notification of Intent to conduct a performance test must be provided to the Administrator 60 days before the performance test is scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must keep records of all performance tests.</p> <p><i>Reporting:</i></p> <p>Semi-annual compliance reporting in accordance with 40 CFR 63.7550.</p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p>	<p>40 CFR 63.7500(a)(1) and Table 2 (Item 1a) for emission limit</p> <p>40 CFR 63.7515(a) and (b) for testing frequency</p> <p>40 CFR 63.7545(d) for performance test notification</p> <p>40 CFR 63.7520 and Table 5 (Item 3) for performance testing requirements</p> <p>40 CFR 63.7520(a) for site-specific test plan requirement</p> <p>40 CFR 63.7521(b) for site-specific fuel monitoring plan</p> <p>40 CFR 63.7555 for recordkeeping</p> <p>40 CFR 63.7515(f) and 63.7550 for reporting</p>



PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
G1.16a	Mercury	5.7 E-06 lb per MMBtu of heat input	<p><i>Performance Testing:</i></p> <p>Reference Test Method is EPA RM 29, 30A, 30B, or alternate method listed in 40 CFR Part 63 Subpart DDDDD Table 5, Item 4e.</p> <p>Performance tests are to be conducted in accordance with the requirements in 40 CFR 63.7520.</p> <p>Conduct tests annually, no more than 13 months after the previous performance test. If performance tests for at least 2 consecutive years show that emissions are at or below 75 percent of the emission limit and there are no changes in the operation of the boiler, performance tests may be performed every third year.</p> <p>Operating limit (Condition G.17) must be confirmed or reestablished during performance tests.</p> <p>Develop site-specific test and fuel monitoring plans in accordance with 40 CFR 63.7520(a) and 40 CFR 63.7521(b).</p> <p><i>60-day Notification:</i></p> <p>Notification of Intent to conduct a performance test must be provided to the Administrator 60 days before the performance test is scheduled to begin.</p> <p><i>Recordkeeping:</i></p> <p>The Permittee must keep records of all performance tests.</p> <p><i>Reporting:</i></p> <p>Semi-annual compliance reporting in accordance with 40 CFR 63.7550.</p> <p>Submit source test results in the monthly air report. See Facility-wide General Requirement, Condition 38 for source test report requirements.</p>	<p>40 CFR 63.7500(a)(1) and Table 2 (Item 1b) for emission limit</p> <p>40 CFR 63.7515(a) and (b) for testing frequency</p> <p>40 CFR 63.7545(d) for performance test notification</p> <p>40 CFR 63.7520 and Table 5 (Item 4) for performance testing requirements</p> <p>40 CFR 63.7540(a)(1) and Table 7 (1a, 1b, and footnote a) for operating limit confirmation/reestablishment</p> <p>40 CFR 63.7520(a) for site-specific test plan requirement</p> <p>40 CFR 63.7521(b) for site-specific fuel monitoring plan</p> <p>40 CFR 63.7555 for recordkeeping</p>

PB20	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
				40 CFR 63.7515(f) and 63.7550 for reporting
G1.16b	Mercury	3.2 kg (7.1 lb) per 24-hour period	<p>Stack sampling must be conducted as specified in 40 CFR 61.53(d), as applicable.</p> <p>Sludge sampling must be conducted as specified in 40 CFR 61.54, as applicable.</p> <p>Monitoring of emissions and operations must be conducted as specified in 40 CFR 61.55(a) as applicable.</p> <p>Records must be maintained as specified in 40 CFR 61.53(d)(6) and 40 CFR 61.54(g), as applicable.</p>	<p>40 CFR 61.52(b) for emission standard</p> <p>40 CFR 61.53(d) for performance test requirements</p> <p>40 CFR 61.54 for alternative sludge sampling</p> <p>40 CFR 61.55(a) for additional performance testing</p>
G1.17	Mercury and HCl	Equal to or lower fuel input of chlorine and mercury than the maximum values calculated during the most recent performance test	<p>Keep records of monthly fuel use, including type(s) of fuel and amount(s) used.</p> <p>Maintain a copy of all calculations and supporting documentation for maximum chlorine and mercury fuel input.</p> <p>Any plans to burn a new fuel or new mixture of fuels requires that the maximum HCl and mercury input be recalculated.</p> <p>Compliance reporting in accordance with 40 CFR 63.7550.</p>	<p>40 CFR 63.7540(a)(2)(ii) for continuous compliance demonstration</p> <p>40 CFR 63.7555(d) for recordkeeping</p> <p>40 CFR 63.7540(a)(4) and (6) for new fuel recalculation</p> <p>40 CFR 63.7550 for reporting</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.18	Any pollutant for which compliance is demonstrated by a Boiler MACT performance test (Operating Limit)	Maintain 30-day rolling average operating load $\leq$ 110 percent of the highest hourly average operating load recorded during the most recent performance test	<p>Collect operating load data or steam generation data every 15 minutes. Reduce the data to 30-day rolling averages.</p> <p>See Facility-wide General Requirement, Condition 28 for CMS data recovery requirements.</p> <p>Report deviations monthly.</p> <p>Compliance reporting in accordance with 40 CFR 63.7550.</p>	<p>40 CFR 63.7500(a)(2) and Table 4 (Item 7) for operating limit</p> <p>40 CFR 63.7520 and Table 7 (Item 5) for establishing operating limit; Table 7 (footnote a) for operating limit confirmation/reestablishment</p> <p>40 CFR 63.7540 and Table 8 (Item 10) for boiler operating load data collection requirements</p> <p>40 CFR 63.7550 for reporting</p> <p>WAC 173-401-615(3)(b) for monthly reporting of deviations</p>
G1.19	Work Practice Standard	Once every five year Tune-up	<p>For a boiler or process heater with a continuous oxygen trim system that maintains an optimum air to fuel ratio, the boiler/process heater tune-up must be performed as specified in 40 CFR 63.7540(a)(12) and Table 3.</p> <p>If the boiler/process heater removes the continuous oxygen trim system, the boiler/process heater tune-up must be performed annually as specified in 40 CFR 63.7540(a)(10) and Table 3.</p> <p>Report in accordance with 40 CFR 63.7550(c)(1).</p>	<p>40 CFR 63.7540(a)(10) and Table 3 (Item 3) for once every five year tune-ups</p> <p>40 CFR 63.7550(c)(1) for reporting</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.20	Startup (Work Practice Standard)	The Permittee must comply with all applicable emission limits at all times except for startup periods conforming with this work practice standard	<p>All CMS must be operated during startup.</p> <p>The Permittee must use one or a combination of clean fuel(s) as listed in Table 3 (Item 5.b) during startup.</p> <p>Once firing non-clean fuels during startup, emissions must be vented to the main stack(s) and all emission control devices must be engaged.</p> <p>Monitoring data must be collected during startup, as specified in 40 CFR 63.7535(b).</p> <p>Reporting in accordance with 40 CFR 63.7550.</p>	<p>40 CFR 63.7500(f) and Table 3 (Item 5)</p> <p>40 CFR 63.7535(b) for monitoring requirements</p> <p>40 CFR 63.7550 for reporting</p> <p>40 CFR 63.7575 for definition of startup</p>
G1.21	Shutdown (Work Practice Standard)	The Permittee must comply with all applicable emission limits at all times except for shutdown periods conforming with this work practice standard.	<p>All CMS must be operated during shutdown.</p> <p>While firing non-clean fuels during shutdown, emissions must be vented to the main stack(s) and all emission control devices must be engaged.</p> <p>Monitoring data must be collected during shutdown, as specified in 40 CFR 63.7535(b).</p> <p>Reporting in accordance with 40 CFR 63.7550.</p>	<p>40 CFR 63.7500(f) and Table 3 (Item 6)</p> <p>40 CFR 63.7535(b) for monitoring requirements</p> <p>40 CFR 63.7550 for reporting</p> <p>40 CFR 63.7575 for definition of shutdown</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.22	Startup/Shutdown Recordkeeping	N/A	<p>The Permittee must maintain startup/shutdown records regarding the following:</p> <ol style="list-style-type: none"> <li>1) The calendar date, time, occurrence and duration of each startup and shutdown;</li> <li>2) The type(s) and amount(s) of fuels used during each startup and shutdown.</li> </ol>	40 CFR 63.7555(d)(9) and (10)

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.23	Good Operations and Maintenance	N/A	<p>At all times, the Permittee must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.</p> <p><i>General Recordkeeping:</i></p> <p>The Permittee must maintain records of:</p> <ol style="list-style-type: none"> <li>1) The occurrence and duration of each malfunction of the boiler or process heater, or of the associated air pollution control and monitoring equipment; and</li> <li>2) Actions taken during periods of malfunction to minimize emissions in accordance with the general duty to minimize emissions in §63.7500(a)(3), including corrective actions to restore the malfunctioning boiler or process heater, air pollution control, or monitoring equipment to its normal or usual manner of operation.</li> </ol>	<p>40 CFR 63.7500(a)(3)</p> <p>40 CFR 63.7555(d)(6) and (7) for recordkeeping</p>

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.24	Monitoring Data Collection	N/A	<p>The Permittee shall operate the monitoring system and collect data at all required intervals at all times that the boiler is operating and compliance is required, except for periods of monitoring system malfunctions or out of control periods (see 40 CFR 63.8(c)(7)), and required monitoring system quality assurance or control activities, including, as applicable, calibration checks, required zero and span adjustments, and scheduled CMS maintenance as defined in your site-specific monitoring plan. A monitoring system malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring system to provide valid data. Monitoring system failures that are caused in part by poor maintenance or careless operation are not malfunctions. You are required to complete monitoring system repairs in response to monitoring system malfunctions or out-of-control periods and to return the monitoring system to operation as expeditiously as practicable.</p>	40 CFR 63.7535

<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.25	Fuels	N/A	<p>Allowable fuels for PB20 include:</p> <ul style="list-style-type: none"> <li>- Wood fuels including hog fuel, forest biomass, urban wood, and burnable rejects from the mill and OCC recycle facility (burnable rejects must be processed to remove plastics and metal before use as fuel),</li> <li>- Oil, including reprocessed fuel oil (RFO),</li> <li>- Primary and secondary sludge from the mill process wastewater treatment plant, and</li> <li>- Natural gas.</li> </ul> <p>The following shall not be burned in PB20:</p> <ul style="list-style-type: none"> <li>- Medical wastes (Note: Order No. 99AQ-I052 which allowed a small amount of medical waste to be burned in PB20 is hereby rescinded),</li> <li>- Mill garbage, and</li> <li>- OCC rejects which have not been processed to remove plastics and metal before use as fuel.</li> </ul>	Order 8429, Modification 1, Condition 5
G1.26	Urban Wood Acceptance Program	N/A	<p>All urban wood purchased for use in PB20 must meet an acceptance program included as part of the PB20 O&amp;M manual (AOP Condition G1.27). The acceptance program must include acceptance criteria which at a minimum prohibits wood treated with creosote, pentachlorophenol, or copper-chrome-arsenic; municipal waste, hazardous material contaminants (asbestos, lead, mercury), lead painted items, and plastic coatings. The acceptance program must be incorporated into the O&amp;M manual. Any changes to the acceptance program must be submitted to Ecology prior to instituting the changes.</p>	Order 8429, Modification 1, Condition 5



<b>PB20</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
G1.27	O&M Manual	N/A	Operating and maintenance (O&M) manuals for all equipment added or modified by Order 8429, that has the potential to affect emissions to the atmosphere, shall be developed and followed. Copies of the manuals shall be available to Ecology. Emissions that result from a failure to follow the requirements of the manuals may be considered proof that the equipment was not properly operated and maintained.	Order 8429, Modification 1, Condition 17

## H1. PAPER MACHINES

PM	Parameter	Limit (shall not exceed)	Monitoring, Reporting	Applicable Requirements
H1.1	VOCs	N/A	Additives used in the paper-making process on the paper machines shall be “low-VOC”. The Permittee shall annually submit a list of additives used in the paper-making process on the paper machines and identify those that are not “low-VOC”.	PSD 01-03, Amendment 3, Condition 4 Order No. 9213, Condition 3
H1.2	Daily Production	220 ADTP/hr, daily average	Sum average hourly production (ADTP/hr) at Paper Machine Nos. 5, 7, 10, 11, and 12 daily. Report maximum daily sum for the month and all limit exceedances in monthly report.	Order No. 9213, Condition 2

## II. BOX PLANT PRODUCTION LINES

The emission units shall comply with the General Requirements of 40 CFR Part 63 as listed in Table 1 of Subpart KK.

Box Plant	Parameter	Limit (shall not exceed)	Monitoring & Reporting	Applicable Requirements
II.1	HAPs	Mass of total HAPs applied must be less than 0.04 times the mass of inks, coatings, varnishes, adhesives, primers, solvents, reducers, thinners, and other materials applied, monthly average	<p>Report mass of material applied, 0.04 times mass of material applied, and mass of HAP applied monthly.</p> <p>Report malfunctions and exceedance semi-annually in accordance with 40 CFR 63.830.</p> <p>Recordkeeping in accordance with 40 CFR 63.829.</p>	<p>40 CFR 63.825(b) and (b)(4) for limit</p> <p>40 CFR 63.830 for reporting</p> <p>40 CFR 63.829 for recordkeeping</p>
II.2	Acrylic Acid (FFG)	0.131 lbs/day	<p>Record the square footage in mean square foot (MSF) produced by the Flexo Folder Gluer (FFG) on a daily basis and the average ink usage factor<sup>a</sup> and weighted average content of acrylic acid in the applied ink products on a monthly basis.</p> <p>Estimate the average daily and maximum daily application of acrylic acid applied at the new FFG<sup>b</sup> and report them in the monthly report.</p> <p>Report any exceedances in the monthly report.</p>	Order No. 13302, Condition 1.b.1
II.3	Propylene Glycol (FFG)	3.75 lbs/day	<p>Record the square footage in MSF produced by the FFG on a daily basis and the average ink usage factor<sup>a</sup> and weighted average content of propylene glycol in the applied ink products on a monthly basis.</p> <p>Estimate the average daily and maximum daily application of propylene glycol applied at the new FFG<sup>b</sup> and report them in the monthly report.</p> <p>Report any exceedances in the monthly report.</p>	Order No. 13302, Condition 1.b.2

Box Plant	Parameter	Limit (shall not exceed)	Monitoring & Reporting	Applicable Requirements
I1.4	VOCs (FFG)	2.0 tpy	<p>Record the square footage in MSF produced by the FFG on a daily basis and the average ink usage factor and weighted average content of VOCs in the applied ink products on a monthly basis. Ink usage factor is the pounds of ink applied per MSF produced at the Box Plant.</p> <p>Estimate the monthly VOC emissions and the annual VOC emissions, based on a 12-month rolling average, from the FFG and report them in the monthly report.</p> <p>Estimate application of the pollutant using the following equation:  (Ink usage factor) x (MSF produced by the FFG) x (weighted average content of applicable pollutant in the applied inks).</p>	Order No. 13302, Condition 1.b.3
I1.5	Recordkeeping (FFG)	N/A	<p>In addition to the monitoring and reporting requirements in Conditions I1.2 through I1.4, the facility must maintain the following records for the Flexo Folder Gluer for a minimum of 5 years:</p> <ol style="list-style-type: none"> <li>a. Documentation about the inks that are used each month, including, but not limited to, MSDS or SDS for each of the inks,</li> <li>b. The VOC content in each ink and weighted percentage of any VOC that is a HAP or a TAP, and</li> <li>c. An estimate of the average amount of ink used on a daily basis.</li> </ol>	Order No. 13302, Condition 2
I1.6	Additional Reporting (FFG)	N/A	<p>The Permittee must submit a TAP emissions report for the Flexo Folder Gluer to Ecology annually. The report must be submitted by January 31<sup>st</sup> for the previous calendar year. The report must include the following information:</p> <ol style="list-style-type: none"> <li>a. A list of any new inks that were used during the calendar year.</li> <li>b. A list of any new TAPs associated with the new inks.</li> <li>c. The calculated annual emission rate for any TAPs that were emitted by the Flexo Folder Gluer unit.</li> </ol>	Order No. 13302, Condition 3

Box Plant	Parameter	Limit (shall not exceed)	Monitoring & Reporting	Applicable Requirements
11.7	New Source Review (FFG)	N/A	In accordance with WAC 173-400-110, a modification to the Flexo Folder Gluer, including a change in the method of operation such as the use of new inks, is subject to new source review requirements. Prior to the use of any new inks that will cause the Flexo Folder Gluer to emit either a new TAP or an existing TAP above the new source review exemptions levels, the facility must submit a request to revise this Order, as allowed by WAC 173-400-111(8), to address those increases. The request must include sufficient information for Ecology to assess the items specified by WAC 173-400-111(8)(a).	Order No. 13302, Condition 4
11.8	Operations and Maintenance	N/A	The operation and maintenance manual for the Box Plant Production Lines must be updated to reflect the addition of the Flexo Folder Gluer. The operation and maintenance manual must be followed. A copy of the manual must be available to Ecology.	Order No. 13302, Condition 5

**J1. RECIPROCATING INTERNAL COMBUSTION ENGINES (RICE) - EMERGENCY**

The facility has four emergency compression ignition (CI) RICE: MWC Fire Pump, OCC Fire Pump, Turbine Room Backup Generator, and IT Server Backup Generator. 40 CFR Part 63, Subpart ZZZZ regulates these stationary reciprocating internal combustion engines.

40 CFR Part 63 requirements are cited in this permit, as applicable. WAC 173-400-075(6) incorporates 40 CFR Part 63 by reference.

<b>RICE</b>	<b>Monitoring, Reporting, Recordkeeping</b>	<b>Applicable Requirements</b>
J1.1	<p>Change the oil and filter every 500 hours of operation or annually, whichever comes first. An oil analysis program may be used to extend the specified oil change requirement in accordance with 40 CFR 63.6625(i) or (j), as applicable.</p> <p>Inspect the air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary.</p> <p>Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.</p>	40 CFR Part 63, Subpart ZZZZ, Table 2c
J1.2	<p>Minimize the engine's time spent at idle, and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.</p>	40 CFR 63.6625(h)
J1.3	<p>There is no time limit on the use of emergency stationary RICE in emergency situations.</p> <p>Emergency RICE may operate for up to 100 hours per year for maintenance checks and readiness testing or other periods defined in 40 CFR 63.6640(f).</p> <p>Emergency RICE may operate for up to 50 hours per year in non-emergency situations not mentioned above. This time will count toward the 100 hours per year previously mentioned.</p>	40 CFR 63.6640(f)

RICE	Monitoring, Reporting, Recordkeeping	Applicable Requirements
J1.4	<p>Records of the hours of operation of the engine that is recorded through the nonresettable hour meter must be maintained. Records must include how many hours are spent for emergency operation, including what classified the operation as an emergency, and how many hours are spent for nonemergency operation. If the engines are used for demand response operation, maintain records of the notification of the emergency situation and the time the engine was operated as part of demand response. Records must be kept and readily available for five (5) years following the date of each occurrence, measurement, maintenance, corrective action report, or record.</p>	<p>40 CFR 63.6655 for recordkeeping. 40 CFR 63.6660 for records retention.</p>
J1.5	<p>The stationary RICE must be operated and maintained according to the manufacturer's emission-related operation and maintenance instructions; or</p> <p>A maintenance plan must be developed and followed which provides to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.</p> <p>Records must be retained of the operation and maintenance of the engines according to the manufacturer's emission-related instructions or according to the developed maintenance plan consistent with good air pollution control practice for minimizing emissions. Records must be kept and readily available for five (5) years following the date of each occurrence, measurement, maintenance, corrective action report, or record.</p>	<p>40 CFR Part 63 Subpart ZZZZ, Table 6 40 CFR 63.6655 for recordkeeping. 40 CFR 63.6660 for records retention.</p>
J1.6	<p>Beginning January 1, 2015, existing emergency compression ignition (CI) stationary RICE with a site rating of more than 100 brake hp and a displacement of less than 30 liters per cylinder that uses diesel fuel, and operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in §63.6640(f)(2)(ii) and (iii), or that operates for the purpose specified in §63.6640(f)(4)(ii), must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.</p>	<p>40 CFR 63.6604(b)</p>

## J2. RECIPROCATING INTERNAL COMBUSTION ENGINES (RICE) – NEW SOURCE PERFORMANCE STANDARDS

The facility has three emergency compression ignition (CI) RICE for which new source performance standards in 40 CFR Part 60, Subpart IIII apply: MWC Fire Pump, OCC Fire Pump, and IT Server Backup Generator.

40 CFR Part 60 requirements are cited in this permit, as applicable. WAC 173-400-115 incorporates 40 CFR Part 60 by reference.

RICE	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
J2.1	NMHC + NOx	4.0 g/kW-hr	Compliance must be demonstrated by keeping records of engine manufacturer data indicating compliance with the standards.	40 CFR 60.4205(b) and 40 CFR 89.112 for IT Server Backup Generator  40 CFR 60.4205(c) for fire pumps
J2.2	CO	3.5 g/kW-hr	Compliance must be demonstrated by keeping records of engine manufacturer data indicating compliance with the standards.  Limit not applicable to OCC Fire Pump and MWC Fire Pump	40 CFR 60.4205(b) and 40 CFR 89.112 for IT Server Backup Generator
J2.3	PM	0.2 g/kW-hr	Compliance must be demonstrated by keeping records of engine manufacturer data indicating compliance with the standards.	40 CFR 60.4205(b) and 40 CFR 89.112 for IT Server Backup Generator  40 CFR 60.4205(c) for fire pumps
J2.4	Operations	N/A	In order for the engines to be considered an emergency stationary ICE under this 40 CFR Part 60, Subpart IIII, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (1) through (3) of this condition, is prohibited. If you do not operate the engine	40 CFR 60.4211(f)



RICE	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>according to the requirements in paragraphs (1) through (3) of this condition, the engine will not be considered an emergency engine and must meet all requirements for non-emergency engines.</p> <p>(1) There is no time limit on the use of emergency stationary ICE in emergency situations.</p> <p>(2) You may operate your emergency stationary ICE for any combination of the purposes specified in paragraphs (i) through (iii) of this condition for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraph (3) of this condition counts as part of the 100 hours per calendar year allowed by this paragraph (2).</p> <p>(i) Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.</p> <p>(ii) Emergency stationary ICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies (incorporated by reference, see §60.17), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.</p>	

RICE	Parameter	Limit (shall not exceed)	Monitoring, Reporting, Recordkeeping	Applicable Requirements
			<p>(iii) Emergency stationary ICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.</p> <p>(3) Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraph (f)(3)(i) of this section, the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.</p>	
J2.5	Operations and Maintenance	N/A	The Permittee must: operate and maintain the stationary CI internal combustion engines and control devices according to the manufacturer's emission-related written instructions; change only those emission-related settings that are permitted by the manufacturer; and meet the requirements of 40 CFR parts 89, 94 and/or 1068, as applicable.	40 CFR 60.4211(a)
J2.6	Fuel Requirements	N/A	The Permittee must use diesel fuel that has a maximum sulfur content of 15 ppm and a minimum cetane index of 40 or a maximum aromatic content of 35 percent by volume.	40 CFR 60.4207(b) for fuel requirements

### J3. RECIPROCATING INTERNAL COMBUSTION ENGINES (RICE) – NON-EMERGENCY

NESHAP Subpart ZZZZ regulates stationary reciprocating internal combustion engines. The facility has three non-emergency spark ignition (SI) RICE: 3 Kiln Auxiliary Drive System Engine, 4 Kiln Auxiliary Drive System Engine, and 5 Kiln Auxiliary Drive System Engine.

40 CFR Part 63 requirements are cited in this permit, as applicable. WAC 173-400-075(6) incorporates 40 CFR Part 63 (MACT) by reference.

RICE	Monitoring, Reporting, Recordkeeping	Applicable Requirements
J3.1	<p>Change the oil and filter every 1,440 hours of operation or annually, whichever comes first. An oil analysis program may be used to extend the specified oil change requirement in accordance with 40 CFR 63.6625(i) or (j), as applicable.</p> <p>Inspect spark plugs every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.</p> <p>Inspect all hoses and belts every 1,440 hours of operation or annually, whichever comes first, and replace as necessary.</p>	40 CFR Part 63, Subpart ZZZZ, Table 2c
J3.2	<p>Minimize the engine's time spent at idle, and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the non-startup emission limitations apply.</p>	40 CFR 63.6625(h)
J3.3	<p>The stationary RICE must be operated and maintained according to the manufacturer's emission-related operation and maintenance instructions; or</p> <p>A maintenance plan must be developed and followed which provides to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.</p> <p>Records must be retained of the operation and maintenance of the engines according to the manufacturer's emission-related instructions or according to the developed maintenance plan consistent with good air pollution control practice for minimizing emissions. Records must be kept and readily available for five (5) years following the date of each occurrence, measurement, maintenance, corrective action report, or record.</p>	<p>40 CFR Part 63 Subpart ZZZZ, Table 6</p> <p>40 CFR 63.6655 for recordkeeping.</p> <p>40 CFR 63.6660 for records retention.</p>

### K1. MILLWIDE EMISSION LIMITS

<b>Mill Wide</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring &amp; Reporting</b>	<b>Applicable Requirements</b>
K1.1	PM and PM <sub>10</sub>	698.5 tpy, 12-month rolling total	Report 12-month rolling total in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.98
K1.2	SO <sub>2</sub>	1,885 tpy, 12 month rolling total	Report 12-month rolling total in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.99
K1.3	CO	7,056.5 tpy, 12 month rolling total	Report 12-month rolling total in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.100
K1.4	NO <sub>x</sub>	3,028.5 tpy, 12 month rolling total	Report 12-month rolling total in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.101
K1.5	TRS (as H <sub>2</sub> S)	263 tpy, 12 month rolling total	Report 12-month rolling total in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.102
K1.6	VOCs	1,674 tpy, 12 month rolling total	Report 12-month rolling total in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.103
K1.7	Kraft Pulp Production	2,800 machine dried tons (MDT)/day, 12 month rolling average	Report 12-month rolling average in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.96
K1.8	Total Primary Production	3,600 MDT/day, 12 month rolling average	Report 12-month rolling average in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.97

<b>Mill Wide</b>	<b>Parameter</b>	<b>Limit</b> (shall not exceed)	<b>Monitoring &amp; Reporting</b>	<b>Applicable Requirements</b>
K1.9	Steam Production @ main header	2.6 million lb/hr @ 800 psig, 1-hr average	Report maximum hourly steam production for each day in monthly report (see Appendix ApA.5).	PSD 01-03, Amendment 3, Condition 1.104
K1.10	N/A	N/A	The following units shall no longer be operated: #5 Washer Line, Lime Slaker No.3, and Lime Kiln 2.	Order 8429, Condition 8

## **L1. GREENHOUSE GAS (GHG) REPORTING**

The following **state-only** GHG requirements are not enforceable under the federal Clean Air Act.

### **L1.1 GHG Reporting Schedule**

Permittee must submit the report required under Chapter 173-441 WAC to Ecology no later than March 31 of each calendar year for GHG emissions in the previous calendar year.

Reporting requirements begin for Calendar Year 2012 and each subsequent calendar year.

The report and certificate or representation must be submitted electronically in accordance with the requirements of WAC 173-441-050 and 173-441-060 and in a format specified by Ecology.

Submit a revised annual GHG report within 45 days of discovering that an annual GHG report previously submitted contains one or more substantive errors.

[WAC 173-441-050(2), WAC 173-441-070, WAC 173-441-050(7)]

### **L1.2 Report Content**

Each annual GHG report shall contain the content specified in WAC 173-441-050(3).

Each GHG emission report and any other submission under Chapter 173-441 WAC shall be certified, signed, and submitted by the designated representative or any alternate designated representative.

- (a) Each such submission shall include the following certification statement signed by the designated representative or any alternate designated representative: *"I am authorized to make this submission on behalf of the owners and operators of the facility or supplier, as applicable, for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."*

All requests, notifications, and communications to Ecology pursuant to Chapter 173-441 WAC, other than submittal of the annual GHG report, shall be submitted to the following address:

Greenhouse Gas Report  
Air Quality Program  
Department of Ecology  
PO Box 47600  
Olympia, WA 98504-7600

[WAC 173-441-050(3), WAC 173-441-060(5)]

### L1.3 Emissions Calculations

Use the calculation methodologies specified in the relevant sections of Chapter 173-441 WAC. Use the same calculation methodology throughout a reporting period unless you provide a written explanation of why a change in methodology was required.

Calibration and accuracy requirements: Permittee must meet the applicable flow meter calibration and accuracy requirements of WAC 173-441-050(8). The accuracy specifications in this subsection do not apply where either the use of company records (as defined in WAC 173-441-020(3)) or the use of "best available information" is specified in an applicable subsection of Chapter 173-441 WAC to quantify fuel usage and/or other parameters. Further, the provisions of this subsection do not apply to stationary fuel combustion units that use the methodologies in 40 C.F.R. Part 75 to calculate CO<sub>2</sub> mass emissions.

[WAC 173-441-050(4), WAC 173-441-050(8)]

### L1.4 Recordkeeping

Keep records as specified in WAC 173-441-050(6). Retain all required records for at least three years. The records shall be kept in an electronic or hard copy format (as appropriate), and recorded in a form that is suitable for expeditious inspection and review. Upon request by Ecology, the records required under this section must be made available to Ecology. Records may be retained offsite if the records are readily available for expeditious inspection and review. For records that are electronically generated or maintained, the equipment or software necessary to read the records shall be made available, or, if requested by Ecology, electronic records shall be converted to paper documents.

[WAC 173-441-050(6)]

## **M1. COMPLIANCE ASSURANCE MONITORING (CAM)**

The Permittee is required to submit a CAM Plan per 40 CFR Part 64. WestRock Longview's CAM Plan submitted with the 2011 AOP renewal permit application (updated in October 2019) and included in this permit's statement of basis shall satisfy the CAM Plan submittal requirement. CAM is applicable to the following pollutant-specific emission units (PSEUs): Recovery Furnace 19 (PM), Recovery Furnace 22 (PM), Smelt Dissolver Tank 19 (PM), Smelt Dissolver Tank 22 (PM), Lime Kiln 3 (PM), Lime Kiln 4 (PM), Lime Kiln 5 (PM), and Power Boiler 20 (PM). The following general CAM requirements apply to the aforementioned units and the associated limits that are subject to CAM, as identified in the permit conditions above.

### **General CAM requirements:**

#### M1.1 Obligation to monitor and data availability requirement.

Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of this part, including data averages and calculations, or fulfilling a minimum data availability requirement, if applicable.

The owner or operator shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. [40 CFR 64.7(c)]

#### M1.2 Excursions.

The Permittee shall report excursions as defined in the unit specific monitoring requirements. An excursion does not necessarily indicate an exceedance of the applicable particulate emission standards referenced above, nor does evidence of an excursion preclude the Permittee from certifying continuous compliance as provided in Facility Wide Condition 39 of this permit if the Permittee has other data on which to base a determination of compliance during the reporting period in which the excursion occurred. (40 CFR 64.6(c)(2)(10/22/97); 40 CFR 70.6(c)(iii)(C) (6/27/03)

#### M1.3 Response to an excursion.

Upon detecting an excursion or exceedance, the owner or operator shall restore operation of the pollutant-specific emissions unit (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as through response by a computerized distribution control system), or any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable. [40 CFR 64.7(d)]

#### M1.4 Quality Improvement Plan (QIP).

If Ecology or U.S. EPA Region 10 determines, based on the frequency of excursions reported, review of operation and maintenance procedures and records, and reports on corrective action taken in response to an excursion, that the Permittee's corrective action procedures are not consistent with good air pollution control practice for minimizing emissions, Ecology or U.S. EPA Region 10 may require the Permittee to develop and implement a Quality Improvement Plan. (40 CFR 64.8 and 64.6(c)(3) (10/22/97))

#### M1.5 Reporting.

A monitoring report required by this section shall be submitted at a minimum semiannually and shall include:

- (a) Summary information on the number, duration and cause (including unknown cause, if applicable) of each excursion and the corrective action taken;
- (b) Summary information on the number, duration and cause (including unknown cause, if applicable) for monitor downtime incidents (other than downtime associated with zero and span or other daily calibration checks, if applicable); and;



(c) A description of the actions taken to implement a QIP during the reporting period, if required. Upon completion of a QIP, the Permittee shall include in the next monthly report documentation that the implementation of the plan has been completed and reduced the likelihood of similar levels of excursions occurring. [40 CFR 64.9(a)]

#### M1.6 Recordkeeping.

The recordkeeping required by this section shall include records of the monitoring data described in this section, corrective actions taken pursuant to this section, any QIP prepared under Condition M1.4, and any activities taken to implement a QIP. Instead of paper records, the Permittee may maintain records on alternative media, such as microfilm, computer files, magnetic tape disks, or microfiche, provided that the use of such alternative media allows for expeditious inspection and review. (40 CFR 64.9(b) and 64.6(c)(3) (10/22/97))

## FACILITY-WIDE GENERAL REQUIREMENTS [WAC 173-401-600]

These generally applicable requirements apply facility-wide, including insignificant emission units or activities. Insignificant emission units or activities, however, are not subject to monitoring, testing, recordkeeping, reporting, or compliance certification requirements.

1. Varying Emission Rate. The Permittee cannot vary the rate of emission of a pollutant according to atmospheric conditions or ambient concentrations of that pollutant, except as directed according to air pollution episode regulations. [WAC 173-400-205]
2. Emissions Detrimental to Persons or Property. The Permittee shall not cause or permit emission of any contaminant if it is detrimental to the health, safety, or welfare of any person, or causes damage to property or business. [WAC 173-400-040(6)]
3. Concealment and Masking. The Permittee shall not install or use any means that conceal or mask an emission of an air contaminant that would otherwise violate provisions in this permit. [WAC 173-400-040(8)]
4. Fugitive Emissions. The Permittee shall take reasonable precautions to prevent the release of air contaminants from emission units engaged in material handling, construction, demolition, or any other operation that is a source of fugitive emissions. Reasonable precautions include, but are not limited to, application of water as necessary to control fugitive dust or the timely removal or coverage of material piles. [WAC 173-400-040(4)(a)]
5. Fugitive Dust. The Permittee shall take reasonable precautions to prevent fugitive dust from becoming airborne and maintain and operate the source to minimize emissions. Reasonable precautions include but are not limited to application of water to paved areas and debris piles as necessary to control fugitive dust or the timely removal or coverage of material piles. [WAC 173-400-040(9)(a)]
6. Fallout. The following condition is **state only** and is not federally enforceable under the Clean Air Act: No deposit of particulate matter beyond property line so as to interfere unreasonably with use and enjoyment of the property upon which the material is deposited. [WAC 173-400-040(3)]
7. Odors. The following condition is **state only** and is not federally enforceable under the Clean Air Act: Any person causing odor which may unreasonably interfere with use and enjoyment of property must use recognized good practice and procedures to reduce odors to a reasonable minimum. [WAC 173-400-040(5)]
8. Opacity. The Permittee may not cause or allow the emission of a plume, from any emissions unit other than a kraft recovery furnace, smelt dissolver tank, or lime kiln, which has an average opacity greater than twenty percent for more than six consecutive minutes in any sixty minute period. The emissions unit shall comply with the alternative visible emission standard for:

- (i) Soot blowing or grate cleaning in WAC [173-400-040](#) (2)(a);
- (ii) Hog fuel or wood fired boiler in operation before January 24, 2018, in WAC [173-400-040](#) (2)(e); and/or
- (iii) Furnace refractory in WAC [173-400-040](#) (2)(f).
- (iv) There shall be no more than one violation notice issued in any sixty minute period.
- (v) These provisions (of WAC 173-405-040(6)) shall not apply when the presence of uncombined water is the only reason for the opacity of the plume to exceed the applicable maximum.

[WAC 173-405-040(6)]

9. Complaints. Except where specific requirements are defined elsewhere, the Permittee shall assure compliance with Conditions 1 through 8 by recordkeeping of actions taken by the Permittee in response to complaints received by the Permittee or of possible noncompliance noticed by the facility staff in day-to-day operations. The Permittee shall assess the validity of each complaint and commence corrective action, if warranted, as soon as possible, but no later than 3 working days of receiving the complaint excluding holidays and weekends. The Permittee shall keep records of the following: complaints received, the assessment of validity, and what, if any, corrective action is taken in response to the complaint. [WAC 173-401-630]
10. Sulfur Dioxide Emissions. The emission of sulfur dioxide from any emissions unit other than a recovery furnace or lime kiln shall not exceed 1,000 parts per million for an hourly average, corrected to 7% oxygen for combustion units. [WAC 173-405-040(9)]
11. Credible Evidence. For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of the applicable requirements cited in this requirement, nothing in this permit shall preclude the use, including the exclusive use, of any credible evidence or information relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed. [40 CFR 51.212; 40 CFR 52.12; 40 CFR 52.33; 40 CFR 60.11; 40 CFR 61.12]
12. Operation and Maintenance. The Permittee shall at all times, including periods of abnormal operation and upset conditions, to the extent practicable, maintain and operate any affected facility, including associated air pollution control equipment, in a manner consistent with good air pollution control practice. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to Ecology that may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source. [40 CFR 60.11(d), 40 CFR 63.6(e)(1), WAC 173-405-040(8)]
13. Chemical Accidental Release Program. The Permittee does not meet the applicability standards for Accidental Release Prevention Provisions under 40 CFR Part 68.

The Permittee has a general duty to: identify hazards which may result from accidental releases using appropriate hazard assessment techniques; to design and maintain a safe facility taking such steps as are necessary to prevent releases; and to minimize the consequences of accidental releases that do occur. [40 CFR Part 68]

14. Ozone Protection.

- a. The Permittee shall comply with the applicable standards for recycling and emissions reductions pursuant to 40 CFR Part 82, Subpart F except as provided for Motor Vehicle Air conditions (MVACs) in Subpart B:
  - i. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to Section 82.156.
  - ii. Equipment used during the maintenance, service, repair, or disposal must comply with standards for recycling and recovery equipment pursuant to Section 82.158.
  - iii. Persons performing maintenance, service, repair, or disposal of appliances must be certified by an approved technician certification program pursuant to Section 82.161.
  - iv. Persons disposing of small appliances, MVACs, and MVAC-like appliances must comply with recordkeeping requirements pursuant to Section 82.166. ("MVAC-like appliance" is defined at Section 82.152.)
  - v. Persons owning commercial or industrial process refrigeration equipment must comply with the leak repair requirements pursuant to Section 82.156.
  - vi. Owners/operators of appliances normally containing 50 or more pounds, or refrigerant purchased and added to such appliances must do so in compliance with Section 82.166.
- b. Permittee may switch from any ozone-depleting substance to any alternative approved pursuant to the Significant New Alternatives Program (SNAP), 40 CFR Part 82, Subpart G, without a permit revision but shall not switch to a substitute listed as unacceptable pursuant to such program. [40 CFR 82.174]
- c. Any certified technician employed by Permittee shall keep a copy of their certification at their place of employment. [40 CFR 82.166(1)]
- d. The Permittee shall not willfully release any regulated refrigerant and shall use refrigerant extraction equipment to recover regulated refrigerant that would otherwise be released into the atmosphere. [RCW 70.94.970(2), 970(4)]
- e. Compliance with this term and condition will be demonstrated by using a certified contractor or employee.

15. Volatile Organic Liquid Storage Vessels. The Permittee shall keep records showing the dimensions and capacities of all storage vessels having capacities greater than or equal to 75 cubic meters that are used to store volatile organic liquids and for which construction, reconstruction, or modification commenced after July 23, 1984. These records are to be kept for the life of each storage vessel.

The requirement above does not apply to storage vessels with a capacity greater than or equal to 151 cubic meters storing a liquid with a maximum true vapor pressure less than 3.5 kilopascals (kPa), or with a capacity greater than or equal to 75 cubic meters but less than 151 cubic meters storing a liquid with a maximum true vapor pressure less than 15.0 kPa.

The Permittee shall maintain a record of volatile organic liquid stored, the period of storage, and the maximum true vapor pressure of the volatile organic liquid during the storage period. [40 CFR 60.116b (a) and (b)]

16. Used Oil Burning. The following condition is **state-only** and is not federally enforceable under the Clean Air Act.

The Permittee cannot burn used oil not meeting standards prescribed in RCW 70.94.610(1). This condition shall not apply to used oil burned in space heaters if the space heater has a maximum heat output of not greater than 0.5 million BTUs per hour or used oil burned in facilities permitted by Ecology. [RCW 70.94.610]

17. Asbestos. The Permittee must comply with 40 CFR sections 61.145 and 61.150 and WAC 173-400-075 if asbestos-containing material is present above specified quantities in a facility being demolished or renovated. [WAC 173-400-075; 40 CFR Part 61, Subpart M]

18. New Source Review. The Permittee shall not construct new sources or make modifications required to be reviewed under WAC 173-400-110, WAC 173-400-560, WAC 173-400-720, WAC 173-400-820, or WAC 173-460-040 before the Permittee obtains written final approval from Ecology in accordance with those regulations, pays the appropriate fees required by WAC 173-455-120, and pays the cost of public notice described in WAC 173-400-171. [WAC 173-400-110; WAC 173-400-171; WAC 173-400-560; WAC 173-400-720; WAC 173-400-820; 173-460-040]

19. Replacement or Substantial Alteration of Emission Control Technology. The following condition is **state-only** and is not federally enforceable under the Clean Air Act.

Prior to replacing or substantially altering emission control technology subject to review under WAC 173-400-114, the Permittee shall file for a notice of construction application with Ecology according to that regulation. The Permittee shall pay the appropriate fees required by WAC 173-455-100(4) prior to commencing construction. [WAC 173-400-114]

20. Nonroad Engines. The following condition is **state-only** and is not federally enforceable under the Clean Air Act.

Prior to installation or operation of a nonroad engine, as defined in WAC 173-400-030(59), the Permittee shall meet the requirements of WAC 173-400-035. If the nonroad engine(s) has a cumulative maximum rated brake horsepower greater than 500, a notification of intent to operate must be submitted to Ecology. If the nonroad engine(s) has a cumulative maximum rated break horsepower greater than 2,000, the Permittee must not operate the engine(s) unless Ecology issues written approval to operate. [WAC 173-400-035]

## MONITORING, RECORDKEEPING & REPORTING

### Monitoring Requirements [WAC 173-401-630(5)(b)]

21. Unit-Specific Requirements. The Permittee shall conduct routine monitoring of emissions in accordance with the program of monitoring or testing required by specific emission unit conditions of this permit. [WAC 173-405-072]
22. Representative Conditions. The Permittee must conduct stack tests during representative operating conditions unless required operating conditions during testing is otherwise specified. [40 CFR 60.8(c), 40 CFR 63.7(e), WAC 173-401-630(1), 40 CFR 70.6(c)(1)]
23. Unavoidable Excess Emissions. This portion of the condition is applicable until WAC 173-400-109 becomes effective. This condition applies, where applicable, to excess emissions that are claimed to be unavoidable pursuant to WAC 173-400-107. The Permittee may include in its reports demonstrations that excess emissions were unavoidable, consistent with the requirements of WAC 173-400-107. The Permittee shall have the burden to prove that deviations from permit terms were unavoidable. Excess emissions that are unavoidable are excused and not subject to penalty. [WAC 173-400-107]

This portion of the condition is applicable upon the effective date of WAC 173-400-109. This condition applies, where applicable, to excess emissions that are claimed to be unavoidable pursuant to WAC 173-400-109. The Permittee may include in its reports demonstrations that excess emissions were unavoidable, consistent with the requirements of WAC 173-400-109. The Permittee shall have the burden to prove that deviations from permit terms were unavoidable. Excess emissions that are unavoidable are not subject to penalty. Claim of unavoidable excess emissions does not apply to exceedance of an emission standard in 40 CFR Parts 60, 61, 62, 63, and 72, or Ecology's adoption by reference of these standards. [WAC 173-400-109]

24. Violation Duration. A violation of an emission limit is presumed to commence at the time of the testing, recordkeeping, or monitoring indicating noncompliance, and to continue until the time of retesting, recordkeeping, or monitoring that indicates compliance. This presumption may be defeated if credible evidence shows that the violation was of longer duration, that there were intervening days during which no violation occurred, or that that violation was not continuing in nature. [42 U.S.C. 7413(e)(2)]. The Permittee may conduct monitoring or testing more frequently than required by this permit.
25. Insignificant Emission Units. The Permittee is not subject to any testing, monitoring, reporting, or recordkeeping requirements for insignificant units or activities listed. [WAC 173-401-530(2)(c)]
26. Continuous Emission Monitoring System Operating Requirements. Continuous emission monitoring systems (CEMS) required under an order, PSD permit, or regulation issued by a permitting authority and not subject to CEMS performance specifications and data recovery requirements imposed by 40 CFR Parts 60, 61, 62, 63, or 75 must meet the following CEMS performance specifications:

- a. The owner or operator shall recover valid hourly monitoring data for at least 95 percent of the hours that the equipment (required to be monitored) is operated during each calendar month except for periods of monitoring system downtime, provided that the owner or operator demonstrated that the downtime was not a result of inadequate design, operation, or maintenance, or any other reasonable preventable condition, and any necessary repairs to the monitoring system are conducted in a timely manner.
- b. The owner or operator shall install a continuous emission monitoring system that meets the performance specification in 40 CFR Part 60, Appendix B in effect at the time of its installation, and shall operate this monitoring system in accordance with the quality assurance procedures in Appendix F of 40 CFR Part 60 in effect on May 1, 2012, and the U.S. Environmental Protection Agency's "Recommended Quality Assurance Procedures for Opacity Continuous Monitoring Systems" (EPA) 340/ 1-86-010.
- c. Monitoring data commencing on the clock hour and containing at least forty-five minutes of monitoring data must be reduced to one hour averages. Monitoring data for opacity is to be reduced to six minute block averages unless otherwise specified in the order of approval or permit. All monitoring data will be included in these averages except for data collected during calibration drift tests and cylinder gas audits, and for data collected subsequent to a failed quality assurance test or audit. After a failed quality assurance test or audit, no valid data is collected until the monitoring system passes a quality assurance test or audit.
- d. Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under subsection (a) of this section, all continuous monitoring systems shall be in continuous operation.
  - i. Continuous monitoring systems for measuring opacity shall complete a minimum of one cycle of sampling and analyzing for each successive ten second period and one cycle of data recording for each successive six minute period.
  - ii. Continuous monitoring systems for measuring emissions other than opacity shall complete a minimum of one cycle of sampling, analyzing, and recording for each successive fifteen minute period.
- e. The owner or operator shall retain all monitoring data averages for at least five years, including copies of all reports submitted to the permitting authority and records of all repairs, adjustments, and maintenance performed on the monitoring system.
- f. The owner or operator shall submit a monthly report (or other frequency as directed by terms of an order, air operating permit or regulation) to the permitting authority within thirty days after the end of the month (or other specified reporting period) in which the data were recorded. The report required by this section may be combined with any excess emission report required by WAC 173-400-107 or -108, whichever is in effect at the time of the excess emissions. This report shall include:

- i. The number of hours that the monitored emission unit operated each month and the number of valid hours of monitoring data that the monitoring system recovered each month;
- ii. The date, time period, and cause of each failure to meet the data recovery requirements of (a) of this subsection and any actions taken to ensure adequate collection of such data;
- iii. The date, time period, and cause of each failure to recover valid hourly monitoring data for at least 90 percent of the hours that the equipment (required to be monitored) was operated each day [Note: A CEM must provide valid data for all but two hours per day (ninety percent standard)];
- iv. The results of all cylinder gas audits conducted during the month; and
- v. A certification of truth, accuracy, and completeness signed by an authorized representative of the owner or operator.

[WAC 173-400-105(7)]

27. NSPS CMS Data Recovery. Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems shall be in continuous operation. All CEMS and COMS shall meet the following minimum frequency of operation requirements:
- a. All COMS shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.
  - b. All CEMS shall complete a minimum of once cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)]

The Permittee shall make every effort to acquire, maintain, and recover valid monitoring data. CMS downtime and resulting monitoring data loss due to malfunctions shall be less than 10% of the monthly unit operating time. Report CMS downtime in excess of 10% as a percentage of unit operating time in the monthly report. An explanation for the loss of monitoring data must be provided in the monthly report. Periods when CMS data is not recovered due to daily calibration, zero and span checks are not considered nor reported as CMS downtime in the monthly report. Records of daily calibration, zero and span checks shall be kept for a period of five years and made available upon request to Ecology. [40 CFR 70.6(c)(1)]



28. MACT CMS Data Recovery. Except for system breakdowns, out-of-control periods, repairs, maintenance periods, calibration checks, and zero (low-level) and high calibration drift adjustments, all CMS, including COMS and CEMS shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

- a. All COMS shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.
- b. All CEMS for measuring emissions other than opacity shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 63.8(c)(4)]

The Permittee shall make every effort to acquire, maintain, and recover valid monitoring data. CMS downtime and resulting monitoring data loss due to malfunctions shall be less than 10% of the monthly unit operating time. Report CMS downtime in excess of 10% as a percentage of unit operating time in the monthly report. An explanation for the loss of monitoring data must be provided in the monthly report. Periods when CMS data is not recovered due to daily calibration, zero and span checks are not considered nor reported as CMS downtime in the monthly report. Records of daily calibration, zero and span checks shall be kept for a period of five years and made available upon request to Ecology. [40 CFR 70.6(c)(1)]

### **Recordkeeping Requirements**

29. Monitoring Records. The Permittee shall keep records of any periodic and continuous monitoring required by this permit. These records shall include the following, where applicable:

- a. The date, place as defined in requirement, and time of sampling or measurement;
  - b. The date(s) analysis was performed;
  - c. The company or entity that performed the analysis;
  - d. The analytical techniques or methods used;
  - e. The results of such analysis;
  - f. Inspector sign name;
  - g. The operating conditions existing at the time of sampling or measurement.
- [WAC 173-401-615(2)(a)]

30. Inspection Checklists. Where the Permittee is required to use and maintain an inspection checklist, the checklist must contain, at a minimum, the following information:

- a. The person conducting the inspection;
- b. The date/time of the inspection
- c. Location of the inspection;
- d. The observations made during the inspection;
- e. Corrective actions taken if any; and

- f. The date and time corrective action was initiated and completed. [WAC 173-401-615(1)(b)]
  
- 31. Changes at Source. The Permittee shall keep records describing changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under the permit, and the emissions resulting from those changes. [WAC 173-401-724(5)]
- 32. Records Retention. The Permittee shall retain records of all required monitoring data and support information for a period of five (5) years from the date of monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. [WAC 173-401-615(2)(c)]
- 33. Recording Permit Deviations. The Permittee shall maintain a contemporaneous record of any deviation from the requirements of this permit. [WAC 173-401-615(3)(b)]

**Reporting Requirements** [WAC 173-401-520, -615(3), & -710]

- 34. Unit Reporting Requirements. In addition to any emission unit specific reporting requirements identified below, emission unit specific reporting requirements are identified in specific unit conditions of this permit.
- 35. Production reporting. Report within 15 days of the end of each month average daily production of air-dried unbleached pulp. [WAC 173-405-072(4)]
- 36. Monthly Reporting. Monthly monitoring reports required by this permit must be submitted to Ecology within 15 days of the end of each calendar month. [WAC 173-405-072]. All reports must clearly identify all instances of deviations from permit requirements. [WAC 173-401-615(3)(a)]
- 37. Notification of Planned Source Test. The Permittee must notify Ecology of all source tests at least 30 days prior to the planned date of the test, unless otherwise specified in applicable regulations or approved by Ecology. Notification must include the unit to be tested, parameter(s) to be tested, date(s) of testing, and test methods to be used during the testing, at a minimum. The Permittee must provide a copy of the source test plan for review upon Ecology request. [WAC 173-400-105(4), WAC 173-401-630(1), 40 CFR 70.6(c)(1)]
- 38. Source Testing Reports. Source test reports must be submitted to Ecology within 60 days of completion of each source test. [WAC 173-405-072]

Source test reports must be submitted to Ecology electronically via EPA's Compliance and Emissions Data Reporting Interface (CEDRI). EPA's Electronic Reporting Tool (ERT) may be used for reporting source testing results in CEDRI. Alternate submittal format may be used upon Ecology approval.

39. Providing Additional Data. For Ecology to evaluate a plant's emissions or emission control program, the permittee shall furnish other data requested by Ecology. [WAC 173-405-072(5)]
40. Emission Inventory. Submit an inventory of emissions from the source each year no later than April 15<sup>th</sup> after the end of the calendar year. If April 15<sup>th</sup> falls on a weekend, then the deadline to file shall be the next business day. Maintain records of information necessary to substantiate any reported emissions. [WAC 173-400-105(1)]
41. CEMS and COMS Data Assessment Report. For CEMS and COMS subject to 40 CFR Part 60, submit a Data Assessment Report (DAR) quarterly (postmarked by April 15<sup>th</sup>, July 15<sup>th</sup>, October 15<sup>th</sup>, and January 15<sup>th</sup>) with the Monthly Air Monitoring Report. Include data for the previous three calendar months. The report must contain:
- a. Identification and location of monitors in the CEMS or COMS.
  - b. Manufacturer and model number of each monitor in the CEMS or COMS.
  - c. Assessment of CEMS data accuracy and date of assessment as determined by the RATA, RAA, or CGA; the RA for the RATA; the A for the RAA or CGA; the RM results, the cylinder gas certified values; the CEMs responses, and calculations. If results show the CEMS to be out-of-control, report both the audit results showing the CEMS to be out-of-control and the results of the audit following corrective action.
  - d. Assessment of COMS data accuracy as determined by the quarterly performance audit or annual zero alignment, COMS responses, and calculations. If results show the COMS to be out-of-control, report both the audit results showing the COMS to be out-of-control and the results of the audit following corrective action.
  - e. A summary of all corrective actions taken when CEMS or COMS was determined to be out-of-control. [40 CFR Part 60 Appendix F].
42. Permit Deviations and Excess Emissions. The Permittee shall promptly submit a report of any deviations from permit conditions. [WAC 173-401-615(3)(b)]
- a. For purposes of this permit, submitting a report "promptly" means the following: (a) If the deviation presents a potential threat to human health or safety, the report shall be made as soon as possible but no later than 12 hours after the discovery of the deviation; (b) for other deviations, "promptly" means that the deviations are identified in the respective monthly report.
  - b. Reports shall describe the probable cause of such deviations, and any corrective actions or preventive measures taken. [WAC 173-401-615(3)]. The Permittee may include in its reports demonstrations that excess emissions were unavoidable, consistent with the requirements of WAC 173-400-107 or -109, whichever is in effect at the time of the excess emissions.

43. Certification of truth, accuracy, and completeness. Any application form, report, or compliance certification required to be submitted by this permit or by Chapter 173-401 WAC shall contain certification by a responsible official of truth, accuracy, and completeness. This certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. [WAC 173-401-520]

44. Report Address. All reports and renewal applications required by this permit shall be submitted to:

Department of Ecology  
Industrial Section  
PO Box 47600  
Olympia, WA 98504-7600

45. Compliance Certification. The Permittee shall submit a report to the Department of Ecology and to EPA Region 10 by February 15<sup>th</sup>, certifying compliance with the terms and conditions contained in this permit for the year the certification covers. The certification shall describe the following:

- a. The permit term or condition that is the basis of the certification;
- b. the compliance status;
- c. whether compliance was continuous or intermittent; and
- d. the methods used for determining compliance.

[WAC 173-401-630(5)]

Where a permit does not require testing, monitoring, recordkeeping, and reporting for insignificant emission units or activities, the Permittee may certify continuous compliance if there were no observed, documented, or known instances of noncompliance during the reporting period. [WAC 173-401-530(2)(d)]

## STANDARD TERMS & CONDITIONS

46. Duty to Comply. The Permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of Chapter 70.94 RCW and, for federally enforceable provisions, a violation of the FCAA. Such violations are grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. [WAC 173-401-620(2)(a)]
47. Need to Halt or Reduce Activity Not a Defense. It shall not be a defense for a Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. [WAC 173-401-620(2)(b)]
48. Permit Actions. This permit may be modified, revoked, reopened, and reissued or terminated for cause. The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition. [WAC 173-401-620(2)(c)]
49. Reopening for Cause. This permit shall be reopened and revised under any of the following circumstances:
- a. Additional applicable requirements become applicable to a major Chapter 401 source with a remaining permit term of three or more years. Such a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions have been extended pursuant to WAC 173-401-620(2)(j);
  - b. Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approval by the administrator, excess emissions offset plans shall be deemed to be incorporated into the permit;
  - c. The permitting authority or the administrator determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit; or
  - d. The administrator or the permitting authority determines that the permit must be revised or revoked to assure compliance with the applicable requirements.
- Procedures to reopen and issue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. [WAC 173-401-730]
50. Property Rights. This permit does not convey any property rights of any sort, or any exclusive privilege. [WAC 173-401-620(2)(d)]

51. Duty to Provide Information. The Permittee shall furnish to the permitting authority, within a reasonable time, any information that the permitting authority may request in writing to determine whether cause exists for modifying, revoking, and reissuing, or terminating the permit, or to determine compliance with the permit. Upon request, the Permittee shall also furnish to the permitting authority copies of records required to be kept by the permit or, for information claimed to be confidential, the Permittee may furnish such records directly to the EPA administrator along with a claim of confidentiality. Permitting authorities shall maintain confidentiality of such information in accordance with RCW 70.94.205. [WAC 173-401-620(2)(e)]
52. Permit Fees. The Permittee shall pay fees as a condition of this permit in accordance with the permitting authority's fee schedule. Failure to pay fees in a timely fashion shall subject the Permittee to civil and criminal penalties as prescribed in Chapter 70.94 RCW. [WAC 173-401-620(2)(f)]
53. Emissions Trading. No permit revision shall be required, under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in this permit. [WAC 173-401-620(2)(g)]
54. Severability. If any provision of this permit is held to be invalid, all unaffected provisions of the permit shall remain in effect and be enforceable. [WAC 173-401-620(2)(h)]
55. Permit Appeals. This permit or any conditions in it may be appealed only by filing an appeal with the Pollution Control Hearings Board and serving it on the permitting authority within 30 days of receipt pursuant to RCW 43.21B.310. This provision for appeal in this section is separate from and additional to any federal rights to petition and review under § 505(b) of the FCAA. [WAC 173-401-620(2)(i)]
56. Permit Continuation. This permit is issued for a 5-year term; however, this permit and all terms and conditions contained therein, including any permit shield provided under WAC 173-401-640, shall not expire until the renewal permit has been issued or denied if a timely and complete application has been submitted. An application shield granted pursuant to WAC 173-401-705(2) shall remain in effect until the renewal permit has been issued or denied if a timely and complete application has been submitted. [WAC 173-401-620(2)(j)]
57. Application and Issuance of a Renewal Permit. The Permittee shall submit a complete permit renewal application to Ecology no later than six months, but no earlier than 18 months, prior to the expiration date of the existing permit. Permits being renewed are subject to the same procedural requirements, including those for public participation, affected state and EPA review that apply to the initial permit. [WAC 173-401-710(1) and (2)]
58. Inspection and Entry. Upon consent of the Permittee or upon presentation of credentials and other documents as may be required by law, the Department of Ecology or an authorized representative shall be allowed to:

- a. Enter the source;
  - b. Have access to and copy at reasonable times any records that must be kept under this permit;
  - c. Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit; and
  - d. As authorized by WAC 173-400-105 and the FCAA, sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or other applicable requirements. [WAC 173-400-105(3); WAC 173-401-630(2)]
59. Federally Enforceable Requirements. All terms and conditions of this permit, including any provisions designed to limit potential to emit, are enforceable by EPA and citizens under the FCAA, unless they are specifically designated as not federally enforceable. [WAC 173-401-625]
60. Tampering and False Statements. No person shall make any false material statement, representation, or certification in any form, notice, or report required in this permit. No person shall render inaccurate any monitoring device or method required under this permit. [WAC 173-400-105(8) and 40 CFR 70.11(a)]

#### **MISCELLANEOUS REQUIREMENTS**

61. Ecology may approve alternate compliance test methods that are of equivalent stringency for any air pollutant. [PSD 01-03, Amendment 3 and Order 3462-AQ-07]
62. Compliance monitoring frequency may be adjusted by Ecology depending on compliance history. [Order 3462-AQ-07]
63. Sampling ports and platforms must be provided for each affected source after the final pollution control device. The ports must meet the requirements of Reference Method 1 of 40 CFR, Part 60, Appendix A. Other arrangements may be acceptable if approved by Ecology prior to installation. Adequate permanent and safe access to the test ports must be provided. [Order 3462-AQ-07]
64. Ecology may require the continuous emission monitoring quality assurance plans submitted to Ecology on July 26, 1991 and December 22, 1995 to be periodically updated. The updates shall satisfy 40 CFR Part 60, Appendix F. [PSD 01-03, Amendment 3 and Order 3462-AQ07]
65. Data required to demonstrate compliance with emission limits in Order 3462-AQ07, Modification 1, Appendix A shall be reported in written form to the Washington State Department of Ecology Industrial Section or its authorized representative at least monthly (unless a different testing and reporting schedule has been approved by Ecology). The report shall be submitted in conformance with the time requirements included in 173-405 WAC, but in no case later than thirty days after the end of the calendar month being reported. The report shall be in a format approved by Ecology. Report contents shall include but not be limited to the following:

- a. The average daily production of machine dried unbleached pulp.
- b. Process or control equipment operating parameters.
- c. The information specified for individual limits, in units of the limit, for each pollutant monitored.
- d. The duration and nature of any monitor downtime.
- e. Results of any monitor audits or accuracy checks.
- f. Results of any stack test using approved Ecology or RPA test methods with acceptable QA/QC.

For each occurrence of monitored emissions or process parameters in excess of the standard the report shall include the following:

- g. The time of the occurrence.
- h. Magnitude of the emission or process parameter excess.
- i. The duration of the excess.
- j. The probable cause.
- k. Any corrective actions taken or planned.
- l. Any other agency contacted.
- m. Signature of responsible person.

[PSD 01-03, Amendment 3 and Order 3462-AQ07]

66. Operating and maintenance manuals for all equipment that has the potential to affect emissions to the atmosphere shall be developed and followed. Copies of the manuals shall be available to Ecology. Emissions that result from a failure to follow the requirements of the manuals may be considered proof that the equipment was not properly operated and maintained. [PSD 01-03, Amendment 3 and Order 3462-AQ07]
67. Any activity that is undertaken by the Permittee or others, in a manner which is inconsistent with the application and this determination, shall be subject to Ecology enforcement under applicable regulations. Nothing in this determination shall be construed so as to relieve the Permittee of its obligations under any state, local, or federal laws or regulations. [PSD 01-03, Amendment 3]



### PERMIT SHIELD

Pursuant to WAC 173-401-640(1), compliance with the terms and conditions of this permit is deemed to constitute compliance with applicable requirements as contained in this permit on which the term or condition is based, as of the date the permit is issued. This permit shield does not exempt the Permittee from requirements, determined to be applicable, enacted after the permit issuance date. This permit shield shall not apply to any insignificant emission unit or activity designated under WAC 173-401-530. [WAC 173-401-530(3)]

Pursuant to WAC 173-401-640(2), the Department of Ecology has determined that the requirements listed below do not apply to the facility, as of the date the permit is issued, for the reasons specified.

CITE	BRIEF DESCRIPTION	REASON
WAC 173-400-040(1)	No visible emissions over 20% opacity for 3 minutes in any one hour, with 4 exceptions.	Opacity standards in the Kraft Pulping Mill regulations (WAC 173-405) take precedence over the general emission standards of WAC 173-400. WAC 173-405-040.
WAC 173-400-040(3)(b)	Emissions unit identified as a significant contributor to nonattainment must use reasonable and available control methods to control emissions of contaminants for which area is designated nonattainment.	No emissions units at the facility have been identified as a significant contributor to nonattainment.
WAC 173-400-040(6)	General limit of 1,000 ppmdv SO <sub>2</sub> .	SO <sub>2</sub> standards for emission units at kraft pulping mills in the Kraft Pulping Mill regulations (WAC 173-405) take precedence over the general emission standards of WAC 173-400. WAC 173-405-040.
WAC 173-400-040(8)(b)	Sources of fugitive dust identified as significant contributors to a PM-10 nonattainment area must use RACT to control fugitive dust emissions.	Facility not located near a PM-10 nonattainment area.

CITE	BRIEF DESCRIPTION	REASON
WAC 173-400-050(1)	No particulate emissions in excess of 0.1 grain/dscf from combustion units, except no particulate emissions in excess of 0.2 grain/dscf from units combusting wood derived fuels for production of steam.	Particulate standards for combustion sources in the Kraft Pulping Mill regulations (WAC 173-405) take precedence over the general emission standards of WAC 173-400. WAC 173-405-040.
WAC 173-400-060	No particulate emissions in excess of 0.1 grain/dscf in general process units.	Inapplicable for smelt dissolving tanks #19. & #22. Particulate standards in the Kraft Pulping Mill regulations (WAC 173-405) take precedence over the general emission standards of WAC 173-400. WAC 173-405-040.
WAC 173-400-070(2)(a)	Hog fuel boilers must meet requirements of WAC 173-400-040 & -050(1), with exceptions.	Specific emission standards for combustion sources in the Kraft Pulping Mill regulations (WAC 173-405) take precedence over the general emission standards of WAC 173-400. WAC 173-405-040.
WAC 173-400-100	Registration required for listed sources, excluding sources subject to the operating permit program, after EPA grants interim or final approval to the state program.	Facility is subject to the operating permit program; EPA has granted interim approval for the state program.
WAC 173-400-105(5)(a)	Continuous opacity & SO <sub>2</sub> monitoring & recording required for fossil fuel-fired steam generators that are not subject to an NSPS, except where capacity is <250 million BTU/hr heat input or where there is an annual avg. capacity factor of ≥30%.	Inapplicable to power boiler #20 Power Boiler which is subject to NSPS requirement. WAC 173-400-105(5)(g)(i).

CITE	BRIEF DESCRIPTION	REASON
WAC 173-400-105(5)(d)	Continuous opacity monitoring & recording required for wood residue fuel-fired steam generators w/ capacity of $\geq 100$ million BTU/hr heat input that are not subject to an NSPS.	Inapplicable to power boiler #20 Power Boiler which is subject to NSPS requirement. WAC 173-400-105(5)(g)(i).
WAC 173-400-105(6)	Submittal required for raw material or fuel change resulting in SO <sub>2</sub> increase $\geq 40$ T/yr. Applies to sources that are not subject to operating permit program.	Facility is subject to the operating permit program.
WAC 173-400-151	Retrofit requirements for visibility protection. BART required for sources to which significant visibility impairment of a Class 1 area is reasonably attributable.	Facility has not been identified as a source impacting a Class I area.
WAC 173-405-040(7) <i>[STATE ONLY, NOT FEDERALLY ENFORCEABLE]</i>	Continuously employ best practicable operation and maintenance procedures for recovery furnaces or lime kilns with an alternative opacity limit.	Facility does not have any alternative opacity limits for recovery furnace or lime kiln.
WAC 173-405-077	Provisions of WAC 173-400-105(5) (Report of startup, shutdown, etc.) apply.	Old WAC 173-400-105(5) has been deleted from state regulations and the SIP.
Chapter 173-410 WAC	Sulfite pulping mill regulations.	Inapplicable to mill with the exception of the NSSC facility.
WAC 173-410-040(1)(a)	SO <sub>2</sub> emission limits for incineration of spent sulfite liquor.	Spent sulfite liquor not incinerated in NSSC system.

CITE	BRIEF DESCRIPTION	REASON
WAC 173-410-040(1)(e)	SO <sub>2</sub> emission limits for sulfite recovery systems.	Chemical recovery not conducted in NSSC system.
WAC 173-410-040(2)(a)&(b)	Particulate emission limits for sulfite recovery systems.	Chemical recovery not conducted in NSSC system.
WAC 173-410-040(2)(c)(i)&(ii)	Particulate emission limits for units combusting wood for steam at sulfite mills.	Steam production not conducted in NSSC system.
WAC 173-410-040(5)	TRS emission limits for sulfite recovery systems.	Chemical recovery not conducted in NSSC system.
WAC 173-410-067	Provisions of WAC 173-400-105(5) (Report of startup, shutdown, etc.) apply.	Old WAC 173-400-105(5) has been deleted from state regulations and the SIP.
Chapter 173-433 WAC	Solid fuel burning device regulations. Applies to wood stoves and fireplaces.	Facility does not operate such devices.
Chapter 173-435 WAC	Air emergency episode plan including source emission reduction plan (SERP) requirements.	Inapplicable except for 040, 050(2), and 060(5).
Chapters 173-470, 474, 475, 480, 481 WAC	Ambient air quality standards.	WAC 173-401-200(4)(a)(xii) states that NAAQS are applicable requirements only as they would apply to temporary sources permitted pursuant to 173-401-635.
Chapter 173-490 WAC	Emission standards and controls for sources of VOCs.	Applies only to facility types specified in the regulation; pulp and paper mills are not specified.

CITE	BRIEF DESCRIPTION	REASON
40 CFR Part 60 Subpart Db	NSPS for steam generators constructed after June 19, 1984 with a heat input rating >100 mmBtu/hr.	Inapplicable to Power Boiler #20 (all limits except PM and opacity are inapplicable to PB20) and Recovery Furnaces #18 & #19 which were constructed prior to the applicability date. Since then, there was no occurrence of a physical change or change in method of operation which increased pollutants to which a standard applied. Per Order 8429, PB 20 has undergone a physical modification with respect to PM and opacity.
40 CFR Part 60 Subpart Dc	NSPS for steam generators constructed after June 9, 1989, with design heat input rating of >10 mmBtu/hr and <100 mmBtu/hr.	Facility has no units this size.
40 CFR 60.43(a)(2)	SO <sub>2</sub> emission limits for subpart D facilities that combust solid fossil fuel, alone or with wood residue fuel.	Facility does not combust solid fossil fuel.
40 CFR 60.44(a)(3)	NO <sub>x</sub> emission limits for to subpart D facilities that combust solid fossil fuel, alone or with wood residue fuel.	Facility does not combust solid fossil fuel.
40 CFR 60.44(a)(4)&(5)	NO <sub>x</sub> emission limits for to subpart D facilities that combust lignite, alone or with wood residue fuel.	Facility does not combust lignite.
40 CFR 60.284(b)(1)	Applies to units burning emissions from digester systems, brownstock washer systems, multiple-effect evaporator systems, or condensate stripper systems in an incinerator.	Facility does not burn in an incinerator.

CITE	BRIEF DESCRIPTION	REASON
40 CFR 60.284(b)(2)	Requirement for scrubber monitoring at NSPS lime kiln.	Inapplicable at Lime Kiln 5 because a scrubber is not used.
40 CFR 60 Subpart K	NSPS for petroleum storage vessels constructed or modified after 6/11/73 and prior to 5/19/78.	Products stored at the facility do not contain petroleum products as defined in Section 60.111a(b).
40 CFR 60 Subpart Ka	NSPS for petroleum storage vessels constructed or modified after 5/18/78 and prior to 7/23/84.	Products stored at the facility do not contain petroleum products as defined in Section 60.111a(b).
40 CFR 60 Subpart Kb	NSPS for petroleum storage vessels constructed or modified after 7/23/84.	Product vapor pressure below volatile organic liquid threshold.
40 CFR 60 Subpart III	NSPS for Stationary Compression Ignition Internal Combustion Engines, for units constructed after July 11, 2005	Inapplicable to turbine room diesel emergency generator onsite as the unit was constructed prior to July 11, 2005.

## Appendix A – Monitoring and Calculation Specifications

### APA.1: OPERATING LIMIT CALCULATIONS

Compliance with the operating limit for each emission unit shall be made by recording and reporting the quantities from number (3), below:

- (1) Record the number of hours of operation of the emissions unit since the last report.
- (2) Record the total production through the emissions unit since the last report.
- (3) Average production rates:
  - (a) For Power Boilers, divide the quantity from (2) by the quantity from (1) to get the average hourly production.
  - (b) For Recovery Furnaces, Smelt Dissolving Tanks, and Lime Kilns, divide the quantity from (2) by the quantity from (1), and multiply by twenty-four to get the average (24-hr) daily production.
- (4) Total primary production is the total paper and board saleable product from the paper machines. All trim and cull go back into pulp furnish to the paper machines.
  - (a) Record daily total primary production.
  - (b) Total for the days since end of the last reporting period.
  - (c) Add to annual total in last report.
  - (d) Subtract the amount of the corresponding period from the immediately previous year.

[PSD 01-03]

### APA.2: MONITORING TERMINOLOGY AND GENERAL SOURCE TEST REQUIREMENTS

Test method abbreviations:

*RM 5: Determination of Particulate Emissions from Stationary Sources*

Reference Method 5 of 40 CFR, Part 60, Appendix A, or an alternative approved by Ecology, under the assumption that all of the particulate collected is PM10.

[PSD 01-03].

*RM 6C: Determination of Sulfur Dioxide Emissions from Stationary Sources*

Reference Method 6C of 40 CFR, Part 60, Appendix A, or an alternative approved by Ecology. For SO<sub>2</sub> source tests conducted on a stack with a continuous TRS monitor, the test may be conducted using Longview Source Test Method 201, a modification of Method 6C which uses the TRS monitor in an SO<sub>2</sub> monitoring mode. Longview Source Test Method No. 311 which uses a certified portable SO<sub>2</sub> emission monitor may be used as an approved test procedure. [PSD 01-03]

*RM 7: Determination of Nitrogen Oxide Emissions from Stationary Sources*

Reference Method 7 of 40 CFR, Part 60, Appendix A, or an alternative approved by Ecology. Longview Source Test Method No. 311 which uses a certified portable SO<sub>2</sub> emission monitor may be used as an approved test procedure. [PSD 01-03]

*RM 9: Visual Determination of the Opacity of Emissions from Stationary Sources*

Reference Method 9 of 40 CFR, Part 60, Appendix A; or Ecology Method 9B as found in the 'Source Test Manual - Procedures for Compliance Testing', 1983, or an alternative approved by Ecology. [Order 3462-AQ07]

*RM 10: Determination of Carbon Monoxide Emissions from Stationary Sources*

Reference Method 10 of 40 CFR, Part 60, Appendix A, or an alternative approved by Ecology. Longview Source Test Method No. 311 which uses a certified portable SO<sub>2</sub> emission monitor may be used as an approved test procedure. [PSD 01-03]

*RM 16: Semicontinuous Determination of Sulfur Emissions from Stationary Sources*

Reference Method 16 of 40 CFR, Part 60, Appendix A, and measured as H<sub>2</sub>S, or an alternative approved by Ecology. Longview Source Test Method 202, which captures gas in a Tedlar bag for analysis, may be used to test smelt dissolving tank TRS emissions. [PSD 01-03]

*RM 25A: Determination of Total Gaseous Organic Concentration using Flame Ionization analyzer*

Reference Method 25A of 40 CFR, Part 60, Appendix A, and measured as C, or an alternative approved by Ecology. [PSD 01-03]

*PS 1:* Performance Specification 1 of 40 CFR, Part 60, Appendix B, "Specification and Test Procedures for Opacity Continuous Emissions Monitoring Systems in Stationary Sources." [Order 3462-AQ07]

*PS 2:* Performance Specification 2 of 40 CFR, Part 60, Appendix B, "Specification and Test Procedures for SO<sub>2</sub> and NO<sub>x</sub> Continuous Emissions Monitoring Systems in Stationary Sources." [PSD 01-03]

*PS 3:* Performance Specification 3 of 40 CFR, Part 60, Appendix F and Appendix B, "Specification and Test Procedures for O<sub>2</sub> and CO<sub>2</sub> Continuous Emissions Monitoring Systems in Stationary Sources." [Order 3462-AQ07]

*PS 4:* Performance Specification 4 of 40 CFR, Part 60, Appendix B, "Specification and Test Procedures for Carbon Monoxide Continuous Emissions Monitoring Systems in Stationary Sources." [PSD 01-03]

*PS 5:* Performance Specification 5 of 40 CFR, Part 60, Appendix B, "Specification and Test Procedures for TRS Continuous Emissions Monitoring Systems in Stationary Sources." [PSD 01-03]



Test and reporting frequency abbreviations: [PSD 01-03]

A/M: means source test is to be performed annually. If any single source exceeds 75% of the limitation, source testing shall be performed monthly (see qualification, below) until 6 consecutive month's tests are below 75% of the limitation, at which time testing may return to an annual schedule. Monthly source testing shall commence within 60 days of the source test which exceeded 75% of the limitation.

M/Q: means source test is to be performed monthly (see qualification, below). Source testing may be reduced to quarterly (see qualification, below) if 6 consecutive month's tests are below 75% of the limitation. If any single source exceeds 75% of the limitation, source testing shall revert to monthly until 6 consecutive month's tests are below 75% of the limitation. Monthly source testing shall commence within 60 days of the source test which exceeded 75% of the limitation.

T/M: means source test is to be performed triennially. If any single source test exceeds 75% of the limitation, source testing shall be performed monthly (see qualification, below) until 6 consecutive month's tests are below 75% of the limitation, after which source testing may return to triennially. Monthly source testing shall commence within 60 days of the source test which exceeded 75% of the limitation.

**Qualification:**

"Monthly" test cycle: A source test must be performed in any month wherein the unit was operated more than 216 hours. A source test must be performed prior to the emissions unit having been operated a total of 720 hours since the end of the month of the last source test.

"Quarterly" test cycle: A source test must be performed in any quarter wherein the unit was operated more than 648 hours. A source test must be performed prior to the emissions unit having been operated a total of 2,160 hours since the end of the quarter of the last source test.

"Annual" test cycle: A source test must be performed in any calendar year wherein the unit was operated more than 2,628 hours. A source test must be performed prior to the emissions unit having been operated a total of 8,640 hours since the end of the calendar year of the last source test.

A: relative to reporting frequency, means annually

C: means testing is continuous by virtue of the CEM.

M: relative to reporting frequency, means monthly.

Q: relative to reporting frequency, means quarterly.

T: relative to reporting frequency, means triennially.

General source test requirements - compliance determination using source testing shall be as follows: [PSD 01-03]

During all emissions testing (source testing) runs, the concurrent process rate of the emission unit shall be recorded in units of measurement characteristic of the emission unit, and submitted with the source test data.

An emissions unit with one stack: The arithmetic mean of three or more runs of at least one hour each in duration.

NOTE: Compliance may be demonstrated for NO<sub>x</sub> and SO<sub>2</sub> emission concentration limit on Lime Kiln 5 and for the CO emission concentration limit on Power Boiler 20 by applying this three-run protocol on one of their two respective stacks.

An emissions unit with two stacks: The arithmetic mean of runs made on both stacks. Two or more runs of at least one hour each in duration must be made on each stack.

Any test runs Longview believes to be invalid due to procedural error may be dropped from the arithmetic mean calculation. Results of such “invalid” runs are to be included in the monthly report with an explanation of the “invalid” determination.

ApA.3: RF, SDT, & LK Mass Rate Limit Calculations

**Compliance with the mass rate limit** for the recovery furnaces, smelt dissolving tanks, and lime kilns shall be monitored as follows: [PSD 01-03]

(1) **Emission Factor:** Pounds pollutant per ton process quantity for each emissions unit.

(a) **Using source test data:** Use source test data for emissions units and pollutants not having CEMS. From the most recent source test results, convert the emission concentration, corresponding stack gas flow rate and emission unit process rate for each run to the equivalent pounds of pollutant emission per process unit of measurement, such as lbs. SO<sub>2</sub>/lb. black liquor solids.

Example 1:  $\{[source\ test\ ppm\ dv\ SO_2] \times (10^{-6}) \times [source\ test\ dscfm] \times (60\ min./hr.) \times (64\ lb.\ SO_2)\} \div [(385\ scf\ SO_2) \times (source\ test\ tons\ BLS\ /hr.)] = lbs.\ SO_2/TBLS$

The same equation may be used for CO, NO<sub>x</sub>, H<sub>2</sub>S/TRS, and VOCs by making the following respective substitutions for the term “64 lb. SO<sub>2</sub>”:

28 lb. CO, 46 lb. NO<sub>x</sub>, 34 lb. H<sub>2</sub>S/TRS, and 12 lb. VOCs as carbon.

Example 2:  $\{[source\ test\ gr/dscf\ PM_{10}] \times (1b./7,000\ gr) \times [source\ test\ dscfm] \times (60\ min./hr.) \div (source\ test\ tons\ BLS\ /hr.)\} = lbs.\ PM_{10}/TBLS$

Example 3, Dry kilns:  $\{[source\ test\ ppm\ dv\ SO_2] \times (10^{-6}) \times [source\ test\ dscfm] \times (60\ min./hr.) \times (64\ lb.\ SO_2)\} \div [(385\ scf\ SO_2) \times (source\ test\ tons\ CaO\ /hr.)] = lbs.\ SO_2/ton\ CaO$

The equation may be used for CO, NO<sub>x</sub>, and H<sub>2</sub>S/TRS by making the following respective substitutions for the term “64 lb. SO<sub>2</sub>”:

28 lb. CO, 46 lb. NO<sub>x</sub>, and 34 lb. H<sub>2</sub>S/TRS

Example 4, Dry kilns:  $\{[source\ test\ gr/dscf\ PM_{10}] \times (1b./7,000\ gr) \times [source\ test\ dscfm] \times (60\ min./hr.) \div (source\ test\ tons\ CaO/hr.)\} = lbs.\ PM_{10}/ton\ CaO$

Calculate the arithmetic mean of the source test runs for each pollutant and each emission unit as described in ApA.2 of this AOP.

(b) **Using CEMS data:** Use CEMS data for applicable emissions units and pollutants.

(i) Determine the average daily process throughput for each emissions unit:

Recovery furnaces – tons black liquor solids per hour (TBLS/hr.). Lime kilns – tons calcium oxide per hour (CaO/hr.).

(ii) From each average daily process throughput, calculate the related stack exhaust flow. Use the equations relating process throughput to stack exhaust flow currently approved by Ecology (see ApA.6 of this AOP).

- (iii) Determine the daily average emission concentration for each emissions unit and pollutant having a related CEMS.
  - (iv) Calculate the emissions factors for the reporting period. The examples in (1)(a), above may be used by substituting the corresponding quantities from (1)(b)(i), (ii), and (iii) for the “*source test*” quantities.
- (2) **Tons per year:**
- (a) Amount processed through the emissions unit since the closing date of the last report.
    - (i) For recovery furnaces and smelt dissolving tanks: Determine the total tons BLS processed through the emission unit since the closing date of the last report.
    - (ii) For the lime kilns: Determine the total tons CaO processed through the emission unit since the closing date of the last report.
  - (b) For each pollutant and emissions unit, multiply the emission factor from (1) by the quantity processed [(2)(a)(i) for the recovery furnaces and smelt dissolving tanks or (2)(a)(ii) for the lime kilns], and divide by 2,000 lbs./ton. The result should be the tons of each pollutant that have been emitted from each emissions unit since the closing date of the last report. Add up the analogous quantities calculated for sufficient contiguous prior periods to total one year’s worth of pollutant emissions for each emissions unit. Each such quantity must be less than the corresponding limit (TPY) in this AOP to demonstrate compliance.

#### APA.4: PB MASS RATE LIMIT CALCULATIONS

**Compliance with mass rate limits** for the power boilers: [PSD 01-03]

- (1) **Emission Factor**, Pounds pollutant per ton process quantity for each emissions unit: Convert each emission concentration, corresponding stack gas flow rate, and power boiler fuel application rate to the equivalent pounds of pollutant emission per million Btu (lb./mmBtu). In the examples below,
- (a) If continuous emissions monitoring (CEM) has been installed: Apply the examples in this appendix (ApA.4), below. Pollutant “*concentration*” is the average daily concentration. “*Exhaust gas flow*” may be calculated from the appropriate “F-factor(s)” from 40 CFR Part 60, Appendix A, Method 19 if not otherwise known. “*Fuel applied*” is to be determined from the average daily fuel composition. Exclude boiler downtime from all calculations.
  - (b) If CEM data are not available, the pollutant *concentration*, *exhaust gas flow*, and *fuel applied* are from the most recent source test run results. Where source test data are used, apply the examples in this table note, below, to each of the source test runs for each pollutant and each power boiler. Calculate the arithmetic mean as described in ApA.2 of this AOP.
  - (c) For Power Boiler 16, calculate SO<sub>2</sub> emissions (lbs. SO<sub>2</sub>/MMBtu) from the purchase records and vendor’s reports on fuel sulfur content for the fuel applied during the reporting period.

Example 1:  $\{ [SO_2 \text{ concentration ppmdv}] \times (10^{-6}) \times [exhaust \text{ gas flow dscfm}] \times (60 \text{ min./hr.}) \times (64 \text{ lb. SO}_2) \} \div [(385 \text{ scf SO}_2) \times (fuel \text{ applied mmBtu/hr.})] = \text{lbs. SO}_2/\text{MMBtu}$

The equation may be used for CO and NO<sub>x</sub> by making the following respective substitutions for the term “64 lb. SO<sub>2</sub>.”

28 lb. CO, and 46 lb. NO<sub>x</sub>.

$$\begin{aligned} \text{Example 2: } & \{ [ \text{PM}_{10} \text{ concentration gr/dscf} ] \times (1\text{b./}7,000 \text{ gr}) \times [ \text{exhaust gas flow dscfm} ] \times \\ & (60 \text{ min./hr.}) \div ( \text{fuel applied mmBtu/hr.} ) \} \\ & = \text{lbs. PM}_{10} / \text{mmBtu} \end{aligned}$$

**(2) Tons per year:**

- (a) Determine the total fuel applied to each power boiler since the closing date of the last report in mmBtu.
- (b) For each pollutant and each power boiler, multiply the respective quantities from (1) and (2)(a), and divide by 2,000 lbs./ton. The result should be the tons of each pollutant emitted from each power boiler since the closing date of the last report. Add this quantity to the analogous quantities calculated for sufficient contiguous prior periods to total one year's worth of emissions for each power boiler. This quantity must be less than the corresponding limit (TPY) in this AOP to demonstrate compliance.

**ApA.5: Plant Wide Limit Calculations**

Compliance determination for plant wide limits: [PSD 01-03]

- (1) Report daily Kraft and total machine production in tons. Add sufficient contiguous periods including the current reporting period to give a twelve month total.
- (2) For PM & PM<sub>10</sub>, SO<sub>2</sub>, CO, and NO<sub>x</sub>: For each pollutant, add the emissions calculated for the period since the close of the last report from the recovery furnaces (19 and 22), the smelt dissolving tanks (19 and 22), the lime kilns (3 through 5), and the power boilers (20) to the analogous quantities calculated for sufficient contiguous prior periods to total one year's worth of emissions concluding with the close of the current reporting period.
- (3) For VOCs:
  - (a) Determine the total tons of black liquor solids processed through each recovery furnace and all smelt dissolving tanks for the one year period ending with the close of the reporting period.
  - (b) Determine the total tons of CaO produced by each lime kiln for the one year period ending with the close of the reporting period.
  - (c) Determine the average fuel application rate for each power boiler (mmBtu/hr.) for the one year period ending with the close of the reporting period. Add them together.
  - (d) Kraft digesters, brownstock washer, and knotter, Primary black liquor oxidizer, Paper machines, and Cooling tower:
    - (i) Abbreviations:
      - B = Batch Kraft digester, MDTP
      - CT = Cooling tower, MDTP
      - K1 = #1 Kamyra digester, MDTP
      - K2 = #2 Kamyra digester, MDTP
      - M&D = Continuous Kraft digester, MDTP
      - OxMDTP = Primary black liquor oxidizer, MDTP
      - PPMP = Primary paper machines, MDTP
    - (ii) Determine the sum of the tons of black liquor solids processed through recovery furnaces 18 and 19 tanks for the one year period ending with the close of the reporting period.

- (iii) Determine the sum of the tons of black liquor solids processed through recovery furnaces 18, 19, and 22 tanks for the one year period ending with the close of the reporting period.
- (iv) Divide the number from (ii) by the number from (iii).
- (v) Determine the production in MDTP from each of K1, K2, B, and M&D tanks for the one year period ending with the close of the reporting period.
- (vi) Sum  $K1 + K2 + B + M\&D$  from (v).
- (vii) Multiply the number from (iv) by the number from (vi) to give OxMDTP for the one year period ending with the close of the reporting period.
- (viii) Multiply the sum of K1 and K2 from (v) by 0.992 to give the pounds of VOCs for the one year period ending with the close of the reporting period from Kamyr digesters #1 and #2.
- (ix) Multiply the sum of B and M&D from (v) by 0.96 and add the product of B times 0.136 to give the pounds of VOCs for the one year period ending with the close of the reporting period from the Batch and Continuous Kraft digesters.
- (x) Multiply OxMDTP from (vii) by 0.355 to give the pounds of VOCs for the one year period ending with the close of the reporting period from the Primary black liquor oxidizer.
- (xi) Multiply the total primary production from (1) by 1.075 to give the pounds of VOCs for the one year period ending with the close of the reporting period from the Primary paper machines and cooling tower.
- (xii) Sum the quantities from (viii), (ix), (x) and (xi) to give the plant wide pounds of VOCs for the one year period ending with the close of the reporting period.
- (e) Multiply the quantity from (3)(a) by 0.21 to give the pounds of VOCs during the past twelve months from recovery furnaces and smelt dissolving tanks.
- (f) Multiply the quantity from (3)(b) by 0.026 to give the pounds of VOCs during the past twelve months from the lime kilns and related lime recovery equipment.
- (g) Multiply the quantity from (3)(c) by 117.4 to give VOCs from the power boilers.
- (h) Add the quantities from (3)(d) through (3)(g), and divide the result by 2,000 to give tons per year (TPY) VOCs, plant wide.
- (4) For daily maximum steam production: Divide the daily total steam production by 24, and report the result in units of the limit.

#### **APA.6: EXHAUST STACK FLOW CORRELATIONS**

[PSD 01-03]

**Exhaust stack flow correlations:** At least annually, the Permittee shall update equations for calculation of gas flow from each recovery furnace and lime kiln exhaust stack. [PSD 01-03: Condition 2]

The equations shall correlate exhaust stack gas flows to process rate from the emissions units. The correlation shall be based on linear regression analysis.

By January 31<sup>st</sup> of each year, the Permittee shall submit the updated equations, the data on which they are based, and the regression analyses to Ecology for approval. The Permittee may submit proposed updates more frequently at its option. An update for an emissions unit shall have occurred only when new data are submitted.

For emission units operated 6,000 hours or more since the last update, each update shall include at least 12 hours of new data, and drop an equal amount of the oldest data. For emission units operated less than 6,000 hours since the last update, the minimum hours of new data (and dropped oldest data) shall be

$(\text{Hours of operation since last update}) \times 12 \div 6,545$ , rounded to the nearest whole number.

The updated equations shall take effect upon approval from Ecology.

Specific calculations to determine exhaust stack gas flow correlations shall be as follows:  
[PSD 01-03: Appendix 2]

1. **Recovery Furnaces:** Where exhaust stack flow is not directly measured, for compliance purposed it may be calculated from the following general form.

**Exhaust stack flow** (dscfm @ 8% O<sub>2</sub>) = a + b × (BLS production rate, lb./hr.)

At the time of issuance of PSD 01-03 and until updated in accordance with procedures in this appendix (ApA.6), the coefficients in the above equation shall be:

$$a = 19,631$$

$$b = 1.3758$$

2. **Lime Kilns:** Exhaust stack flow from lime kilns is the sum of combustion exhaust and carbon dioxide generated by the calcine reaction. Where exhaust stack flow is not directly measured, for compliance purposed it may be calculated from the following general form.

**Combustion exhaust flow** (dscfm @ 10% O<sub>2</sub>) = 1.917<sup>★</sup> × (F-factor<sup>★</sup>, dscf/mmBtu)  
× (lime kiln economy, Btu/ton CaO)  
× CaO production rate, tons/hr.)  
÷ (60 min./hr.)

At the time of issuance of PSD 01-03 and until updated in accordance with procedures in this appendix (ApA.6), the coefficients in the above equation shall be:

$$\text{F-factor} = 8,740 \text{ dscf/mmBtu}$$

$$\text{Lime kiln economy} = 10 \times 10^6 \text{ Btu/ton CaO for lime kilns \#3 and \#4}$$

$$6.5 \times 10^6 \text{ Btu/ton CaO for lime kiln \#5}$$

**Calcine exhaust flow** (dscfm @ 10% O<sub>2</sub>) = 1.917<sup>★</sup> × (13,750<sup>▼</sup> dscf @ 10% O<sub>2</sub> per ton CaO)  
× CaO production rate, tons/hr.)  
÷ (60 min./hr.)

**Add Combustion exhaust flow and Calcine exhaust flow for total Lime Kiln exhaust flow.**

- This coefficient adjusts to 10% O<sub>2</sub>.
- From 40 CFR Part 60, Appendix A, Method 19.
- Assuming ideal gas behavior, and based on the standard calcine reaction product

## Appendix B – Emission Control Compliance Demonstration Plan

The Permittee maintains an "Emission Control Compliance Demonstration Plan" specifying emission control parameter levels to demonstrate compliance with 40 CFR Part 63 - Subpart MM, 40 CFR Part 64 - CAM, and opacity requirements for several sources. Changes to the plan can be made by submitting revisions along with justification for the revisions as part of a monthly report. The revision submission must include an updated summary table including all current emission control parameter levels in effect after the revision. A revision is accepted and in effect unless Ecology notifies the Permittee in writing that the revision is rejected. If a revision is rejected, the emission control parameter level in effect prior to the revision request remains in effect.

The summary table including all current emission control parameter levels in effect at the time of the AOP renewal is included as follows:

Permittee Emission Control Compliance Demonstration Plan - Parameter Summary Table  
PM, PM10, and Opacity Parameters (Order 3462-AQ07):

Unit	Pressure Drop (inches H <sub>2</sub> O)	Scrubber Recirculation Flow (gpm)	Make-up Water Flow (gpm)
Lime Kiln 3	≥17.0	≥310	≥75

Unit	Pressure Drop (inches H <sub>2</sub> O)	Hi Pressure Flow (gpm)	Hi Pressure H <sub>2</sub> O Pressure (psig)
Lime Kiln 4	≥10.4	≥353	≥404

Unit	Pressure Drop (inches H <sub>2</sub> O)	Venturi Scrubber Flow (gpm)	Packed Tower Flow (gpm)
Smelt Dissolver Tank 19 <sup>1</sup>	≥8.1	≥96	≥72
Smelt Dissolver Tank 22	≥9.6	≥92	≥72

Unit	Pressure Drop (inches H <sub>2</sub> O)	Scrubber Flow (gpm)	Normal Condition Wet ESP Total Power (kW)	Field Down Wet ESP Total Power (kW)
Power Boiler 20 N <sup>2</sup>	>0	≥100	≥50	≥70 <sup>3</sup>
Power Boiler 20 S <sup>2</sup>	>0	≥100	≥50	≥70 <sup>3</sup>

1. Parameters apply to both stacks.
2. Scrubber flow rate applies to each scrubber.

3. Unit may only operate by firing natural gas when both N and both S wet ESP rectifier units are out of service. When burning wood and/or oil, if one field goes down in the PB20 N stack and cannot be restarted within 30 minutes, then boiler rate must be cut to a maximum of 50% nominal capacity and all flow routed through PB20 S stack until the field is repaired or wood and/or oil burning is discontinued. When burning wood and/or oil, if one field goes down in the PB20 S stack and cannot be restarted in 30 minutes, then boiler rate must be cut to a maximum of 50% nominal capacity and all flow routed through PB20 N stack until the field is repaired or wood and/or oil burning is discontinued. Nominal capacity is 600,000 pounds per hour of 800 psig steam, 50% steam from wood firing and 50% steam from fossil fuel firing. Minimum power requirements do not apply when firing natural gas only.



### **Appendix C – Applicable Permits and Orders**

The specific applicable elements of these documents have been incorporated into the permit itself. The documents in entirety are kept on file and available for public review by contacting Ecology's Industrial Section.

Order No. 2737-AQ05

PSD 01-03 (No. 01-03, Third Amendment Final Approval of Prevention of Significant Deterioration Application)

NOC Order No. 3462-AQ07, Modification 1

Order No. 3463-AQ07

NOC Order No. 3466-AQ07

NOC Order 8429, Modification 1

NOC Order 9213

Order No. 13302, Modification 1