

IM# 7,196

# NOC Application/Permit Revision/AOP Off-Permit Change Notification

NOTE: Any increase to abated or unabated PTE requires a full NOC modification

RECEIVED

## REASON FOR CHANGE

MAR 21 2012

Submittal Date: 3-21-12

Wa Dept of Health - Office of Radiation Protection

NOC Application Revision

Condition Change/ Clarification

WDOH Condition Number: 4

AOP Condition Number: \_\_\_\_\_

ALARACT Revision

New ALARACT Rev Number: \_\_\_\_\_

## PROJECT IDENTIFICATION

Project Title: E-525 Double-Shell Tank (DST) Transfer System Modifications Project

Current NOC Application Number: RPP-ENV-46299, Transmittal letter 10-ESQ-210 dated 7/2/2010

AEI ID Number (AOP Emission Unit Number(s)): 751

Current WDOH Approval Letter Number(s): AIR 12-334

WDOH NOC ID Number: 855

## DESCRIPTION OF CHANGE

Number of Attachments 0

*WDOH will provide a new approval letter containing any new or modified conditions that result from the following proposed change.*

Proposed Change (provide original and proposed wording):

DELETE AIR 12-334 approval order condition number 4, original wording as follows:

*"4) The breather filter shall be individually tested, annually, to the requirements of ASME AG-1 Section TA, and shall have a minimum efficiency of 99.95%."*

JUSTIFICATION: Emission unit ID #751 241-AZ-301 as listed in FF-01 License effective February 23, 2012, page 1 of 5 for EU\_ID 751 states:

*"Additional Requirements Radial breather filters shall be replaced every 365 days".*

The 241-AZ-301 was fitted with a radial breather filter October 17, 2010 and the annual AG-1 testing requirements are no longer applicable.

## SIGNATURES

Reviewed by Contractor	Reviewed by RL/ORP	Approved by WDOH
<i>DLOYEKMAN Doh</i>	<i>Dennis Boush</i>	
<i>Lucinda Penn</i>		
Date: <u>3-21-12</u>	Date: <u>3-21-12</u>	Date: _____