

**WASTE TREATMENT AND IMMOBILIZATION PLANT  
CHAPTER 4.0  
PROCESS INFORMATION  
CHANGE CONTROL LOG**

Change Control Logs ensure that changes to this unit are performed in a methodical, controlled, coordinated, and transparent manner. Each unit addendum will have its own change control log with a modification history table. The “**Modification Number**” represents Ecology’s method for tracking the different versions of the permit. This log will serve as an up to date record of modifications and version history of the unit.

Modification History Table

Modification Date	Modification Number
02/06/2026	8C.2025.3F
09/13/2024	24590-LAW-PCN-ENV-24-002 (8C.2024.Q3)
05/26/2022	24590-WTP-PCN-ENV-21-004 (8C.2022.Q2)
09/01/2021	24590-WTP-PCN-ENV-20-004 (8C.2021.Q3)
06/24/2020	8C.2020.3F
03/23/2020	24590-LAW-PCN-ENV-18-012 (8C.2020.Q1)
07/01/2019	8C.2019.2F
10/01/2018	24590-WTP-PCN-ENV-18-003 (8C.2018.Q4)
09/05/2017	8C.2017.6F
12/15/2016	8C.2016.Q3
06/20/2016	8C.2016.4F

This page intentionally left blank.

1  
2  
3  
4  
5  
6

**WASTE TREATMENT AND IMMOBILIZATION PLANT**  
**CHAPTER 4.0**  
**PROCESS INFORMATION**

1  
2  
3  
4  
5

This page intentionally left blank.

**CHAPTER 4.0**  
**PROCESS INFORMATION**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36

**TABLE OF CONTENTS**

4.0 Process Information .....5

4.1 Process Description.....5

4.1.1 Process Overview.....6

4.2 Tank Systems .....9

4.2.1 Design, Installation, and Assessment of Tank Systems ..... 10

4.2.2 Ancillary Equipment Requirements ..... 11

4.2.3 Integrity Assessments..... 15

4.2.4 Additional Requirements for Existing Tanks..... 16

4.2.5 Additional Requirements for New Tanks ..... 16

4.2.6 Variances from Secondary Containment Requirements .....20

4.2.7 Tank Management Practices .....20

4.2.8 Routinely Non-Accessible Area.....21

4.2.9 Air Emissions .....21

4.2.10 Management of Ignitable, Reactive and Incompatible Waste in Tanks.....24

4.3 Waste Treatment Plant Miscellaneous Treatment Sub-Systems [WAC 173-303-680 and WAC 173-303-806(4)(i)].....24

4.3.1 Melter Capacity and Production.....24

4.3.2 Description of Melter Units [WAC 173-303-806(4)(i)(i)].....25

4.3.3 Automatic Waste Feed Cut-Off System.....27

4.3.4 Offgas Treatment System.....27

4.3.5 Miscellaneous Unit Emissions Performance.....27

4.3.6 Physical and Chemical Characteristics of Waste [WAC 173-303-680(2)(a)(i)] .....28

4.3.7 Environmental Performance Standards for Melter Systems [WAC 173-303-680(2)].....29

4.3.8 Treatment Effectiveness Report [WAC 173-303-806(4)(i)(iv)] .....29

4.3.9 Approach to Risk Assessment [WAC 173-303-680(2)(c)(i) through (vii)].....29

4.4 Other Waste Management Units .....30

4.4.1 Waste Piles .....30

4.4.2 Surface Impoundments.....30

4.4.3 Incinerators.....30

4.4.4 Landfills .....31

1 4.4.5 Land Treatment .....31  
2 4.4.6 Air Emissions Control .....31  
3 4.4.7 Waste Minimization .....32  
4 4.4.8 Groundwater Monitoring for Land-Based Units .....32  
5 4.4.9 Functional Design Requirements .....32

6

7 **CHAPTER 4 SUBCHAPTERS TABLE OF CONTENTS**

8 Chapter 4A, Figures and Drawings ..... 4A.i  
9 Chapter 4C, Compliance with Uniform Building Code Seismic Design Requirements ..... 4C-i  
10 Chapter 4D, Pretreatment Facility ..... 4D.i  
11 Chapter 4E, Low-Activity Waste Vitrification Facility ..... 4E.i  
12 Chapter 4F, High-Level Waste Vitrification Facility .....4F.i  
13 Chapter 4G, Direct-Feed Low-Activity Waste (Effluent Management Facility) .....4G.i  
14 Chapter 4H, Analytical Laboratory (LAB)..... 4H.i  
15 Chapter 4I, Balance of Facilities ..... 4I.i

16

17

1 **4.0 PROCESS INFORMATION**

2 **4.1 Process Description**

3 The Hanford Tank Waste Treatment and Immobilization Plant (WTP) is a Treatment, Storage, and  
4 Disposal (TSD) Facility, permitted as Operating Unit Group 10 under the Hanford Dangerous Waste  
5 Permit. The WTP includes six major facilities. These facilities are the Low-Activity Waste (LAW)  
6 Vitrification Facility, the High-Level Waste (HLW) Vitrification Facility, the Pretreatment Facility (PTF),  
7 the Analytical Laboratory (Lab), the Direct-Feed Low-Activity Waste (DFLAW) Effluent Management  
8 Facility (EMF), and the Balance of Facilities (BOF).

9 The WTP manages mixed and dangerous wastes using tank systems, containment buildings, container  
10 storage areas, containment miscellaneous units, and miscellaneous unit systems. The floors and lower  
11 portions of the black cells and hot cell walls are lined with stainless steel for secondary containment.  
12 Black cells and hot cells are equipped with an instrumented sump or sumps for leak detection. Liquids are  
13 removed from the black cell sumps by steam ejectors.

14 The WTP uses three separate waste process system configurations during mixed waste treatment  
15 operations. These configurations are the Baseline configuration, the DFLAW configuration, and the  
16 Direct-Feed High-Level Waste (DFHLW) configuration.

17 Baseline Configuration

18 In the Baseline configuration, characterized LAW and HLW are sent directly from the Hanford Tank  
19 Farms to the PTF. The mixed waste is pretreated in the PTF and sent to either the HLW Vitrification  
20 Facility or the LAW Vitrification Facility for processing, depending on the waste characterization.  
21 Underground waste transfer lines allow for the transfer of waste from the Hanford Tank Farms to the  
22 PTF, and to and from the LAW Vitrification Facility, HLW Vitrification Facility, Lab, and other TSD  
23 Facilities.

24 The PTF, in the Baseline configuration, uses tank systems, miscellaneous unit systems (defined in  
25 Operating Unit Group 10, Section III.10.G of this Permit), and containment buildings to prepare waste  
26 feed from the Hanford Tank Farms for vitrification.

27 The LAW Vitrification Facility uses miscellaneous treatment unit sub-systems and equipment (defined in  
28 Operating Unit Group 10, Section III.10.H and III.10.I of this Permit), tank systems, and containment  
29 miscellaneous units to vitrify LAW feed.

30 The HLW Vitrification Facility uses miscellaneous treatment unit sub-systems and equipment (defined in  
31 Operating Unit Group 10, Section III.10.J and III.10.K of this Permit), tank systems, containment  
32 buildings, and container storage areas to vitrify HLW feed.

33 A tank system and a container storage area are used at the Lab. Container storage is used in the BOF for  
34 waste management activities.

35 Direct-Feed Low-Activity Waste Configuration

36 In the DFLAW configuration, treated LAW from the Tank Operations Contractor (TOC) is transferred to  
37 the LAW Vitrification Facility via an underground waste transfer line. The DFLAW configuration  
38 consists of the EMF, which includes the DFLAW EMF Process System (DEP), a dedicated ventilation  
39 system, and dedicated utilities, and underground waste transfer lines that allow for the transfer of waste to  
40 and from the TOC, Lab, and other TSD Facilities. The DFLAW configuration is independent of the  
41 Baseline configuration, and is only used prior to PTF startup and in the event of a prolonged PTF outage.

1 Direct-Feed High-Level Waste Configuration

2 In the DFHLW configuration, treated HLW from the TOC is transferred directly to the HLW Vitrification  
3 Facility via waste transfer lines. The DFHLW configuration also includes a dedicated ventilation system,  
4 dedicated utilities, and underground waste transfer lines that allow for the transfer of waste to and from  
5 the TOC, Lab, and other TSD Facilities. Additional facilities and infrastructure outside of the WTP to  
6 support the direct feed of tank waste and return of effluents generated during the HLW vitrification  
7 process are planned but remain under development per milestones detailed in the Sixth Amended Consent  
8 Decree, State of Washington v. Dept. of Energy (Case 2:08-CV-5085-RMP [E.D. WA January 8, 2025]).

9 Waste Management

10 Waste management activities are discussed in the following sections and in Chapter 4D for the PTF,  
11 Chapter 4E for the LAW Vitrification Facility, Chapter 4F for the HLW Vitrification Facility, Chapter 4G  
12 for the EMF, Chapter 4H for the Lab, and Chapter 4I for the BOF.

13 Integrated Control Network

14 WTP operates an Integrated Control Network (ICN). The ICN provides a real-time control and data  
15 acquisition system platform responsible for the operation and control, and alarm management, of WTP  
16 processes during normal operating conditions. The ICN integrates the WTP control systems, such as the  
17 Process Control System (PCJ), the Mechanical Handling Control System (MHJ), and the Autosampling  
18 Control System (ASJ). The ICN includes network hardware devices (switches and routers), linking  
19 devices, computer servers, operating consoles and workstations, local operator interfaces, panels,  
20 enclosures, and an operating system software platform.

21 The WTP control systems serve as the controller logic that generate control outputs to the WTP  
22 processes, including mechanical handling, autosampling, and ventilation. The control systems conduct  
23 various functions, including:

- 24 • Monitoring and/or controlling the electrical services.
- 25 • Monitoring environmental and stack discharge equipment.
- 26 • Controlling non-safety services and utilities.

27 The control systems send data to the ICN where it is passed to the plant information network. The plant  
28 information network is a network designed to store plant operating system data and information  
29 applicable to the WTP Dangerous Waste Permit (DWP). The following are examples of the plant  
30 information network capabilities:

- 31 • Capture and store information related to WTP DWP sample requests, sample statuses, and sample  
32 results.
- 33 • Capture and store information related to the tracking of dangerous/mixed waste containers  
34 throughout the facilities, from point of generation to off-site shipment; including containers  
35 located in permitted container storage areas, containment miscellaneous units, central  
36 accumulation areas, and satellite accumulation areas.

37 More information on the ICN and plant information network will be provided prior to the initial receipt of  
38 dangerous and/or mixed waste, as required in WTP DWP Permit Condition III.10.D.10.c.v.

39 **4.1.1 Process Overview**

40 In the DFLAW and DFHLW configurations, waste from the Hanford TOC is processed to meet  
41 contractual requirements for transfer of waste directly to the LAW Vitrification Facility and the HLW  
42 Vitrification Facility, respectively. After sampling the waste stream, and confirmation by the WTP that it  
43 meets the waste acceptance criteria for the waste type, LAW or HLW, the waste is then transferred to the  
44 appropriate treatment facility. In the DFLAW configuration, waste from the TOC is pumped via

1 underground waste lines directly to the LAW Vitrification Facility. In the DFHLW configuration, waste is  
2 transferred from the TOC to the HLW Vitrification Facility via underground waste transfer lines.

3 In the Baseline configuration, the WTP will store and treat waste feed from the Hanford Tank Farms in  
4 the PTF. The PTF will separate the waste into two feed streams for the LAW and HLW Vitrification  
5 facilities. Feed from the Hanford Tank Farms is expected to be of four major waste feed types, referred to  
6 as waste feed Envelopes A, B, C, and D. For the DFLAW configuration, waste feed will come from waste  
7 feed Envelope E. These waste feed envelopes are described as follows:

- 8 • **Envelope A.** This waste feed envelope will contain cesium at concentrations high enough to  
9 warrant removal of these radionuclides during pretreatment, to ensure that the Immobilized  
10 Low-Activity Waste (ILAW) glass will meet applicable requirements.
- 11 • **Envelope B.** This waste feed envelope will contain higher concentrations of cesium than  
12 Envelope A. Cesium must be removed to comply with the ILAW specifications. This envelope  
13 may also contain concentrations of chlorine, chromium, fluorine, phosphates, and sulfates that are  
14 higher than those found in Envelope A, which may limit the waste incorporation rate into the  
15 glass.
- 16 • **Envelope C.** This waste feed envelope will contain organic compounds containing complexed  
17 strontium and transuranics (TRU) that will require removal in a processing step unique to this  
18 waste envelope. As with Envelopes A and B, cesium will also require removal in the pretreatment  
19 process to ensure that ILAW glass meets applicable requirements.
- 20 • **Envelope D.** HLW feed will be in the form of a slurry containing approximately 10 to 200 grams  
21 of unwashed solids per liter. The liquid fraction of the slurry will be separated from the solids and  
22 classified as Envelope A, B, or C waste. The solid fraction will be Envelope D waste.
- 23 • **Envelope E.** Direct feed from LAW Pretreatment System, with a nominal sodium concentration  
24 of 5 to 8 molar.

25 A new waste feed envelope will be established for the DFHLW configuration. Treatment assumptions and  
26 capabilities for this new envelope will be within those for the envelopes defined above.

27 The WTP treatment processes are designed to immobilize the waste constituents in a glass matrix by  
28 vitrification and to treat the offgas from the processes to a level that protects human health and the  
29 environment.

30 Secondary waste streams (e.g., dangerous and/or mixed waste) are characterized and recycled into the  
31 treatment process, transported to permitted TSD facilities located on the Hanford Site, or transported  
32 off-site, as appropriate.

33 Nonradioactive dangerous waste is also generated by laboratory and maintenance activities. This waste is  
34 managed at the WTP until it can be transferred to an off-site TSD unit. There are six primary components  
35 of the WTP: PTF, LAW Vitrification Facility, HLW Vitrification Facility, EMF, the Lab, and the  
36 supporting BOF systems and utilities. The following discussion presents an overview of these waste  
37 treatment processes and BOF systems at the WTP. Figure 4A-1 in Chapter 4A presents a simplified  
38 process flow diagram of the WTP treatment processes.

### 39 Pretreatment

40 In the Baseline configuration, waste feed is stored and subsequently treated in the PTF prior to  
41 vitrification. The processes in the PTF condition the waste feed and removes cesium, strontium, TRU  
42 compounds, and entrained solids from the LAW fraction. The waste feed is also processed through  
43 ultrafiltration to separate the solids.

1 There are four types of waste management units in the PTF:

- 2 • Container storage areas.
- 3 • Tank systems.
- 4 • Containment buildings.
- 5 • Miscellaneous unit systems.

6 The structure of the PTF is supported by a reinforced concrete foundation. The superstructure is made of  
7 structural steelwork with a metal roof. Typically, the process cells within the PTF are constructed of  
8 reinforced concrete. Secondary containment is provided as required for tank systems and miscellaneous  
9 unit systems managing dangerous or mixed waste. Secondary containment consists of either stainless  
10 steel liners or special protective coatings. Table 4D-3 in Chapter 4D provides information on secondary  
11 containment. Figure 4A-2 and 4A-2A in Chapter 4A present simplified process flow diagrams of the  
12 pretreatment processes.

### 13 Low-Activity Waste Vitrification Facility

14 The LAW Vitrification Facility houses the vitrification systems for production of the ILAW. Three types  
15 of waste management units are located in the LAW Vitrification Facility, as follows:

- 16 • Containment miscellaneous units.
- 17 • Tank systems.
- 18 • Miscellaneous treatment unit sub-systems and equipment.

19 The LAW Vitrification Facility is constructed of reinforced concrete and structural steelwork. The  
20 below-grade portion of the building structure is made of reinforced concrete, and the superstructure is  
21 made of reinforced concrete and structural steelwork with a metal roof. The LAW Vitrification Facility  
22 structure is supported by a reinforced concrete mat foundation.

23 Secondary containment is provided as required for tank systems and miscellaneous unit sub-systems and  
24 equipment managing dangerous or mixed waste. Secondary containment consists of either stainless steel  
25 liners or protective coatings. Table 4E-4 in Chapter 4E provides information on secondary containment.  
26 Figure 4A-3 in Chapter 4A presents a simplified process flow diagram of the LAW Vitrification Facility  
27 treatment processes.

### 28 High-Level Waste Vitrification Facility

29 The HLW Vitrification Facility houses the vitrification systems for producing Immobilized High-Level  
30 Waste (IHLW). Four types of waste management units are located in the HLW Vitrification Facility, as  
31 follows:

- 32 • Container storage areas.
- 33 • Tank systems.
- 34 • Containment buildings.
- 35 • Miscellaneous treatment sub-systems and equipment.

36 The HLW Vitrification Facility is constructed of reinforced concrete and structural steelwork. The lower  
37 elevations of the building structure are reinforced concrete construction, and the upper elevations made of  
38 structural steelwork with a metal roof. The HLW Vitrification Facility structure is supported by a  
39 reinforced concrete mat foundation. Secondary containment is provided as required for tank systems and  
40 miscellaneous unit sub-systems and equipment managing dangerous or mixed waste. Secondary  
41 containment consists of either stainless steel liner or protective coating. Table 4F-3 in Chapter 4F  
42 provides information on secondary containment. Figure 4A-4 in Chapter 4A presents a simplified process  
43 flow diagram of the HLW Vitrification Facility treatment processes.

## 1 Direct-Feed Low-Activity Waste Effluent Management Facility

2 The EMF consists of four primary buildings: the LAW Effluent Process Building, the LAW Effluent  
3 Drain Tank Building, the LAW Effluent Electrical Building, and the LAW Effluent Utility Building. The  
4 EMF contains an evaporator system, nine major process vessels, two supporting reagent product storage  
5 tanks, Heating, Ventilation, and Air Conditioning (HVAC) equipment, and electrical utilities. The  
6 buildings are constructed of reinforced concrete and structural steelwork with a metal roof. The EMF  
7 structures are supported by a reinforced concrete mat foundation.

8 The EMF is designed with a minimum of a 48-hour effluent storage capacity, and includes underground  
9 waste transfer lines to transfer waste to and from the LAW Vitrification Facility, Lab, and other TSD  
10 Facilities. Secondary wastes generated by the EMF are managed as described in Chapter 4G.1.

11 There are two types of waste management units in the EMF:

- 12 • Tank systems.
- 13 • Miscellaneous unit systems.

14 Secondary containment is provided as required for tank systems managing dangerous or mixed waste.  
15 Secondary containment consists of either stainless steel liner or protective coating. Table 4G-3 in  
16 Chapter 4G provides information on secondary containment.

## 17 Analytical Laboratory

18 The Lab houses the hot cells, laboratories, and systems for analyzing process samples and managing  
19 regulatory compliance samples. Two types of waste management units are located in the Lab:

- 20 • Container storage areas.
- 21 • Tank systems.

22 The Lab is constructed of reinforced concrete, structural steelwork, and a metal roof. The below-grade  
23 portions of the building structure are constructed of reinforced concrete. The Lab structure is supported by  
24 a reinforced concrete mat foundation. Secondary containment is provided as required for tank systems  
25 managing dangerous or mixed waste. Secondary containment consists of either stainless steel liner or  
26 protective coating. Table 4H-2 in Chapter 4H provides information on secondary containment.

## 27 Balance of Facilities

28 The BOF includes support systems and utilities required for the waste treatment processes within the  
29 PTF, LAW Vitrification Facility, HLW Vitrification Facility, EMF, and the Lab. BOF support systems  
30 and utilities include, but are not limited to, heating and cooling, process steam, process water, chilled  
31 water, primary and secondary power supplies, and compressed air. The BOF also includes the Glass  
32 Former Reagent system (GFR) that supplies glass former reagents to the LAW and HLW Vitrification  
33 facilities. Regulated waste management units within the BOF include:

- 34 • HLW Failed Melter Storage Facility.
- 35 • WTP Waste Storage Area.
- 36 • Transportation Staging Area.

## 37 **4.2 Tank Systems**

38 This section contains descriptive information for each tank system used for managing mixed waste. The  
39 term “tank systems” refers to mixed waste storage or treatment tanks, including primary containment  
40 sumps, and their associated ancillary equipment and containment systems. Figures and permit drawings  
41 depicting design features of tank systems are found in DWP Operating Unit Group 10.

1 The following text uses the terms “vessel” and “tank.” The term “vessel” is an engineering term and  
2 denotes more robust construction than a typical mixed waste storage or treatment tank. The term “vessel”  
3 is included due to the use of the term in the American Society of Mechanical Engineers (ASME) codes  
4 and specifications that are followed for most tank construction at the WTP.

#### 5 **4.2.1 Design, Installation, and Assessment of Tank Systems**

6 This section describes the attributes of tank systems containing mixed waste. Tanks and ancillary  
7 equipment containing only additives or reagents, such as glass forming chemicals, precipitation reagents,  
8 or unused resin, are not regulated under the Resource Conservation and Recovery Act (RCRA) or the  
9 Washington State Dangerous Waste Program and are therefore not included.

10 Tank systems containing mixed waste are designed to comply with worst-case scenarios, such as extreme  
11 pH, temperature, and pressure conditions. The WTP is entirely new construction, and there are no  
12 “existing tanks” in the plant.

13 Tank systems, with the exception of the two outside tanks at the PTF and the eight outside vessels at the  
14 EMF, are located indoors and within process cells, process rooms, or caves with controlled access.

##### 15 **4.2.1.1 Design Requirements**

###### 16 Tanks

17 The mixed waste tanks at the WTP are designed, at a minimum, to *Boiler and Pressure Vessel Code*  
18 (ASME 2000), the American Petroleum Institute (API) codes, or other appropriate design codes and will  
19 be operated under atmospheric pressure conditions. Tank integrity is reinforced by additional  
20 requirements of the tank group and seismic category assignment to each tank.

21 The vessels are designed for seismic loading in accordance with the Uniform Building Code (UBC) or  
22 International Building Code (IBC) standard for Zone 2B (UBC 1997 or IBC 2021).

23 The codes and standards that are followed for design, construction, and inspection for the tanks are  
24 identified below, as applicable:

- 25 • ANSI American National Standards Institute.
- 26 • API American Petroleum Institute.
- 27 • ASME American Society of Mechanical Engineers.
- 28 • ASNT American Society of Non-Destructive Testing.
- 29 • ASTM ASTM International.
- 30 • NACE National Association of Corrosion Engineers.
- 31 • NBBPVI The National Board of Boilers and Pressure Vessel Inspectors.
- 32 • OSHA Occupational Safety and Health Administration.
- 33 • PFI Pipe Fabrication Institute.
- 34 • UBC Uniform Building Code.
- 35 • IBC International Building Code.

###### 36 Piping and Pipe Support Design

37 The design code of the WTP piping and pipe supports is ASME B31.3 Code (ASME 1996), as well as the  
38 United States Department of Energy (DOE) seismic requirements. In compliance with DOE seismic  
39 requirements (DOE 1996), response spectrum method, or UBC (UBC 1997) static method is used for the  
40 seismic analysis of the piping systems.

1 **4.2.1.2 Physical Information for Tanks**

2 Tables in Chapters 4D, 4E, 4F, 4G, and 4H list current tank design information (capacity, materials of  
3 construction, and dimensions). The tank systems are grouped by plant and process system.

4 Tank operation is generally automated. However, operator intervention can be used when human  
5 decisions or approval are required for initiation and termination of a process operation. Descriptions of  
6 tank system operation for major WTP process systems are identified in Chapters 4D, 4E, 4F, 4G, and 4H.

7 **4.2.2 Ancillary Equipment Requirements**

8 Information concerning ancillary equipment is provided in the following subsections.

9 **4.2.2.1 Transfer or Pressure Control Devices**

10 Several fluid transfer devices are used in the WTP. These devices include mechanical pumps, reverse  
11 flow diverters, and steam ejectors. Breakpots and seal pots, although not fluid transfer devices, are an  
12 important component of vessel operations. These components are discussed in the following sections.

13 Mechanical Pumps

14 Mechanical pumps are used for operations that require high-flow pumps (such as through the evaporator  
15 circuits) or high-pressure head pumps (such as for pumping a waste stream through ultrafiltration  
16 circuits). Mechanical pumps are located in process cells, process rooms, or caves. In general, mechanical  
17 pumps are repaired in place or removed to a maintenance area. However, remotely maintained pumps are  
18 used in areas where maintenance activities would result in a significant radiation dose to the operators.

19 For normal process operating sequences, mechanical pumps and associated valves are controlled by the  
20 process control system. In systems where off-normal conditions require pump shutdown, the design  
21 includes an alarm mechanism that also trips the transfer device. The pump system is designed to allow for  
22 the drainage of liquid from the pump, and for the introduction of flush liquids at the end of transfers to  
23 reduce residual contamination.

24 Reverse Flow Diverters

25 Reverse flow diverters provide for the maintenance-free pulsed or metered transfer of liquids or slurries  
26 throughout the treatment process. A reverse flow diverter does not need to be fully submerged in order to  
27 remove the contents of a vessel, and it maintains a small and predictable volume of tank contents  
28 following its use. Operation of the reverse flow diverter is cyclical, following timed phases: suction  
29 phase, drive phase, and blowdown. The following paragraphs describe a typical reverse flow diverter  
30 system arrangement.

31 **Suction phase:** In the suction phase, the secondary automatic valve A is open, admitting air to the suction  
32 jet pump. Valve B is shut and liquid is drawn from the supply tank through the reverse flow diverter and  
33 into the charge vessel. The suction ejector is designed so that it cannot produce a vacuum capable of  
34 lifting liquid higher than a certain valve known as the “suction lift.” After a short time, the liquid reaches  
35 this “suction lift” height and stops, then valve A is shut.

36 **Drive phase:** When valve A is shut, valve B is opened, admitting air to the drive nozzle. Air passes  
37 through the nozzle and pressurizes the charge vessel. Liquid is forced across the reverse flow diverter and  
38 into the delivery pipe. The delivery pipe is quickly filled with liquid that flows into the delivery vessel.

39 **Blowdown phase:** When the charge vessel is nearly empty, valve B is shut; no air is supplied to either jet  
40 pump. The compressed air in the charge vessel passes back through the paired jet pumps, down the vent  
41 pipe, and into vessel vent system.

42 Shortly after blowdown begins, the pressure in the charge vessel falls below the delivery head, and the  
43 flow of liquid into the delivery vessel is halted.

1 The liquid in the delivery vessel then falls back down the pipe, across the reverse flow diverter, and into  
2 the charge vessel. After a short time, the pressure in the charge vessel falls to zero (gauge). The cycle is  
3 now complete.

#### 4 Steam Ejectors

5 Steam ejectors are used to transfer process liquids, or to reduce the operating pressure of a system by gas  
6 removal. They empty liquid from vessels by means of suction lift, using a simple control system.

7 An automated control valve supplies high-pressure steam to the steam ejector. This steam accelerates  
8 through a nozzle, creating a differential pressure along a submerged suction leg within the vessel. The  
9 pressure then forces the liquid up the suction pipe. This effect is known as striking. The steam then  
10 conveys the liquid to the destination vessel, normally via a breakpot. Control is established using liquid  
11 level instrumentation in the vessel being emptied, and using a temperature indicator, such as a  
12 thermocouple, within the breakpot.

#### 13 Seal Pots

14 A seal pot is a type of hydraulic seal. A hydraulic seal is used primarily to maintain a separation between  
15 vessel vent or offgas systems for feed and receipt vessels. This separation is necessary to prevent  
16 migration of airborne contamination between the vessels. Without the seal, airflow could occur due to the  
17 different pressures in the vent systems. The seal is a slug of liquid in the interconnecting pipe work that  
18 remains after each liquid transfer is completed, blocking airflow between vessels.

19 The seal can be provided by constructing a simple “U” shape in the piping. Different piping arrangements  
20 are used for different purposes. A seal pot is a small vessel with one (inlet or outlet) pipe submerged in  
21 the liquid slug in the lower part of the pot, while the other pipe terminates in the top of the pot, above the  
22 static liquid level. The pot may be provided with a level indicator or alarm, if necessary, to ensure  
23 adequate liquid level. Periodic liquid additions may be needed to maintain the seal, especially if the  
24 pipeline is infrequently used.

#### 25 Breakpots

26 The main function of the breakpot is to reduce the amount of mixed waste material entrained into the  
27 vessel ventilation system. Breakpots are provided on transfer lines that use steam ejectors for moving  
28 liquids by pressure flow. These types of transfers create the potential for air entrainment of mixed waste  
29 contamination. Breakpots function to convert steam from pressure flow to liquid gravity flow, thereby  
30 reducing both the effluent loading on the downstream vessel ventilation treatment system and the mixed  
31 waste contamination levels in the vessel vent ductwork. Breakpots also serve a secondary purpose by  
32 providing a siphon break for other transfer systems where siphoning could occur.

33 Breakpots are typically placed at a high point in the discharge line from the steam ejector. Liquid is  
34 pumped into the breakpot through an inlet nozzle in its wall. The incoming liquid is directed towards a  
35 baffle. Within the baffle, noncondensed steam and gases disengage. The breakpot is self-draining; the  
36 liquid drains through the breakpot discharge pipe to the destination vessel.

37 A packed bed where disentrainment of the gas stream occurs is located above the inlet nozzle(s). The  
38 exiting gas from the packed section passes into the vessel ventilation system. The packed bed can be  
39 washed periodically using a wash ring permanently installed above the packed bed.

#### 40 **4.2.2.2 Bulges**

41 Bulges allow hands-on maintenance of equipment after process fluids are flushed from the bulge piping  
42 and components. Bulges provide shielding to personnel during process operation and allow vulnerable or  
43 failure prone components to be located outside the process environment. The cell wall provides shielding  
44 between the cell and the bulge interior. The bulge includes shielding and contamination control as needed,  
45 depending on the process fluid within the bulge piping.

1 A typical bulge consists of a metal frame attached to the outside wall of a process cell; the frame is used  
2 to support the piping and components as well as the shielding plates (usually steel), which are bolted to  
3 the frame. Bulges provide secondary containment for DWP ancillary equipment inside the bulge.

4 The ancillary equipment located inside the bulges are provided with leak detection or the bulge is  
5 provided with a drain line that flows to a sump equipped with leak detection. Leak detection can be  
6 provided internal to the bulge or in the sump associated with bulge drain line.

7 There are two classifications of bulges used at the WTP. One is a “process” bulge; the other is a “service”  
8 bulge. The process bulge contains valves, pumps, piping, etc. The service bulge contains valves used to  
9 transfer reagents, steam, etc., to the in-cell process equipment. The design of the two bulges is similar.

10 Bulges are equipped with several wash systems, facilitating washing both internal and external piping,  
11 components, and bulge confinement surfaces. Decontamination of the equipment internals and associated  
12 piping is achieved by externally connecting a flushing system located on the outside of the bulge. Wash  
13 fluids could be water or more aggressive media such as nitric acid, provided compatibility with the bulge  
14 materials is ensured. Internal bulge wash fluid is routed via a floor drain through a gravity drain line to a  
15 secondary sump. During the wash, sump level and alarms are monitored. Upon completion of the wash,  
16 the sump is returned to its normally dry condition.

17 Additional information on process bulges may be found in Chapter 4A, Figure 4A-127.

### 18 **4.2.2.3 Description of Waste Treatment Plant Piping System**

#### 19 Interplant Piping Transfer Lines

20 In all three configurations –Baseline, DFLAW, and DFHLW – waste feed from the Hanford TOC is  
21 transported to the WTP via underground waste transfer lines.

22 The waste feed transfer lines are double-walled pipe. The inner pipe is constructed of stainless steel, while  
23 the outer secondary containment pipe is constructed of carbon steel. The carbon steel outer pipe is coated  
24 with a fusion bonded epoxy (FBE) coating. In addition, the coated outer pipe for the waste transfer lines  
25 are surrounded by an injected closed-cell polyurethane foam insulation and a high-density polyethylene  
26 outer jacket. This extra layer of protective material isolates the waste transfer lines from soil.

27 The inner pipe is supported by guides, saddles, support keys, or anchors within the outer pipe. The inner  
28 pipe transports waste and maintains the pressure boundary, while the outer pipe provides secondary  
29 containment for the inner pipe. The piping system is buried under a minimum depth of soil for radiation  
30 shielding. The minimum depth of soil was finalized at the detail design phase and will not be less than the  
31 2 feet (ft) freeze depth. A heat trace system is not required for pipes buried below freeze depth.

32 In the Baseline configuration, the waste transfer lines between the PTF and the other WTP process plants  
33 do not have this extra barrier from the soil, but are cathodically protected as described later in this section.  
34 In the DFLAW configuration, the new effluent or process waste transfer lines between the TOC and the  
35 EMF, starting at the DOE interface point at the WTP property boundary and ending at the LAW, and  
36 from the EMF back to the Hanford Tank Farms ending at DOE interface point at the WTP property  
37 boundary, utilize the High Density Polyethylene (HDPE) jacketed design to isolate the transfer lines from  
38 the soil environment. Similarly, the transfer lines between the LAW and EMF, the Lab and EMF, and the  
39 EMF to the intersection of the existing transfer line between the PTF and the Liquid Effluent Retention  
40 Facility/Effluent Treatment Facility (LERF/ETF) interface point, utilize the HDPE jacketed design. In the  
41 DFLAW configuration, the cathodically protected intra-facility piping system between the PTF and the  
42 other WTP facilities are isolated, and not used. In the DFHLW configuration, new or existing effluent or  
43 waste transfer lines connecting the HLW Vitrification Facility to the TOC, the Lab, other TSD Facilities,  
44 are protected from the soil environment by use of cathodic protection or HDPE jackets.

45 A leak detection system is provided for each of the underground waste transfer lines. A leak detection  
46 alarm sends a signal to stop waste transfer pumps and terminate the transfer of waste feed.

1 The underground piping system has a continuous slope down toward the PTF from the Hanford Tank  
2 Farms in the Baseline configuration. In the DFLAW configuration all transfer lines slope to Leak  
3 Detection Boxes (LDBs) located in the LAW Effluent Drain Tank Building. The exception is the  
4 LERF/ETF transfer line LDBs which are located at the LERF/ETF interface point on the WTP property  
5 line. Any released liquids resulting from leaks to the outer pipe will be removed as required by the  
6 Washington Administrative Code (WAC) 173-303-640(4)(b). The piping system is designed to allow line  
7 flushing to occur.

#### 8 Liquid Effluent Transfer Lines

9 In the Baseline configuration, liquid effluent generated at the WTP is routed to the PTF for recycling  
10 through the WTP and then transferred to the LERF/ETF for treatment and disposal.

11 To support the Baseline configuration two HDPE jacketed waste effluent lines are routed from the PTF to  
12 the LERF/ETF interface point located northwest of the EMF along the WTP property line. In the DFLAW  
13 configuration two HDPE transfer lines intersect the existing LERF/ETF transfer lines between the PTF  
14 and the interface point. In this configuration the transfer line between the PTF and the line intersection is  
15 isolated to prevent fluids from flowing to the PTF. The pipes have a continuous downwards slope towards  
16 the LERF/ETF. A leak detection system is provided for the LERF/ETF waste transfer lines at their  
17 interface point. In the DFHLW configuration liquid effluent transfer lines will be designed to transfer  
18 HLW vitrification effluents from the HLW Facility back to Tank Farms for disposition.

#### 19 Intraplant Piping

20 Pipelines within the plants, associated with the tank systems located in process cells, black cells, bulges  
21 and pipe and pump pits, are typically single-walled pipelines. Secondary containment is provided by  
22 partially lined process cells, process rooms, or caves; and is provided by pump and pipe pits, melter  
23 encasement assembly areas, and bulges or concrete ducts with liners at appropriate locations. The bulge  
24 or concrete ducts are provided with a low point which drains to process cells, process rooms, or caves.  
25 The leak detection equipment located within the process cells, process rooms, and caves provides warning  
26 of a piping leak through leak detection alarms.

27 Piping between plants and the two outdoor tanks at the PTF, and the eight EMF outdoor vessels, are  
28 double-walled, FBE-coated, insulated, HDPE-jacketed lines. The majority of the transfer lines are located  
29 below grade, and below the freeze line. The above ground segment of the lines to the associated vessels  
30 are insulated and heat traced to prevent freezing.

#### 31 Cathodic Protection

32 An impressed current cathodic protection system is used in the Baseline configuration for eliminating or  
33 mitigating corrosion on underground piping. The cathodic protection system maintains a negative pipe to  
34 soil potential on the protected pipe relative to a saturated copper/copper sulfate reference electrode.

35 The impressed current cathodic protection system uses direct current provided by a rectifier that is  
36 powered from the plant's normal 480 VAC power system. The direct current from the rectifier is  
37 connected across the buried anode wire and the protected pipe. The current flows from the anode wire,  
38 which is positive, through the electrolyte, to the protected pipe, which is negative, and back to the rectifier  
39 completing the electrical circuit.

40 An annual survey, recommended by NACE International (formerly the National Association of Corrosion  
41 Engineers), is performed on the system provided with cathodic protection. Test stations are provided to  
42 permit potential measurements. Additional information on inspections is provided in Operating Unit  
43 Group 10, Chapter 6A.

## 1 Corrosion Protection

2 The following WTP waste transfer and effluent transfer lines that utilize FBE, thermal insulation, and an  
3 HPDE jacket, are isolated from soil moisture with an external water resistant barrier to provide corrosion  
4 protection:

- 5 • DOE waste feed pipelines from the Hanford Tank Farm interface point to the PTF.
- 6 • Radioactive/dangerous waste effluent transfer lines from the PTF to the LERF/ETF interface  
7 point.
- 8 • Mixed waste transfer lines from the TOC to the EMF starting at the WTP property boundary and  
9 ending at the LAW Vitrification Facility.
- 10 • Mixed waste transfer lines from the EMF back to the Hanford Tank Farms beginning at EMF and  
11 ending at the WTP property boundary.
- 12 • Mixed waste transfer lines from the LAW Vitrification Facility to the EMF.
- 13 • Mixed waste transfer lines from the Lab to the EMF.
- 14 • Mixed waste transfer lines from the EMF to an intersection point on the existing transfer line  
15 from the PTF to the LERF/ETF interface point at the WTP property boundary.

16 The incoming TOC waste feed pipelines that interface with the WTP pipelines are intentionally not  
17 cathodically protected. Consistent with the existing Hanford Tank Farm waste transfer design, transfer  
18 lines from the WTP boundary, the Waste Feed Receipt Process (FRP) transfer lines and the LERF/ETF  
19 effluent coaxial transfer lines are furnished with additional corrosion protection by the addition of an  
20 external water resistant barrier. This barrier isolates the lines from moisture in the surrounding soils and  
21 provides corrosion protection in lieu of cathodic protection.

22 The barrier consists of a 2-inch layer of sprayed or injected closed-cell polyurethane foam with an  
23 external jacket of extruded HDPE jacket with a minimum thickness of 140 mils. This barrier is located  
24 over the fusion bonded epoxy coated carbon steel outer encasement pipe which provides secondary  
25 containment for the inner stainless steel process line.

26 The incoming waste transfer lines are also bonded at the crossing of the plant service air piping between  
27 the PTF and the HLW Vitrification Facility on the opposite end (which is cathodically protected piping).  
28 This area is defined as the “zone of influence.” Bonding is provided to minimize stray electrical currents  
29 that may occur in the zone of influence.

### 30 **4.2.3 Integrity Assessments**

31 Periodic integrity assessments are conducted on the WTP tank and miscellaneous treatment systems per  
32 the integrity assessment program and schedule in the DWP Operating Unit Group 10, Chapter 6A. Results  
33 of the integrity assessments will be included in the WTP Unit operating record until ten (10) years after  
34 post-closure, or corrective action is complete and certified, whichever is later. Written assessments of the  
35 adequacy of the design of tank systems and miscellaneous treatment systems are prepared on a  
36 system-by-system basis. Separate reports are prepared for tanks, tank system ancillary equipment, and  
37 associated secondary containment systems. Each assessment is reviewed and certified by an independent,  
38 qualified, registered professional engineer to attest that the tank and miscellaneous treatment systems are  
39 adequately designed for managing dangerous waste. Each assessment includes an evaluation of the  
40 foundation, structural support, seams, connections, pressure controls, compatibility of the waste with the  
41 materials of construction, and corrosion controls for each mixed waste management system, as  
42 appropriate. Integrity assessment reports are located in DWP Operating Unit Group 10, Appendix 7.5:  
43 “Civil, Structural, and Architectural Criteria and Typical Design Details,” Appendix 8.11 for the PTF,  
44 Appendix 9.11 for the LAW Vitrification Facility, Appendix 10.11 for the HLW Vitrification Facility,  
45 Appendix 11.11 for the Lab, and Appendix 13.11 for the EMF.

1 **4.2.4 Additional Requirements for Existing Tanks**

2 Tanks and vessels that are permitted in the WTP are newly constructed; pre-existing tanks will not be  
3 used. Therefore, the requirements of this section do not apply.

4 **4.2.5 Additional Requirements for New Tanks**

5 Tank system installation is performed in a manner designed to prevent damage to the tank system. The  
6 WTP uses an independent, qualified installation inspector, or an independent qualified registered  
7 professional engineer to perform tank system installation inspections, in accordance with WAC 173-303-  
8 810(13)(a). Inspection activities include testing tanks for tightness, verifying protection of ancillary  
9 equipment against physical damage and stress, and evaluating evidence of corrosion. The inspections  
10 document weld breaks, punctures, coating scrapes, cracks, corrosion, and other structural defects.  
11 Installation inspections conform to permit requirements and consensus-recognized standards. Inspection  
12 findings and corrective actions, as appropriate, are documented in post-inspection reports.

13 **4.2.5.1 Additional Requirements for New Above-Ground Tanks**

14 The majority of the tanks and vessels to be constructed in the WTP are located within the PTF, the Lab,  
15 the LAW Vitrification Facility, and the HLW Vitrification Facility. Therefore, the requirements of this  
16 section do not apply to the indoor tanks.

17 The two outdoor Process Condensate Tanks located at the PTF (RLD-TK-00006A/B), and the eight  
18 outdoor vessels at the EMF (DEP-VSL-00002, DEP-VSL-00003A/3B/3C, DEP-VSL-00004A/4B, and  
19 DEP-VSL-00005A/5B), are located within a bermed and lined secondary containment system and are not  
20 in direct contact with soil. The design of the outdoor tanks' concrete pad addresses backfill, soil  
21 saturation, seismic forces, and freeze thaw effects. A portion of the ancillary piping for the unit is in  
22 contact with the soil, and the effects of corrosion on the piping are addressed in the final design.

23 **4.2.5.2 Secondary Containment System Requirements**

24 Most of the tank systems containing mixed waste are located within the plants, although two tanks are  
25 located outside the PTF, and eight vessels are located outside of the EMF. Tank systems containing  
26 mixed waste that are located within the plants are arranged within process cells, process rooms, caves, or  
27 other areas provided with secondary containment liners or coatings. The outside tanks and vessels are  
28 located on a bermed, concrete pad, provided with special protective coatings and covings or waterstops,  
29 or provided with stainless steel liners that provide secondary containment.

30 The secondary containment systems are designed, installed, and operated to prevent migration of waste or  
31 accumulated liquid to soil, groundwater, or surface water. The piping associated with the tank systems are  
32 located in the process cells, process rooms, caves, berms, or bulges. Secondary containment for piping  
33 systems is incorporated into the design.

34 Tank systems and wet miscellaneous treatment systems are provided with secondary containment that can  
35 contain 100 percent of the volume from the largest tank within the containment area. In the PTF, the  
36 15 black cells and the hot cell at the 0' (ft) elevation are interconnected through hydraulic connections  
37 (open penetrations that interconnect adjacent cells) such that the combined secondary containment  
38 volume is available, if necessary, to contain a 100 percent leak from the largest tank. A leak to the hot cell  
39 floor, if large enough, drains to the overflow vessels in the pit at -45' (ft) elevation and ultimately to  
40 the -45' (ft) pit secondary containment if the volume of the overflow vessel(s) is exceeded. Secondary  
41 containment areas lined with stainless steel have a gradient (minimum 1 percent) designed to channel  
42 fluids to a sump. In some cases, there may be more than a single sump. For example, the hot cell in the  
43 PTF has three instrumented sumps for leak detection. Fire suppression water is included as appropriate in  
44 determining the height of the secondary containment. Table 4D-3 in Chapter 4D, Table 4E-4 in Chapter  
45 4E, Table 4F-3 in Chapter 4F, Table 4G-3 in Chapter 4G, and Table 4H-2 in Chapter 4H summarize the

1 calculated minimum liner height at the four process plants and the Lab. The flooding volume documents  
2 identified above present the secondary containment height for each plant.

3 A concrete berm with protective coatings or stainless liners is used for the PTF and EMF outdoor tanks  
4 and vessels. These secondary containment areas are capable of holding 100 percent of the volume from  
5 the largest tank within the berm, plus the precipitation from a 25-year, 24-hour rainfall event, as required  
6 under WAC 173-303-640(4)(e)(i)(B).

7 The WTP uses selected industry standards to ensure secondary containment systems have sufficient  
8 strength, thickness, and compatibility with waste. The design includes an engineered structural base to  
9 protect against failure resulting both from excess force applied during catastrophic events or settlement,  
10 and from the stress of daily operation.

11 In the event of a spill or release, the secondary containment design prevents released mixed waste from  
12 reaching the environment, and safely contains the waste until it can be transferred to an appropriate  
13 collection tank.

14 The following subsections provide detailed descriptions of typical secondary containment systems that are  
15 used at the WTP.

### 16 Process Cells

17 Process cells are located within process plants. Process cells are typically constructed of concrete walls to  
18 protect plant operators and the environment from radiological exposure and to prevent migration of waste  
19 or accumulated liquid to soil, groundwater, or surface water. Operator access to the process cells is not  
20 allowed during normal operations. However, access is allowed for certain areas within WTP for  
21 nonroutine operations such as equipment replacement or maintenance. Process cells are provided with  
22 liners and special protective coatings as required. Systems within process cells that manage mixed waste  
23 have secondary containment (for example, process vessels and piping).

### 24 Black Cells

25 A black cell is a type of process cell that may contain vessels, evaporators, and piping systems that are  
26 used to support process waste stream storage and blending functions. No active equipment  
27 (i.e., equipment with moving parts) components are located in the black cell. The design for the vessels  
28 and piping is all welded construction. Some instrumentation (e.g., thermocouples, radiation detectors) are  
29 remotely replaceable by insertion into sealed pipe wells. The black cell vessels and design do not possess  
30 design features for remote replacement. The black cell concept is used in areas where the risk of vessel or  
31 piping failure due to corrosion or erosion is low. The PTF contains fifteen black cells and the HLW  
32 Vitrification Facility contains three black cells.

### 33 Hot Cell

34 Alternatively, a hot cell is a type of process cell that contains active equipment and periodically needs to  
35 be remotely accessed for equipment maintenance or replacement.

36 All process cells are provided with secondary containment as required. The floor is sloped to a collection  
37 sump to allow for collection and removal of accumulated liquid within the sump.

### 38 Caves

39 Caves are located within process plants. Caves typically are constructed with concrete walls thick enough  
40 to protect personnel from exposure to mixed waste. Caves house mechanical handling equipment  
41 designed for remote operation and maintenance. They generally have viewing windows and closed-circuit  
42 television to allow observation of the cave operations and for overseeing remote maintenance. The cave  
43 floors and portions of the walls are provided with secondary containment as required. The floor of the  
44 cave is sloped to a collection sump to allow for collection and removal of accumulated liquid within the  
45 sump.

1 Berms

2 Concrete berms are used at the LAW Vitrification Facility for the Caustic Collection Tank  
3 (LVP-TK-00001). The berms are of sufficient structural strength and height to contain the 100 percent of  
4 the volume of the largest tank.

5 Vault-like structures are used for the two outdoor Process Condensate Tanks (RLD-TK-00006A/B) at the  
6 PTF, and the eight outdoor vessels at EMF (DEP-VSL-00002, DEP-VSL-00003A/B/C,  
7 DEP-VSL-00004A/B, and DEP-VSL-00005A/B). These vault-like structures are of sufficient structural  
8 strength and height to contain 100 percent of the volume of the largest tank plus, for the outdoor Process  
9 Condensate Tanks, the amount of precipitation that results from the 24-hour, 25-year storm event.

10 A protective coating is applied to the concrete pad and a portion of the berms and vault-like structures to  
11 prevent contaminant penetration into the concrete. The containment system is designed to allow for the  
12 discharge of storm water after visual or other testing.

13 Drip Pan

14 The ancillary equipment/piping may be provided with a drip pan, sloped, or otherwise designed to  
15 perform the secondary containment functions, including leak detection. One such drip pan is located in  
16 the HLW Vitrification Facility Drum Transfer Tunnel (H-B015).

17 Low-Activity Waste Melter Feed Line Encasement Assembly

18 The feed lines that transfer wastes from the LAW Melter Feed Process system to the melters are housed in  
19 the LAW Melter Feed Line Encasement Assemblies (LMP-LDB-00001/00002). The encasement  
20 assemblies are a sloped bellows encasement that contains the feed line where they travel between the  
21 process cells and the melter gallery. The encasement assemblies are equipped with leak detection cables  
22 that run under the feed lines and into the bellows. The assemblies are equipped with drain lines to flow to  
23 sumps in the LAW process cells.

24 Autosampling System Samplers

25 The Autosampling System (ASX) samplers in the PTF, HLW Vitrification, and LAW Vitrification  
26 facilities contain both upper and lower secondary containment liners and leak detection systems. The  
27 upper containment area is designed to collect a potential leak from the incoming sample feed and return  
28 lines where they connect to the ISOLOK<sup>®</sup> sampling device. If a leak occurs in the upper containment  
29 area, the leak flows to the sloped liner which diverts the leak to the annular space of the coaxial sample  
30 return lines. Leaks flow down the secondary containment pipe and discharge to secondary containment  
31 with leak detection, typically a sump with a radar level detector. The ASX sample feed and sample return  
32 lines, and the routing of potential leaks in the annular space of the return lines are shown on the associated  
33 process system piping and instrumentation diagrams (P&IDs).

34 The sloped stainless steel liner in the lower containment area is designed to divert liquids to a sloped  
35 collection trough. The trough contains a removable weir that allows liquids to collect and activate the  
36 thermal level detection switch and alarms to indicate that a leak has occurred. Effluent from a leak flows  
37 to the same drain line that manages ISOLOK flush solutions. The ISOLOK flush lines terminate below  
38 the top of the trough drain to ensure that the leak detection system is not activated when flushing the  
39 ISOLOK. The ASX lower containment area drain lines are shown on the associated process system  
40 P&IDs.

41 Sump and Leak Detection Boxes and Secondary Containment Drain Systems

42 Sumps, LDBs, and secondary containment drain systems for the four process plants and the Lab are listed  
43 in Table 4D-4 in Chapter 4D, Table 4E-5 in Chapter 4E, Table 4F-4 in Chapter 4F, Table 4G-4 in  
44 Chapter 4G, and Table 4H-5 in Chapter 4H and described in the following sections. Systems monitor and  
45 collect liquids managed in the system. Sumps, LDBs, and secondary containment drains are provided

1 with a stainless steel liner or equivalent to act as the secondary containment. The sumps and LDBs within  
2 the process areas provide a low point for each secondary containment. The sumps and LDBs serve the  
3 following functions:

- 4 • Low point containment.
- 5 • Removal of material by means of sump emptying ejectors or pumps.
- 6 • Sampling of sump contents by means of sump sampling ejectors.

7 The following sections describe the type of sump used at the WTP and the secondary containment drains.

#### 8 Sumps and Leak Detection Boxes

9 Sumps and LDBs are part of the secondary containment system provided for tank systems and wet  
10 miscellaneous treatment systems. Sumps and LDBs are located at a low point in the secondary  
11 containment systems and are equipped with leak detection instrumentation and corresponding alarm.  
12 Mechanical or fluidic pumps are used to remove liquid that may accumulate in a sump or LDB.

13 Four sumps located in the HLW Vitrification Facility Melter Cave 1 and 2 (HSH-SUMP-00003/7/8/9) are  
14 equipped with stainless steel sump baskets. Sump baskets capture and retain small objects which may be  
15 inadvertently dropped into the sump and prevent them from entering the piping. The baskets are provided  
16 with a lifting bail for the crane to remove from the sump and handles for the power manipulator to empty  
17 into a waste bucket. Sumps in the PTF, LAW, Lab, and EMF are provided with screened or perforated  
18 covers to prevent small objects from falling into or accumulating in the sump.

19 Many of the bulges, the autosamplers, and some process areas have secondary containment drains. This  
20 type of liquid collection system is located in a low spot in the cell formed by the sloping floor. Liquid  
21 detection instrumentation is provided for the secondary containment drains. Collected liquids  
22 gravity-drain to a collection vessel with a tank level indicator. The managed liquids could be waste  
23 released from a tank system, including ancillary equipment, or water used to wash the exterior of tanks or  
24 the walls of the containment area. Design details of each secondary containment drain/drain line are  
25 included in Table 4D-4 in Chapter 4D, Table 4E-5 in Chapter 4E, Table 4F-4 in Chapter 4F, Table 4G-4  
26 in Chapter 4G, Table 4H-5 in Chapter 4H, and shown on the P&IDs for the Radioactive Liquid Waste  
27 Disposal (RLD) and/or Plant Wash and Disposal (PWD) systems.

#### 28 Design Requirements

29 The process cells, process rooms, or caves with mixed waste vessel or tank systems are partially lined  
30 with stainless steel or special protective coating, which covers the floor and extend up the sides of the  
31 process cell or cave to a height that can contain 100 percent of the volume from the largest tank within the  
32 process cell or cave. Table 4D-3 in Chapter 4D, Table 4E-4 in Chapter 4E, Table 4F-3 in Chapter 4F,  
33 Table 4G-4 in Chapter 4G, and Table 4H-2 in Chapter 4H present the calculated minimum secondary  
34 containment liner height at the four process plants and the Lab.

35 A concrete berm with special protective coatings or stainless liner are used for the PTF and EMF outdoor  
36 tanks and vessels. These secondary containment areas are capable of holding 100 percent of the volume  
37 from the largest tank within the berm, plus the precipitation from a 25-year, 24-hour rainfall event, as  
38 required under WAC 173-303-640(4)(e)(i)(B).

39 The WTP uses consensus-recognized standards to ensure that the process cells, process rooms, caves, or  
40 berms provide secondary containment with sufficient strength, thickness, and compatibility with waste.  
41 The design includes an engineered structural base to protect the cells, caves, berms, and tank systems  
42 against failure resulting both from excess force applied during catastrophic events or settlement, and from  
43 the stress of daily operation. In the event of a spill or release, the structural and foundation design for tank  
44 and process cells, process rooms, caves, and berms prevents released mixed waste from reaching the  
45 environment, and safely contains the waste until it can be transferred to an appropriate collection tank.

1 **4.2.5.3 Management of Release or Spill to Sump and Secondary Containment Drain**  
2 **Systems**

3 The WTP uses dry sumps and LDBs as part of the secondary containment and leak detection systems.  
4 Sumps and LDBs are instrumented to inform the operator to investigate the cause of the liquid detected in  
5 the sump or LDB. Secondary containment systems are sloped to direct flow of leaks or spills to the sump  
6 or LDB. To remove liquid from the sumps or LDBs in a timely fashion, sumps and LDBs are equipped  
7 with mechanical or fluidic pumps.

8 A detection alarm indicating that there is liquid in the sump or LDB will be investigated to determine if  
9 the alarm is valid. If the alarm is valid, the incident will be corrected. Mixed waste released from the  
10 primary system and collected in a sump or LDB will be removed within 24 hours, or in as timely a  
11 manner as possible. If the released material cannot be removed within 24 hours, the Washington State  
12 Department of Ecology (Ecology) will be notified.

13 Any secondary containment system from which there has been a leak or a spill, or which is unfit for use,  
14 will be removed from service immediately and will satisfy requirements per WAC 173-303-640(7).

15 **4.2.5.4 Additional Requirements for Secondary Containment**

16 The WTP dangerous waste storage tanks have vault-type secondary containments that have either  
17 chemical-resistant water stops and special protective coatings or the following configurations that  
18 Ecology has approved as equivalent to a coating/water stop system:

- 19 • An impermeable interior coating that is compatible with the stored waste and a polymeric filler  
20 material at interior corners and construction joints that performs a function equivalent to a water  
21 stop.
- 22 • A welded stainless steel liner attached to walls and floors.

23 Ancillary equipment such as piping is addressed within Section 4.2. Other types of ancillary equipment  
24 such as pumps, seal pots, and reverse flow diverters are provided with secondary containment. Inspection  
25 of ancillary equipment is addressed in Operating Unit Group 10, Chapter 6A.

26 **4.2.6 Variances from Secondary Containment Requirements**

27 No variances from secondary containment requirements are sought for the WTP tank systems. Tank  
28 systems are provided with secondary containment as identified in the flooding volume documents  
29 described in the previous sections.

30 **4.2.7 Tank Management Practices**

31 The following provides the basic philosophy for the WTP vessel overflow systems. Three types of  
32 barriers exist to prevent overflow of process equipment: preventive controls, detectors, and regulators.  
33 Preventive controls promote controlled filling within normal process ranges. Detectors recognize if a  
34 vessel is being overfilled and alert an operator. Lastly, if preventive controls and detectors fail to stop  
35 overflow from occurring, regulators trip a control sequence that stops inflow and/or initiates outflow. The  
36 principal design concept to control vessel overflow is to prevent an overflow from occurring. The  
37 engineering design minimizes the likelihood of tank, ancillary equipment, and containment system  
38 overflows, and over-pressurization, ruptures, leaks, corrosion, and other failures.

39 In general, overflows are prevented by inventory control in conjunction with level monitoring. The fluid  
40 levels in a vessel are maintained within low- and high-level ranges. Appropriate alarm settings are used to  
41 note deviations from the designed settings. Automatic trip action is designed to shut down feed to the  
42 vessel when the high-level settings are exceeded. These automatic trip actions are provided for vessels  
43 with the potential for high operational and environmental impact in case of an accident or release.

1 Most of the WTP tank systems are designed to incorporate minimal or zero maintenance requirements  
2 and are based on a design life of approximately 40 years. The design emphasis of zero maintenance  
3 minimizes the likelihood of spills and overflows in the tank systems. In the event that the process controls  
4 fail to prohibit vessel overflowing, engineered overflows are provided to prevent liquid from entering the  
5 vessel ventilation systems. Vessels that are nominally operating at atmospheric pressure have a suitable  
6 gravity or engineered overflow system, unless an overflow can be shown not to be possible. Vessels or  
7 systems that normally operate at above atmospheric pressures are not provided with overflows.

8 The following principles apply when designing an engineered overflow system:

- 9 • The overflow system for vessels must be instantaneously and continuously available for use.
- 10 • Overflowed process streams must be returned to the waste treatment process.
- 11 • Overflow systems must meet the requirements of WAC 173-303, Dangerous Waste Regulations,  
12 Section 640, *Tank systems*. In meeting these requirements, overflowing direct to the cell floor is  
13 only considered as the last overflow in a cascaded system. Where an overflow is from a vessel to  
14 the cell, the overflow system maintains segregation of the cell and vessel ventilation systems. The  
15 compatibility of the overflowing liquid and the recipient vessel is considered.
- 16 • A vessel overflow line is sized to handle the maximum inflow to the vessel without the liquid  
17 level in the overflowing tank reaching an unacceptably high level. No valves or other restrictions  
18 are permitted in the overflow line. This line is also designed to prevent the buildup of material  
19 that could cause blockages.
- 20 • The overflow receiver is sufficiently sized to contain the overflow.
- 21 • Inspections are performed on the various tank and overflow systems, using the example schedules  
22 described in DWP Operating Unit Group 10, Chapter 6A.

#### 23 **4.2.8 Routinely Non-Accessible Area**

24 Tanks, vitrification sub-systems, or miscellaneous unit equipment that manage mixed or dangerous waste  
25 will be provided with a sign or label according to Permit Condition III.10.E.5.e. The label, or sign, will be  
26 posted at the entry of the non-accessible room or cell, and be legible at a distance of at least fifty (50) feet,  
27 and bear a legend that identifies the waste in a manner which adequately warns employees, and  
28 emergency response personnel of the major risk(s) associated with the waste being stored or treated in the  
29 room or process cell. Personnel may be required to access these areas on a case-by-case basis such as an  
30 emergency response event. The list of routinely non-accessible rooms to support the DFLAW  
31 configuration is provided in Table 6A-3d, DWP Operating Unit Group 10, Chapter 6A.

#### 32 **4.2.9 Air Emissions**

##### 33 **4.2.9.1 Tank System Emissions**

34 Most of the tanks are connected to a vessel ventilation system to collect vapors. Vessel vents are located  
35 on process vessels and tanks, breakpots, and other small vessels. Exhaust from reverse flow diverters and  
36 pulse jet mixers are also collected.

##### 37 **4.2.9.2 Process Vents**

38 The air emission regulations, specified under WAC 173-303-690 and 40 Code of Federal Regulations  
39 (CFR) 264 Subpart AA, apply to process vents associated with distillation, fractionation, thin-film  
40 evaporation, and air or steam stripping operations that manage mixed waste with total organic carbon  
41 concentrations of at least 10 parts per million by weight. The WTP does not use these regulated processes;  
42 therefore, this regulation does not apply to the WTP.

1 **4.2.9.3 Equipment Leaks**

2 Regulations provided in WAC 173-303-691 and 40 CFR 264 Subpart BB contain the *Air Emission*  
3 *Standards for Equipment Leaks*. These air emission standards do not apply to the WTP because waste  
4 feed entering the WTP contains less than 10 percent total organic carbon by weight and is excluded under  
5 40 CFR 264.1050(b).

6 **4.2.9.4 Tanks and Containers**

7 The regulations specified under WAC 173-303-692 and 40 CFR 264 Subpart CC do not apply to the  
8 WTP mixed waste tank systems and containers. These tanks and containers qualify as waste management  
9 units that are "...used solely for the management of radioactive mixed waste in accordance with all  
10 applicable regulations under the authority of the Atomic Energy Act and the Nuclear Waste Policy Act"  
11 and are excluded under 40 CFR 264.1080(b)(6). Containers bearing nonradioactive, dangerous waste,  
12 such as maintenance and laboratory waste, that is not excluded under 40 CFR 264.1080 (b)(2) or  
13 40 CFR 264.1080(b)(8), will comply with the tank and container standards specified under 40 CFR 264  
14 Subpart CC.

15 **4.2.9.5 Identification of Containers**

16 All dangerous and/or mixed waste containers are labeled in a manner that adequately identifies the major  
17 risk(s) associated with the contents. When labeling, ensure labels are not obscured or otherwise  
18 unreadable, waste containers are oriented so as to allow inspection of the labels identified with the  
19 container tracking number, and, to the extent possible, any labels which the generator placed upon the  
20 container, empty dangerous and mixed waste containers must have their dangerous and/or mixed waste  
21 labels destroyed or otherwise removed immediately upon being rendered empty.

22 For purposes of container labeling, hazards include the following:

- 23 • Persistent (if a WP01 or WP02 waste code).
- 24 • Toxic (if a WT01, WT02, or D waste code other than D001, D002, or D003).
- 25 • Ignitability (if a D001 and other waste codes).
- 26 • Corrosive (if a D002 and other waste codes).
- 27 • Reactive (if a D003 and other waste codes).

28 This does not apply to ILAW containers and IHLW canisters, in accordance with Permit Condition  
29 III.10.D.5.

30 **4.2.9.6 Ventilation Control**

31 This section describes air emissions from vessel ventilation systems and reverse flow diverter exhausts.  
32 Organic emissions from vents associated with evaporator or distillation units are also discussed.

33 In compliance with WAC 173-303-695, WTP facilities have been designed to prevent fugitive emissions  
34 of contaminants from containment buildings within the WTP permitted facilities through pathways other  
35 than High-Efficiency Particulate Air (HEPA)-filtered and monitored discharge points to the environment.  
36 WTP HVAC systems, in conjunction with the building structures provide the confinement system needed  
37 to prevent exit of contaminants from WTP facilities through doors, windows, building cracks or other  
38 unmonitored and unfiltered exit paths directly to the environment.

39 The WTP facilities are designed such that they are segregated into confinement zones for ventilation  
40 control purposes. WTP confinement zones consist of barriers or barrier systems, which includes walls,  
41 floors and roofs, and the associated HVAC systems.

1 WTP facilities' ventilation confinement zones consist of the following:

2

Confinement Zone	Contamination Classification	Ventilation Design Philosophy Definitions
Primary	C5	Plant areas and associated ventilation ductwork that are in direct contact with airborne contaminants to adjacent zones under both normal and abnormal operating conditions. Maintained at approximately (-) 1.0 to (-) 1.4 inches of water relative to C3 areas.
Secondary	C3	Contaminated areas where work requires protective clothing. Maintained at maximum negative pressure of (-) 0.4-inches of water relative to surrounding C2 areas.
Tertiary	C2	Controlled Area. Operating areas of the process building that have direct interfaces with contaminated areas and have the potential to be contaminated. Maintained at a slight negative pressure with respect to atmosphere.

3

4 Information regarding specific facilities can be found in Chapters 4D.3, 4E.3, and 4F.3.

5 Airborne contaminants in C2 areas will cascade to C3 areas or be removed by C2 exhaust system HEPA  
6 filters prior to discharge to the environment. Airborne contaminants in C3 areas will cascade to C5 areas  
7 or be removed by C3 exhaust system HEPA filters prior to discharge to the environment, including  
8 releases from containment buildings within C3 areas. Airborne contaminant in C5 areas will be removed  
9 by C5 exhaust system HEPA filters prior to discharge to the environment, including releases from  
10 containment buildings within C5 areas.

11 The systems are interlocked such that the exhaust system serving areas of lesser contamination potential  
12 cannot operate without the exhaust systems serving areas of higher contamination potential operating.  
13 This precludes pressurization of WTP areas and possible fugitive dust emissions from the facility through  
14 doors, windows, building cracks, or other unmonitored and unfiltered exit paths.

15 The following design features and operational measures will be used to prevent fugitive dust from  
16 escaping from containment buildings resulting in unfiltered and unmonitored releases to the environment,  
17 and control fugitive emissions such that openings will not exhibit visible emissions:

- 18 • Cascading air flow from areas of least potential contamination to areas of greatest potential  
19 contamination (i.e., C2 to C3 to C5 areas).
- 20 • Greater negative pressure in confinement areas compared to outside environment pulls air into the  
21 area preventing backflow.
- 22 • Intake from one confinement zone to another through air in-bleed units, with isolation and  
23 backflow control type features.
- 24 • HEPA filtration of exhausted air is monitored prior to atmosphere discharge through the exhaust  
25 stack. C2 and C3 exhaust systems have one stage of HEPA filters. C5 exhaust systems have two  
26 stages of HEPA filters.
- 27 • Redundant exhaust fans maintain negative pressure and cascading airflow during normal  
28 operation, routine fan maintenance and repair conditions.
- 29 • Personnel ingress and egress through airlocks and subchange rooms.

- 1 • Dedicated HEPA-filter systems will be provided for each maintenance area, workshop, and  
2 decontamination room where local process-generated airborne contaminants will be collected to  
3 prevent spread outside of the area.
- 4 • Containment buildings (i.e., cells or areas) are typically located within C3 or C5 areas for control  
5 of airborne contamination.
- 6 • Containment buildings are located within ventilation-controlled process facilities.

#### 7 **4.2.10 Management of Ignitable, Reactive and Incompatible Waste in Tanks**

8 In the Baseline configuration, mixed waste from the Hanford Tank Farms is initially designated as both  
9 ignitable (D001) and reactive (D003). The D001 and D003 waste numbers are described in the waste  
10 analysis plan in DWP Operating Unit Group 10, Chapter 3C. The PTF process vessels are located in a  
11 manner that meets the National Fire Protection Association (NFPA) buffer zone requirements for process  
12 vessels, as contained in Tables 2-1 through 2-6 of the *NFPA-30 Flammable and Combustible Liquids*  
13 *Code* (NFPA 1981). The process vessels are designed to store the waste in such a way that it is protected  
14 from materials or conditions that could cause the contents to ignite or react. Vessel contents will be  
15 constantly mixed and will be actively vented to process stacks, which will be equipped with vapor  
16 collection and treatment systems that manage emissions. Further information on waste numbers is  
17 contained in DWP Operating Unit Group 10, Chapter 3C.

18 In the DFLAW and DFHLW configurations, the treated LAW and HLW waste feeds received from the  
19 TOC will not demonstrate the characteristics of ignitable or reactive waste.

20 Ignitable or reactive waste may be generated from laboratory or maintenance activities. This waste is  
21 accumulated and managed in compliance with regulatory requirements, in approved containers.  
22 Potentially incompatible waste generated from laboratory or maintenance activities will not be stored in  
23 the tank systems.

24 A potential for incompatibility may exist, for example when nitric acid is used to elute waste components  
25 from ion-exchange column resins that were previously regenerated with sodium hydroxide. To minimize  
26 a reaction, water flushes are performed between batches.

27 Process reagents that could react with waste in the tank systems are stored in areas that are separated by  
28 physical barriers from process tanks. Potentially incompatible wastes generated from laboratory or  
29 maintenance activities will not be stored in proximity to each other in the tank systems.

### 30 **4.3 Waste Treatment Plant Miscellaneous Treatment Sub-Systems [WAC 173-303-680** 31 **and WAC 173-303-806(4)(i)]**

32 The WTP miscellaneous treatment units consist of the vitrification melters, offgas treatment equipment,  
33 evaporators and associated equipment. The melters immobilize mixed waste in a glass matrix. The  
34 following sections provide additional information on the vitrification systems.

35 Other miscellaneous treatment sub-systems, and their associated process control features, are described in  
36 Section 4.2.

#### 37 **4.3.1 Melter Capacity and Production**

38 For the melters, throughput is defined on the basis of quantity of glass waste produced. In turn, the  
39 quantity of glass waste produced depends on the degree to which the feed can be incorporated into the  
40 glass matrix. The maximum design throughput of the LAW Melter systems is approximately 15 metric  
41 tons per day of glass waste for each melter and approximately 30 metric tons per day. The production rate  
42 of the HLW Melters is approximately 3 metric tons per day for each melter and approximately 6 metric  
43 tons per day throughput.

1 In the event that two LAW melters do not meet the combined production of 30 metric tons of glass a day  
2 then the existing LAW Building will retain capacity to install the third melter before or after hot start up.  
3 No melter support vessels or support systems should be deleted from process cell design that could  
4 preclude later melter installation. A third melter would not be proposed if a third LAW melter would  
5 exceed the capacity of the container handling system or the ventilation system in the LAW Building.

#### 6 **4.3.2 Description of Melter Units [WAC 173-303-806(4)(i)(i)]**

7 The LAW Melter systems are located in the melter galleries and the HLW Melters are housed within the  
8 melter caves as depicted in the general arrangement plan and section permit drawings.

9 The following subsections provide detailed descriptions of the melter units.

#### 10 Low-Activity Waste Melter Units

11 Figure 4A-48 in Chapter 4A provides a sketch of a LAW Melter. Each LAW Melter (LMP-MLTR-  
12 00001/2) is a rectangular shell, lined with refractory material. An additional outer steel casing with access  
13 panels is provided to enclose the LAW Melter. This outer steel casing is designed to provide local  
14 shielding and containment. Each LAW Melter has a nominal design capacity of approximately 15 metric  
15 tons of glass waste per day. Each has a molten glass surface area of approximately 107 square feet (ft<sup>2</sup>).  
16 Each of the two LAW melters has external dimensions of approximately 31 × 21 × 16 ft high, and weighs  
17 approximately 295 metric tons empty and 318 metric tons with glass. The operating temperature of the  
18 melter is between 1050°C and 1200°C.

19 The locally shielded LAW Melter (LMP-MLTR-00001/2) is operated and maintained in a personnel  
20 access area. The melter is maintained at a lower pressure than the surrounding room to prevent escape of  
21 contaminants. Consumable melter parts are replaced through access panels. The melters are transported in  
22 and out of the gallery on a rail system.

23 The melter refractory package is designed to serve as a mechanical, thermal, and electrical barrier  
24 between the molten glass residing in the melter and the melter shell. The refractory package is housed in a  
25 steel shell and provides containment for the molten glass. Active cooling on the outside of the refractory  
26 package is provided by water jackets. The water jackets are in the intermediate loop of a two-loop system  
27 that transfers heat from the LAW Melter through heat exchangers to cooling towers. The intermediate  
28 loop containing the water jacket is a closed system that isolates the water circulating through the water  
29 jacket from the water in the cooling water loop circulating to the cooling tower. Mixed waste material  
30 leaking into the intermediate loop cooling water is prevented from becoming an inadvertent discharge via  
31 the cooling tower. The refractory package provides adequate containment if there is a temporary loss of  
32 cooling. Penetrations in the melter system are sealed using appropriate gaskets and flanges. This system is  
33 designed for plenum temperatures of up to 1,100°C. The LAW melter lid is composed of steel and  
34 refractory material layers.

35 Each LAW Melter (LMP-MLTR-00001/2) uses two independent discharge chambers. An air lift pumps  
36 molten glass from the bottom of the melter pool, through a riser, into a discharge chamber, and pours it  
37 into an ILAW container. The ILAW is then allowed to cool, forming a highly durable borosilicate glass  
38 waste form within the container.

39 Spent LAW Melters are initially managed within the LAW melter gallery containment miscellaneous  
40 unit. Spent LAW Melters are removed from the melter gallery and transported using a transport and rail  
41 system. If necessary, the melter exterior surfaces will be decontaminated prior to shipment to the  
42 Integrated Disposal Facility (IDF). Once the melters are removed from WTP, they will be transferred to  
43 IDF for disposal. Removal of the cooling water within the melters is not required.

1 Since the melters are permitted as miscellaneous units, they are not required to meet void requirements  
2 per WAC 173-303-665(12), but IDF will include measures to minimize subsidence within the disposal  
3 cells. Treatment of the used melters is not required, because the vitrified glass remaining in the melters  
4 meets the criteria associated with the Land Disposal Restrictions (LDR) treatment variance approved by  
5 Ecology.

### 6 High-Level Waste Melter Units

7 Figure 4A-27 in Chapter 4A provides a sketch of an HLW Melter. Each HLW Melter (HMP-MLTR-  
8 00001/2) is a rectangular shell, lined with refractory material. They have four compartments: a glass tank,  
9 two discharge chambers, and a plenum just above the glass tank. The tanks are lined with refractory  
10 material designed to withstand corrosion by molten glass.

11 The HLW Melter systems consist of two melters. Each HLW Melter (HMP-MLTR-00001/2) is designed  
12 for glass production rates up to 3 metric tons per day (MTG/d). The normal operating temperature of the  
13 melter is between 950°C and 1250°C. The HLW Melters have a molten glass surface area of  
14 approximately 40 ft<sup>2</sup>. The HLW Melters have external dimensions of approximately 11 ft high × 14 ft  
15 deep × 14 ft wide. The glass contained in a full HLW Melter has a volume of approximately 145 ft<sup>3</sup> and  
16 weighs approximately 9.1 metric tons. An entire melter, including the supporting structure and transport  
17 mechanism, weighs approximately 90 metric tons empty and approximately 99 metric tons full.

18 The HLW Melters (HMP-MLTR-00001/2) are designed to be remotely operated and maintained. Remote  
19 maintenance is performed by a power manipulator, overhead crane, and auxiliary hoist, or by  
20 through-wall master-slave manipulators. The melter is positioned within the HLW Vitrification Facility  
21 for ease of access and viewing of both discharge chambers during operations, and for viewing access to  
22 the melter lid to facilitate removal and replacement of subcomponents, if needed. A rail and bogie  
23 transport system facilitates remote removal and replacement of the entire melter structure.

24 The HLW Melters (HMP-MLTR-00001/2) uses a refractory package similar to the LAW melters to  
25 contain the molten glass. The refractory package is designed to serve as a mechanical, thermal, and  
26 electrical barrier between the molten glass inside the melter and the melter shell.

27 The HLW Melters also use an outer shell, which, with the refractory package, contains the molten glass  
28 and melter offgas. Active cooling on the exterior of the melter is provided by a water jacket, which is in a  
29 two-loop system that transfers heat from the HLW Melter through heat exchangers to cooling towers. The  
30 loop containing the water jacket is a closed system that isolates the water circulating through the water  
31 jacket from the water in the cooling water loop circulating to the cooling tower. Mixed waste material  
32 leaking into the intermediate loop cooling water is prevented from becoming an inadvertent discharge  
33 through the cooling tower. The refractory package provides adequate containment should there be a loss  
34 of cooling. The HLW Melter lid is constructed of a steel outer shell and insulated from the melter plenum  
35 by refractory material.

36 The HLW Melter uses two independent discharge chambers. Discharge is achieved by transferring the  
37 molten glass from the bottom of the melter pool, through a riser, and then poured into a stainless steel  
38 IHLW canister. Glass waste transfer is accomplished through air lifting. The IHLW is then allowed to  
39 cool, forming a highly durable borosilicate glass waste form.

40 Spent HLW Melters are removed from the melter cave and placed in an overpack. The spent melter is  
41 treated as newly generated waste and is initially managed within the HLW melter containment buildings.  
42 If necessary, the overpack will be decontaminated using a dry process. Failed HLW Melters are stored in  
43 the failed melter storage building.

### 4.3.3 Automatic Waste Feed Cut-Off System

The LAW and HLW Melters are equipped with the ability to cut off waste feed. Automatic waste feed cut-off systems terminate feed to the melter if a specified operating condition is exceeded. This design approach is consistent with the WAC 173-303-680 regulatory requirements.

The LAW (LMP-MLTR-00001/2) and HLW (HMP-MLTR-00001/2) Melters are fed via air displacement slurry pumps that utilize pressurized air as the motive force. These pumps supply feed to the melters in slugs that act to keep lines from plugging. The feed is injected into the melters through the feed nozzles on top of the melter, creating a “cold cap,” where waste feed undergoes several physical and chemical changes. The glass product in the melter is then “air lifted” through the discharge chamber and into the glass container. Melter offgas is generated from the vitrification of LAW and HLW of which the rate of generation is dynamic and not steady state. The offgas is then carried away and treated via a dedicated offgas system.

The melter systems are designed to minimize the need for automatic waste feed cut-off functions. Control of melter level and plenum pressure, process alarming, and optimized operating procedures are in place to reduce the occurrences of interlocking. Given the processing speeds and the relatively slow rates of change in the operating states of the melter, operators should have adequate time to react to upset conditions. An example of the slow rate of change can be seen in the volume of feed per air displacement slurry pump feed cycle when increasing melter level. Each pump cycle adds approximately one gallon of slurry into the melter. At one gallon of volume, the liquid level rises no greater than 0.01 inch inside the melter. This provides ample time for operator response.

Previous operating experience with similar melter systems has shown the following operating conditions may warrant automatic waste feed cut off:

- Maximum melter chamber pressure.
- Minimum off-gas temperature at the thermo catalytic oxidizer bed inlet.
- Maximum carbon bed adsorber bed temperature.
- Maximum stack gas flow rate.
- Maximum stack gas carbon monoxide.

These interlocks have been sufficient to allow continued melter operations without inadvertent feed cut-off signals, yet provide a sufficient safety margin, and can be found in Permit Condition Table III.10.H.F.

### 4.3.4 Offgas Treatment System

The offgas treatment system treats or removes steam, aerosols, entrained particulates, decomposition products, and volatile contaminants that are generated from the vitrification processes and the vessel ventilation systems. The typical constituents contained in the melter offgas stream are as follows:

- Nitrogen oxides from decomposition of metal nitrates in the melter feed.
- Chloride, fluoride, and sulfur as oxides, acid gases, and salts.
- Entrained feed material and glass.

A detailed description of the current offgas treatment trains for the LAW (LMP-MLTR-00001/2) and HLW (HMP-MLTR-00001/2) Melters is provided in Chapter 4E and Chapter 4F, respectively.

### 4.3.5 Miscellaneous Unit Emissions Performance

The WTP melter systems are thermal treatment units classified as miscellaneous units in WAC 173-303-680. The dangerous waste regulations require that permits for miscellaneous units include such terms, conditions, and provisions that are necessary to protect human health and the environment and are appropriate for the miscellaneous unit being permitted. Ecology has determined that regulations

1 that are most appropriate to apply to the melters and offgas systems (melter systems) are found in the tank  
 2 requirements (WAC 173-303-640) and applicable sections of the incinerator requirements (WAC  
 3 173-303-670) and 40 CFR Section 63.1203. As applied to the melter systems, the tank regulations  
 4 primarily provide requirements for structural integrity, material compatibility, secondary containments,  
 5 etc.

6 The incinerator regulations primarily provide operational requirements for parameters such as  
 7 temperature, pressure, feed rate, demonstration testing, and performance standards, etc. Ecology  
 8 determined and incorporated into the final WTP DWP issued in September 2002 the standards specified  
 9 in 40 CFR Section 63.1203 in the following table apply to the WTP melter system miscellaneous units.

10

<b>Miscellaneous Unit Emissions Performance Standards</b>	
<b>Pollutant</b>	<b>Ecology-Directed Requirement</b>
PODC	99.99% destruction and removal efficiency (DRE)
Dioxins and Furans	0.20 ng TEQ/dscm
Mercury	45 µg/dscm
Lead and Cadmium	120 µg/dscm, combined emissions
Arsenic, Beryllium, Chromium	97 µg/dscm, combined emissions
Carbon Monoxide and Hydrocarbons	Carbon monoxide not in excess of 100 ppmv over an hourly rolling average, monitored continuously with a continuous emissions monitoring system. Hydrocarbons not in excess of 10 ppmv during DRE test runs, over an hourly rolling average (monitored with a continuous emissions monitoring system during test runs), corrected to 7 percent oxygen, and reported as propane.
Hydrochloric Acid and Chlorine Gas	21 ppmv, combined emissions, expressed as hydrochloric acid equivalents, dry basis
Particulate Matter	34 mg/dscm

PODC is Principal Organic Dangerous Constituent.

TEQ is dioxin/furan toxicity equivalence defined in 40 CFR 63.1201(a).

dscm is dry standard cubic meter.

ppmv is parts per million by volume.

ppmdv is parts per million by volume, dry.

Rolling average is the average of all 1-minute averages over the averaging period [40 CFR 63.1201(a)].

11

12 DOE intends that the melter systems be designed and constructed so that they operate in compliance with  
 13 the appropriate and applicable standards. Environmental performance demonstrations during cold  
 14 commissioning of the HLW and LAW Vitrification facilities are used to verify compliance with the  
 15 Destruction and Removal Efficiency (DRE) and other applicable air emission standards.

16

#### **4.3.6 Physical and Chemical Characteristics of Waste [WAC 173-303-680(2)(a)(i)]**

17

18 A description of the waste characteristics of the LAW and HLW feeds is presented in DWP Operating  
 19 Unit Group 10, Chapters 3A and 3C. The immobilized waste generated by the vitrification processes is in  
 20 the form of glass that maintains its chemical and physical integrity during long-term storage. Chapters 3A  
 and 3C describe the types and frequency of analysis that are performed on the glass waste.

1 **4.3.7 Environmental Performance Standards for Melter Systems [WAC 173-303-680(2)]**

2 An environmental performance demonstration will be conducted to demonstrate the efficiency of the  
3 LAW and HLW Melter systems and their respective air pollution control systems. Emissions from the  
4 LAW and HLW systems will be sampled and analyzed during an environmental demonstration performed  
5 during cold commissioning. The data developed during the environmental performance demonstration  
6 supports the screening-level risk assessment, which supports the development of environmental  
7 performance standards for the LAW and HLW Melter systems.

8 The operational activities of the WTP include methods intended to ensure proper performance of  
9 equipment and processes.

10 **4.3.7.1 Protection of Groundwater, Subsurface Environment, Surface Water, Wetlands  
11 and Soil Surface [WAC 173-303-680(2)(a) and (b)]**

12 The LAW Melters are located in the LAW Melter Gallery (L-0112) within the LAW Vitrification  
13 Facility. The HLW Melters are located in the HLW Melter caves (H-0117, H-0106) within the HLW  
14 Vitrification Facility. Both plants are designed to comply with standards that ensure protection of the  
15 surface and subsurface environments. The vitrification plants are completely enclosed and are designed to  
16 have sufficient structural strength and corrosion protection to prevent collapse or other structural failure.  
17 In addition, the melter systems, melter feed systems, and related piping are provided with secondary  
18 containment, to minimize the potential for release. The LAW Melter Gallery (L-0112) and the HLW  
19 Melter caves (H-0117, H-0106) will be permitted as a containment miscellaneous unit and containment  
20 buildings and are described in Chapter 4E and Chapter 4F, respectively.

21 Floors within the vitrification plants are protected in a manner consistent with the intended usage of the  
22 space. The floor and portions of the walls of HLW Melter cave are partially lined with stainless steel.  
23 Nonradioactive materials usage areas requiring heavy equipment have concrete floors with hardener and  
24 sealer finishes.

25 The *Hanford Facility Dangerous Waste Permit Application General Information Portion*, Section 5.4  
26 (DOE-RL 1998), provides climatological data, topography, hydrogeological and geological  
27 characteristics, groundwater flow quantity and direction, groundwater quality data, and surface water  
28 quantity and quality data for the area around the WTP.

29 **4.3.7.2 Protection of the Atmosphere [WAC 173-303-680(2)(c)]**

30 A risk assessment is performed to evaluate the impacts of the WTP emissions on human and ecological  
31 receptors. Actual offgas emissions is measured during an environmental performance demonstration that  
32 is performed as part of the WTP commissioning activities. The data is used during a screening-level risk  
33 assessment that is performed to determine ecological and human health risk. The emissions data and the  
34 results of the screening-level risk assessment are used to establish operating conditions for the melters  
35 that do not endanger human health and the environment.

36 **4.3.8 Treatment Effectiveness Report [WAC 173-303-806(4)(i)(iv)]**

37 A treatment effectiveness report evaluating the performance of the miscellaneous treatment sub-systems,  
38 and their effectiveness in treating the LAW and HLW, will be located in DWP Operating Unit Group 10.  
39 The report uses the results of the environmental performance demonstration and the risk assessment  
40 activities to document treatment effectiveness of miscellaneous treatment sub-systems.

41 **4.3.9 Approach to Risk Assessment [WAC 173-303-680(2)(c)(i) through (vii)]**

42 A screening-level risk assessment is being conducted to evaluate any possible human health and  
43 ecological risk posed by the thermal treatment of mixed wastes. The risk assessment provides information  
44 about the potential terrestrial, aquatic, and food pathways for exposure of human and ecological receptors  
45 to dangerous waste constituents. This risk assessment presents the quantitative methods, detailed

1 assumptions, and numerical parameters that are used to estimate the nature, extent, and magnitude of  
2 potential risks from operation of the WTP. The primary regulatory guidance followed for this risk  
3 assessment is found in the *Human Health Risk Assessment Protocol for Hazardous Waste Combustion*  
4 *Facilities* (Environmental Protection Agency [EPA] 1998a) and the *Screening-Level Ecological Risk*  
5 *Assessment Protocol for Hazardous Waste Combustion Facilities* (EPA 1999a).

6 Treated air emissions through the stack are the only planned direct releases into the environment from the  
7 WTP. Other waste streams are transferred to a permitted facility and are not released directly into the  
8 environment.

9 Major components of the human health and ecological risk assessment process for evaluating airborne  
10 emissions are as follows:

- 11 • Risk assessment work plan.
- 12 • Pre-demonstration test risk assessment.
- 13 • Final risk assessment.

14 The overall approach for the risk assessment is to identify potential risks associated with various  
15 receptors, their locations, exposure pathways, and activity patterns in two broad exposure scenarios, as  
16 follows:

- 17 • Plausible exposure scenario.
- 18 • Worst-case exposure scenario.

19 The plausible exposure scenarios are based on where potential receptors currently exist or may reasonably  
20 be expected to exist within the foreseeable future. The worst-case assumptions are based on locations of  
21 maximum concentration even though it is not expected that such receptors will ever actually exist at these  
22 locations. Both scenarios reflect current uses of the surrounding land and habitat and reasonable  
23 assumptions about future uses of the land and habitat.

24 During the environmental performance demonstration, emission samples are collected and analyzed, and  
25 the data used to evaluate risk to the human population and ecological (such as wildlife) receptors.  
26 Operating conditions are established for the WTP, which limit risks to human health and the environment  
27 to acceptable levels.

## 28 **4.4 Other Waste Management Units**

29 Sections 4.4.1 through 4.4.5 discuss the applicability of the requirements for waste management units that  
30 have not been discussed up to this point in the permit. Sections 4.4.6 through 4.4.9 describe the  
31 applicability of air emission controls, waste minimization, groundwater monitoring, and functional design  
32 requirements to the WTP. References to other sections of the permit are provided as appropriate.

### 33 **4.4.1 Waste Piles**

34 The operation of the WTP does not involve the placement of dangerous waste in waste piles. Therefore,  
35 the requirements of WAC 173-303-660, *Waste piles*, do not apply to the WTP.

### 36 **4.4.2 Surface Impoundments**

37 The operation of the WTP does not involve the placement of dangerous waste in surface impoundments.  
38 Therefore, the requirements of WAC 173-303-650, *Surface impoundments*, do not apply to the WTP.

### 39 **4.4.3 Incinerators**

40 The WTP does not include a dangerous waste incinerator. However, applicable sections of the incinerator  
41 requirements in WAC 173-303-670 and 40 CFR Section 63.1203 apply to the WTP.

1 **4.4.4 Landfills**

2 The operation of the WTP does not involve the placement of dangerous waste in landfills. Therefore, the  
3 requirements of WAC 173-303-665, *Landfills*, do not apply to the WTP.

4 **4.4.5 Land Treatment**

5 The operation of the WTP does not involve the land treatment of dangerous waste. Therefore, the  
6 requirements of WAC 173-303-655, *Land treatment*, do not apply to the WTP.

7 **4.4.6 Air Emissions Control**

8 Information regarding air emissions control is provided in the following sections:

- 9 • PTF Vessel Vent Process and Exhaust System (PVP/PVV) - Chapter 4D, Section 4D.4.2.
- 10 • LAW Vitrification Facility offgas treatment system description - Chapter 4E, Section 4E.4.2.
- 11 • HLW Vitrification Facility offgas treatment system description - Chapter 4F, Section 4.2.
- 12 • DFLAW EMF Vessel Vent Process System (DVP) - Chapter 4G, Section 5.1.
- 13 • Process vents (40 CFR 264 Subpart AA) - Section 4.2.9.2.
- 14 • Equipment leaks (40 CFR 264 Subpart BB) - Section 4.2.9.3.
- 15 • Tanks and containers (40 CFR 264 Subpart CC) - Section 4.2.9.4.

16 C1 Ventilation (C1V) System

17 C1 areas are normally occupied and are expected to remain free of contamination. C1 areas will be  
18 operated slightly pressurized relative to atmosphere and other adjacent areas. The C1V system consists of  
19 air handling units, change rooms exhaust fan, ductwork, and accessories. Areas served by this system  
20 include:

- 21 • Office spaces.
- 22 • Control Room.
- 23 • Incident Command Post (ICP) (During DFLAW operations).
- 24 • Lunch Room.
- 25 • Restrooms.
- 26 • Change Rooms.
- 27 • Truck Bays.
- 28 • LAW Switchgear Building.

29 C2 Ventilation (C2V) System

30 C2 areas will typically consist of non-process operating areas, equipment rooms, stores, access corridors,  
31 and plant rooms adjacent to areas with higher contamination potential. The C2V is served by dedicated air  
32 handling units and exhaust fans. Ventilation air supplied to C2 areas will be exhausted by the C2 exhaust  
33 system and cascaded into adjacent C3 areas. The C2 areas will maintain a nominal negative pressure  
34 relative to atmosphere. C2 exhaust will pass through one stage of HEPA filters and be discharged to the  
35 atmosphere by the exhaust fans. Supply and exhaust fans are provided with variable frequency drives.

36 C3 Ventilation (C3V) System

37 C3 areas are normally unoccupied, but allow operator access, for instance during maintenance. C3 areas  
38 will typically consist of filter plant rooms, workshops, maintenance areas, and monitoring areas. Air will  
39 generally be drawn from C2 areas and, wherever possible, cascaded through the C3 areas into C5 areas, or  
40 alternatively exhausted from the C3 areas by the C3 exhaust system. In general, air cascaded into the  
41 C3 areas will be from adjacent C2/C3 subchange rooms. C3 exhaust will pass through one stage of HEPA

1 filters and be discharged to the atmosphere by the exhaust fans. C3 exhaust fans are provided with  
2 variable frequency drives.

### 3 C5 Ventilation (C5V) System

4 Where there is in-bleed air from the C3 system to the C5 system, fan cascade trip interlocks protect the  
5 system from backflow. Air will be cascaded into the C5 areas and exhausted by the C5 exhaust system.  
6 The C5 exhaust will pass through two stages of HEPA filters and be discharged to the atmosphere by the  
7 exhaust fans. C5 exhaust fans are provided with variable frequency drives.

8 The C5 areas in the LAW Vitrification Facility will be composed of the following:

- 9 • Pour caves.
- 10 • Container transfer tunnel.
- 11 • Buffer storage area.
- 12 • C3/C5 drains/sump collection vessel room.
- 13 • Process cells.
- 14 • Finishing line.

15 Containment will be achieved by maintaining C5 areas at the greatest negative pressure, with airflows  
16 cascaded through engineered routes from C2 areas to C3 areas and on to the C5 areas. The cascade  
17 system, in which air passes through more than one area, will reduce the number of separate ventilation  
18 streams and hence the amount of air requiring treatment. Adherence to this concept in the design and  
19 operation of the LAW Vitrification Facility will ensure that the ventilation air does not become a  
20 significant source of exposure to operators, and that the air emissions do not endanger human health or  
21 the environment.

22 Ventilation system duct work is not required to be doubly contained within the WTP Unit. However,  
23 upon discovery of accumulation of liquids within the duct work, a compliance plan will be submitted  
24 within sixty (60) days of discovery to correct the problems.

#### 25 **4.4.7 Waste Minimization**

26 Waste minimization information is presented in Operating Unit Group 10 of the permit.

#### 27 **4.4.8 Groundwater Monitoring for Land-Based Units**

28 The groundwater monitoring requirements found in WAC 173-303-645, *Releases from regulated units*,  
29 do not apply to the WTP, since it is not operated as a regulated dangerous waste surface impoundment,  
30 landfill, land treatment area or waste pile, as defined in WAC 173-303-040. Therefore, groundwater  
31 monitoring is not required.

#### 32 **4.4.9 Functional Design Requirements**

33 The WTP is designed to comply with applicable design codes and specifications. The documents  
34 referenced in this chapter appendices and contained in DWP Operating Unit Group 10 identify the codes  
35 and standards to which the WTP system, structures, and components are being constructed.