

August 13, 1974

Memo to: Howard Bunten

From: Dan Glantz

Subject: Millwood STP Survey

State of
Washington
Department
of Ecology



A survey of the Millwood treatment plant was made on May 22, 1974. Samples were composited on the half hour commencing at 0830 and ending at 1500 hours.

This is a package type plant, a "Smith & Loveless Oxigest" to be exact. It is located on the bank of the Spokane River, under a covered shed, open on one side. The plant is designed for 300 families and serves 177 at the present time. There is no record of recent bypass being required.

The influent samples should not be considered reliable. The sludge from the sedimentation basin returns directly into the influent flow area as it emerges from the comminutor and the heavy concentration of solids was unavoidable. The effluent samples though, are realistic. Remaining solids are undoubtedly having an adverse effect on the chlorine treatment which is probably hampered further by limited detention. It is obvious, from the high coliform count, this plant is not performing satisfactorily.

Field and laboratory data are attached.

DG:jmh

STP Survey Report Form

Efficiency Study

City Millwood Plant Type Oxigester Pop. Served 177 Design 300
 Capacity
 Receiving Water Spokane River Perennial X Intermittent _____
 Date 5/22/74 Survey Period 0830 - 1600 hours Survey Personnel D. Glantz
 Comp. Sampling Frequency 1/2 hour Sampling Alequot 800 ml.
 Weather Conditions (24 hr) Sunny Are facilities provided for complete by-
 pass of raw sewage? X Yes _____ No/Frequency of bypass none
 Reason for bypass _____ Is bypass chlorinated? _____ Yes _____ No
 Was DOE Notified? _____ Discharge - Intermittent _____ Continuous _____

Plant Operation

Total flow 10,000 GPD How measured Weir
 Maximum flow 12,000 GPD Time of Max. 0900
 Minimum flow 8,000 GPD Time of Min. Noon
 Pre Cl₂ _____ #/day Post Cl₂ 2 1/2 #/day

Field Results

Influent

Effluent

<u>8 Determinations</u>	<u>Max.</u>	<u>Min.</u>	<u>Mean</u>	<u>Median</u>	<u>Max.</u>	<u>Min.</u>	<u>Mean</u>	<u>Median</u>
Temp °C	13.0	12.0		13.0	14.0	12.5		13.0
pH (Units)	7.3	6.9		7.2	7.4	7.0		7.2
Conductivity (µmhos/cm ²)	675	425		600	650	600		610
Settleable Solids (mls/l)	400	350	388	400	23.0	5.5	13.25	13.0

Laboratory Results on Composites

	<u>Influent</u>	<u>Effluent</u>	<u>% Reduction</u>
Laboratory No.	<u>74-1883</u>	<u>74-1884</u>	
5-Day BOD ppm	<u>1090</u>	<u>118</u>	<u> </u>
COD ppm	<u>2175</u>	<u>148</u>	<u> </u>
T.S. ppm	<u>2124</u>	<u>397</u>	<u> </u>
T.N.V.S. ppm	<u>547</u>	<u>225</u>	<u> </u>
T.S.S. ppm	<u>1895</u>	<u>123</u>	<u> </u>
N.V.S.S. ppm	<u>365</u>	<u>40</u>	<u> </u>
pH (Units)	<u>6.9</u>	<u>7.0</u>	<u> </u>
Conductivity (µmhos/cm ²)	<u>570</u>	<u>560</u>	<u> </u>
Turbidity (JTU's)	<u>36</u>	<u>38</u>	<u> </u>

Laboratory Bacteriological Results

Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl ₂ Residual	
		Total Coliform	Fecal Coliform	Fecal Strep	15"	3 Min
74/1885	0900	25,000	Est. 330		.3	.5
86	1100	18,000	" 410		.3	.75
87	1200	Est. 6,500	" 220		.4	.75
88	1300	2,800	" 70		.4	1.0
89	1400	21,000	" 300		.2	.5
90	1500	5,600	" 320		.3	.75

Additional Laboratory Results


NO ₃ -N ppm	-	.02	
NO ₂ -N ppm	-	ND	
NH ₃ -N ppm	-	(1)	
T. Kjeldahl-N ppm	-	(1)	
O-PO ₄ -P ppm	-	.02	
T-PO ₄ -P ppm	-	13.0	

(1) Sample held too long to analyze.

Operator's Name Bob Rapp Phone No. 924-0960

(Al Dougherty)

Furnish a flow diagram with sequence and relative size and points of chlorination.



Type of Collection System

Combined Separate Both

Estimate flow contributed by surface or ground water (infiltration)

_____ MGD

Plant Loading Information

Annual average daily flow rate (mgd)

Peak flow rate (mgd)

Dry _____

Dry _____

Wet _____

Wet _____

COMMENTS: _____

