

August 12, 1974

**Publication No. 74-e09**

WA-07-1110

State of  
Washington  
Department  
of Ecology



Memo to: John Glynn

From: Hans Cregg

Subject: Efficiency Survey Conducted at North Bend STP.

During April 23, 1974, an efficiency study was conducted at the North Bend Sewage Treatment Plant. The operator appears to be concerned with the workings of his plant and is well aware of its existing shortcomings. He is particularly plagued with the problem of getting parts for the outdated pumps and machinery.

Lab results show that BOD, COD and total solids reductions are reasonable for a primary plant with room for improvement. They are 42%, 23% and 23% respectively. The only immediate problem to be dealt with is the high coliform level (both total and fecal). The additional coliform samples taken upstream and downstream from the STP discharge point show the following results:

	Upstream	Downstream
Total Coliform	32,000	24,000
Fecal Coliform	Est. 80	1,700

HC:jmh

STP Survey Report Form

Efficiency Study

City North Bend Plant Type Primary Pop. Served \_\_\_\_\_ Design \_\_\_\_\_  
 Receiving Water \_\_\_\_\_ Perennial \_\_\_\_\_ Intermittent \_\_\_\_\_  
 Date 4/23/74 Survey Period 8 hour Survey Personnel Hans Cregg  
 Comp. Sampling Frequency Every 1/2 hour Sampling Alequot 1000 mls.  
 Weather Conditions (24 hr) Rainy Are facilities provided for complete by-  
 pass of raw sewage? \_\_\_\_\_ Yes \_\_\_\_\_ No/Frequency of bypass \_\_\_\_\_  
 Reason for bypass \_\_\_\_\_ Is bypass chlorinated? \_\_\_\_\_ Yes \_\_\_\_\_ No  
 Was DOE Notified? \_\_\_\_\_ Discharge - Intermittent \_\_\_\_\_ Continuous \_\_\_\_\_

Plant Operation

Total flow See Attached Letter How measured \_\_\_\_\_  
 Maximum flow \_\_\_\_\_ Time of Max. \_\_\_\_\_  
 Minimum flow \_\_\_\_\_ Time of Min. \_\_\_\_\_  
 Pre Cl<sub>2</sub> \_\_\_\_\_ #/day Post Cl<sub>2</sub> \_\_\_\_\_ #/day

Field Results

Influent

Effluent

<u>Determinations</u>	<u>Max.</u>	<u>Min.</u>	<u>Mean</u>	<u>Median</u>	<u>Max.</u>	<u>Min.</u>	<u>Mean</u>	<u>Median</u>
Temp °C	12	11		11	11	10		10
pH (Units)	6.8	6.5		6.6	6.8	6.4		6.7
Conductivity (µmhos/cm <sup>2</sup> )	180	150		150	160	150		150
Settleable Solids (mls/l)	10	7.5	8.5	8	2	1.5	1.6	1.5

Laboratory Results on Composites

	<u>Influent</u>	<u>Effluent</u>	<u>% Reduction</u>
Laboratory No.	<u>74-1353</u>	<u>74-1354</u>	
5-Day BOD ppm	<u>&lt;100</u>	<u>58</u>	<u>42</u>
COD ppm	<u>118</u>	<u>91</u>	<u>23</u>
T.S. ppm	<u>173</u>	<u>134</u>	<u>23</u>
T.N.V.S. ppm	<u>67</u>	<u>54</u>	<u>20</u>
T.S.S. ppm	<u>52</u>	<u>25</u>	<u>48</u>
N.V.S.S. ppm	<u>0</u>	<u>0</u>	<u>---</u>
pH (Units)	<u>6.9</u>	<u>6.9</u>	
Conductivity (µmhos/cm <sup>2</sup> )	<u>190</u>	<u>130</u>	
Turbidity (JTU's)	<u>20</u>	<u>15</u>	

Laboratory Bacteriological Results

Lab No.	Sampling Time	Colonies/100 ml (MF)			Cl <sub>2</sub> Residual	
		Total Coliform	Fecal Coliform	Fecal Strep	15 sec	3 min
74-1355	0930	>4 x 10 <sup>4</sup>	> 4000		0	0
1356	1130	>4 x 10 <sup>4</sup>	> 4000		0	0
1357	1130 <sup>1</sup>	32,000	Est.80			
1358	1130 <sup>2</sup>	24,000	1,700			
1359	1330	>4 x 10 <sup>4</sup>	> 4000		.05	.15
1360	1430	>4 x 10 <sup>4</sup>	12,000		.1	.4

- 1 - Upstream
- 2 - Downstream

Additional Laboratory Results

NO <sub>3</sub> -N ppm	-	4.15	
NO <sub>2</sub> -N ppm	-	N.D.	
NH <sub>3</sub> -N ppm	-	4.85	
T. Kjeldahl-N ppm	-	5.3	
O-PO <sub>4</sub> -P ppm	-	.92	
T-PO <sub>4</sub> -P ppm	-	2.90	

Operator's Name \_\_\_\_\_ Phone No. \_\_\_\_\_

Furnish a flow diagram with sequence and relative size and points of chlorination.

Type of Collection System

Combined  Separate  Both

Estimate flow contributed by surface or ground water (infiltration)

\_\_\_\_\_ MGD

Plant Loading Information

Annual average daily flow rate(mgd)

Peak flow rate(mgd)

Dry \_\_\_\_\_

Dry \_\_\_\_\_

Wet \_\_\_\_\_

Wet \_\_\_\_\_

COMMENTS: \_\_\_\_\_



HAMMOND, COLLIER, & WADE — LIVINGSTONE ASSOCIATES, INC.

CONSULTING ENGINEERS  
 4010 STONE WAY NORTH  
 SEATTLE, WASHINGTON 98103

TELEPHONE: (206) 632-2664

GEORGE R. HAMMOND  
 WILLIAM P. COLLIER  
 LARRY R. WADE  
 DAVID LIVINGSTONE  
 BRUCE LIVINGSTONE  
 GORDON S. RECTOR  
 TED F. LUEBKE

April 24, 1974

State of Washington  
 Department of Ecology  
 Comp. Investigations & Studies Division  
 Olympia, Washington 98504

Attention: Mr. Hans Cregg, Instrument Technician

Subject : North Bend S.T.P. Field investigation, 23 April 1974.

Dear Hans:

Following are the results of the flow measurements we made between about 10:30 and 11:30 AM while you were taking samples, etc.

Our measurements were made by the cross-sectional area of flow/velocity method. The area of flow in the 10-inch effluent sewer was calculated from measurements from the crown of the pipe to the water surface at both ends of the test section, and averaged. Velocity was determined by timing (stop-watch) slugs of dye through the 317.4 ft. test section.

Data and results:

10" Effluent Sewer, D	= 0.83 ft.		0.83 ft.
Upstream, crown to W.S.	= <u>0.35 ft.</u>	Downstream, crown to W.S.	= <u>0.50+ ft.</u>
Upstream, d	<u>0.48 ft.</u>	Downstream d	= <u>0.33 ft.</u>

'd' for calculations assumed to be the average and = 0.40 ft.  
 Cross-section area of flow for 'd' assumed = 0.256 sq. ft.  
 Length of test section = 317.4 ft.

<u>Observation</u>	<u>Min. - Sec.</u>	<u>Sec.</u>	<u>Velocity,</u> <u>ft/sec.</u>	<u>C.F.S.</u>	<u>G.P.M.</u>
No. 1	1:42	102.	3.11	0.796	357
No. 2	1:42.6	102.6	3.09	0.791	355
No. 3	1:40	100.	3.17	0.812	365
No. 4	1:39	99.	3.21	0.822	369

North Bend S.T.P.  
Field investigation, 23 April 1974

I suspect that the calculations from No. 3 and No. 4 are a little low as the cross-section of flow was undoubtedly increasing; since it was in a state of change (and we had used all our dye) I could see no point in re-measuring the depths.

The elevation of the water surface in the wet well was measured just before the first and just after the last flow observations. Reading from the system curves prepared and confirmed by flow measurements during the study for our comprehensive plan, both pumps operating together should have been delivering about 643 and 660 gpm when working from the two water levels observed.

After making the flow calculations and noting that they were on the order of half of what they should be, I telephoned Mr. Schultz for confirmation that both pumps had been in operation during our observations; he assured me that they were.

If I can be of any further help, please call.

Yours very truly,

HAMMOND, COLLIER & WADE - LIVINGSTONE  
ASSOCIATES, INC.

A handwritten signature in dark ink, appearing to read 'D. Livingstone', is written over a horizontal line.

David Livingstone, P.E.

cc: Robert Schultz, Supt. of Public Works

DL/lc