



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

3601 W. Washington • Yakima, Washington 98903-1164 • (509) 575-2800

November 30, 1992

Garret Horsley
dba Horsley Orchards
240 Borquin Road
Wapato WA 98951

Re: Ground Water Application No. G4-31341 - PRELIMINARY PERMIT

Ground Water Application No. G4-31341 was filed by Garret Horsley dba Horsley Orchards on July 9, 1992. An Emergency Drought Authorization was issued on July 28, 1992.

During the 1992 irrigation season, the demand for water well drillers was higher than the number capable of constructing large supplemental irrigation wells. Mr. Horsley was unable to construct the emergency irrigation wells before the termination of the Drought Emergency Authorization issued for Ground Water Application No. G4-31341. Since the possibility exists that irrigation water shortages during the 1993 irrigation season and a similar demand for water well drillers may occur, Garret Horsley dba Horsley Orchards is, hereby, issued a PRELIMINARY PERMIT to construct two wells capable of providing supplemental irrigation water but is not authorized the beneficial use of water from the wells.

This PRELIMINARY PERMIT is issued with the following conditions and requirements:

1. Well No. 1 is to be constructed within the ~~E_{1/4}~~^{W_{1/2} of 4-9-93} of Section 5, T. 11 N., R. 20 E.W.M. Well No. 2 is to be constructed within the ~~SE_{1/4}NE_{1/4}~~ of Section 6, T. 11 N., R. 20 E.W.M.
2. The two wells to be constructed are limited to a combined production capacity of 1900 gallons per minute, corresponding to the requested instantaneous capacity in Ground Water Application No. G4-31341.
3. These wells are authorized to be constructed into the sedimentary deposits known as the Ellensburg Formation and shall be cased and effectively sealed to a minimum depth of 18 feet below land surface.
4. Installation and maintenance of an access port as described in Ground Water Bulletin No. 1 is required. An air line and gage may be installed in addition to the access port.

*Did not reflect
6-24-92 change.*

5. All water wells constructed within the state shall meet the minimum standards for construction and maintenance as provided under RCW 18.104 (Washington Water Well Construction Act of 1971) and Chapter 173-160 WAC (Minimum Standards for Construction and Maintenance of Water Wells).
6. No beneficial use of water is authorized until a regular permit or Drought Emergency Authorization is issued pursuant to Ground Water Application No. G4-31341.
7. This PRELIMINARY PERMIT shall remain in effect until October 31, 1993, unless revoked sooner for cause.

You have the right to obtain review of this order. Request for review must be made, within thirty (30) days of receipt of this order, to the Washington Pollution Control Hearings Board, PO Box 40903, Olympia, Washington 98504-0903. Concurrently, a copy of the request must be sent to the Department of Ecology, PO Box 47600, Olympia, Washington 98504-7600. These procedures are consistent with the provisions of Chapter 43.21B RCW and the rules and regulations adopted thereunder.

Sincerely,



Darlene M. Frye
Technical Unit Supervisor
Water Resources Program

DMF:gh
9211134.pp

Enclosure: Ground Water Bulletin No. 1